

## Performance

Unit Tag: OKAY

## Summary

## Unit Details

Unit Tag:	OKAY	Orientation:	Horizontal
Model:	A16IN - (325 - 775 CFM)	ESP SA / RA (inH <sub>2</sub> O):	0.75 / 0.75
Qty:	1	Filters OA / RA:	2" 85% MERV-13 / 2" 30% MERV-8
Location:	Indoor	Controls Preference:	Constant Volume
Altitude (ft):	0	Dampers & Actuator:	NA
Bypass:	No		

## Electrical Requirements

Total Number of Connections Required: 2

Unit	Preheat Electric Heater
Voltage: 208V/1ph/60Hz	Std. Coil: 1
Range: 207 - 253V	Controls: SCR
FLA: 5.29	Voltage: 208V/3ph/60Hz
MCA: 5.91	Range: 187.2 - 218.4V
RFS: 15A	FLA: 11.12
	MCA: 13.9
	RFS: 15A
	Max KW: 4

## Preheat Electric Heater

Actual	
Outdoor Air (CFM):	325
Voltage:	208V/3ph/60Hz
kW:	0.1
Ent. Air DB/WB (F):	35 / 33
Lvg Air DB/WB (F):	36 / 33.6
Installation:	In Casing – Field Mounted and Wired
*Separate electrical connection required for heater	

## Heat Exchanger

Design Conditions	Outdoor Air	Return Air
SCFM:	325	325
Summer DB (F) / WB (F) / RH (%):	95 / 78 / 47.3	75 / 63 / 51.2
Winter DB (F) / WB (F) / RH (%):	36 / 33.6 / 78.7	70 / 52.9 / 30

Performance Leaving Air	Supply Air	Exhaust Air
SCFM:	325	325
Summer DB (F) / WB (F) / RH (%):	80 / 68.7 / 56.5	90 / 73.4 / 46
Winter DB (F) / WB (F) / RH (%):	61.4 / 48.3 / 36.2	44.6 / 39.5 / 63.5

Performance	Summer	Winter
Supply Air PD (inH2O):	0.24	0.24
Exhaust Air PD (inH2O):	0.51	0.51
Sensible Effectiveness %:	74.8	74.8
Latent Effectiveness %:	60.3	60.3
Total Effectiveness %:	65.9	72.9
EATR %:	0.5	0.5
OACF:	1.00	1.00
Net Supply Airflow (SCFM):	325	325
Energy Recover Ratio %:	65.97	72.83
BTU/H Saved	12405	10061



This statement Certified in accordance with AHRI ERV Certification Program, which is based on AHRI Standard 1060. Certified units may be found in the AHRI Directory at [www.ahridirectory.org](http://www.ahridirectory.org)

