

STAR PROPERTY MANAGEMENT

Southwest Texas Residential Portfolio

MAINTENANCE WORK-ORDER — TICKET REPORT

Ticket Number	MT-2026-083
Priority	Medium
Completion Date	2026-05-13

Description / Work Detail

HVAC compressor belt replacement completed in Building C lobby. Unit returned to full operation. Ticket closed following successful post-repair test.