Sasa Mamoloko Gemivah

34
40
85.1%

WIRE WAYS AND WIRING

SUMMATIVE ASSESMENTS

Module #	671101000-KM-05:
NQF Level	level 4,
Notional hours	110
Credit(s)	Cr 11
Occupation or Specialisation	671101000: Occupational Certificate: Electrician
Associated Occupation	671101: Electrician

Details	Please Complete this Section
Name	Mamoloko Gemivah
Surname	Sasa
Cell NUMBER	082 286 8527
E-mail	mamolokog6@gmail.com

Training	Classroom training registers	Training Provider Date:	
Self assessment	Assessment contract signed & dated	Learner file Date:	
Assessment contract	Assessment contract signed & dated	Learner file Date:	
Initial meeting	Assessor briefing checklist	Learner file Date:	
	Assessment contract & assessment plan	Learner file Date:	
Formative Assessment	Assessment instruments	Learner file Date:	
Summative Assessment	Assessment instruments	Learner file Date:	
Other Evidence	Research portfolio (if applicable)	Learner file Date:	
Feedback	Feedback Report	Learner file Date:	
Moderation	Moderators report	Learner file Date:	
Judgement	Assessor Summary Report / Moderator report	Learner file Date:	
1st Reassessment	Assessors summary report / instruments	Learner file Date:	
2nd Reassessment	Assessors summary report / instruments	Learner file Date:	

Special arrangements for assessment

Place
Language
Resources
Barriers

- If not all evidence available was taken into account during the assessment
- The assessor was not a subject matter expert or did not have a subject matter expert during the assessment process
- The assessor did not assess according to the performance criteria and range statement stipulated in the unit standard
- Not all the range items were available for assessment

2. A learner bringing an appeal against a decision of the assessment will lodge such an appeal with the assessor and the internal moderator within 2 days of the assessment feedback session.

3. A learner bringing an appeal should complete the "Learner's Notice of Assessment Appeal "form before the Appeal Hearing. The form should be handed to the internal moderator or a representative of the SETA.

4. Should the internal moderator re-affirm the assessor' decision, the learner may appeal to the external verifier within 2 days after the initial moderator's feedback session. The external verifier's decision will be final. Should the external verifier re-affirm the assessors' decision, the cost for re-evaluation will be upon the learner. Should the verifier's decision differ from the assessor's decision, the cost for re-evaluation will be borne by the assessor.

ASSESSMENT APPEAL APPLICATION FORM

LEARNER'S NOTICE OF ASSESSMENT APPEAL

TO: The Internal Moderator

Reasons for Appeal

No	Please give detailed reasons for the choice(s) above
1	
2	
3	
4	
5	

Learner's signature: _____ Date: _____

Employee witness: _____ Date: _____

FASTC TECHNOCENTRIC VARSITY

Learner declaration of acceptance of assessment instruments and relevant documentation: Date:	
Learners Name: Sasa Mandato	Signature Sasa M.G
Assessors Name:	Signature:

EASTC TECHNOCENTRIC VARSITY

INSTRUCTIONS:

The following sections will test your knowledge and you are required to answer all the questions.

All true and false items must be answered.

Once you have finished you may obtain feedback from your assessor on the accuracy of your answer.

and large buildings.

8

③ Trunking
- Is a rectangular enclosure used to carry several electrical cables in one system.
- Often used in offices, schools and commercial buildings to distribute power.

④ Ducting
- Is an underground or enclosed pathway for electrical cables.
- Used for underground electrical installation or where cables need extra protection.

⑤ Wire Basket / Ladder Tray
- This is an open metal support system for routing cables.
- Used mainly for data cables and light electrical wiring in commercial buildings and data centres.

Task	Questions Description	Marks
3	a) Describe the principles of operation of various control systems	5
	b) Describe the principles of operation of single and three phase circuit breakers and core balance earth leakage relays (wound primaries and straight primaries with tripping relay)	5

(a) ① Manual Control System is operated directly by a person using switches or push buttons to start or stop equipment.

② Automatic Control System operate systematically using sensors, timers or relays without human intervention.

③ Remote Control System - equipment is controlled from a distance using control circuits, remote switches or communication device.

④ feedback control system - monitors output and automatically adjust operation to maintain the desired performance.

(b) ① Single phase circuit breaker - protect a single phase electrical circuit. When the current exceeds the safe limit due to overload or short circuit, the breaker trips and disconnect the power supply to prevent damage.

② Three phase circuit breaker - protects three phase electrical systems. It disconnect all 3 phases simultaneously when a fault such as overload occurs.

③ Core balance earth leakage Relay - detects current flowing to earth. The phase and neutral conductors pass through a current transformer core. If there's a leakage, the currents become unbalanced and the relay trips the circuit breaker to protect people and equipments.

(b) A common electrode is a single earth electrode that is used to provide earthing for multiple circuits within a reticulation system.

How it is used in Reticulation Circuits

- All the metallic parts of the system are connected to one common earth electrode
- This creates a common reference point for the entire work
- It allows faults current to the flow safely to the ground

(c) Earthing of underground cables

Purpose:

- Protects against insulation failure
- Prevent electric shock
- Protect cable from mechanical and electrical damage
- Protects against insulation failure.

Additional protection:

- Link boxes or earth continuity conductors may be used
- Cross bonding for high-voltage cables.

Earthing of overhead lines.

Purpose:

- protects against lightning strikes
- Provide path for fault current
- keeps structures safe to touch
- Ensures proper operation of protection devile.

10

Assessor's Report

Candidate's Name	Sasa Mamoloko	ID No.	030426072908
Assessor's Name		Reg. No.	
Title			

ASSESSMENT DECISION

Outcome	C	NYC	Comments

OVERALL COMPETENCE JUDGEMENT:

Comments

Date	
Signature of Assessor	Signature of Candidate M.G

M. G

Candidate Appeal Form

Candidate's Name: Sasa Mamoloko		ID No.	0304260729088
Assessor's Name:		Reg. No.	
Title: Wireways and Wiring			
Date:			
SECTION 1			
Candidate's reason for disagreeing with the assessment decision			
Assessor's rationale for the assessment decision			
Candidate's signature			
Assessor's signature			
SECTION 2			
Moderator's decision			
Moderator's signature			

EASTC TECHNOCENTRIC VARSITY

ASSESSMENT REVIEW

NAME of LEARNER	NAME of ASSESSOR
VENUE	DATE of REVIEW

Review Dimension	ASSESSOR	LEARNER/ CANDIDATE	ACTION
The principles/criteria for good assessment were achieved?	☐Agree ☐Disagree	☑Agree ☐Disagree	
The assessment related to the registered unit standard?	☐Agree ☐Disagree	☑Agree ☐Disagree	
The assessment was practical?	☐Agree ☐Disagree	☑Agree ☐Disagree	
It was time efficient and cost-effective and did not interfere with my normal responsibilities?	☐Agree ☐Disagree	☑Agree ☐Disagree	
The assessment instruments were fair, clear and understandable	☐Agree ☐Disagree	☑Agree ☐Disagree	
The assessment judgements was made against set requirements	☐Agree ☐Disagree	☑Agree ☐Disagree	
The venue and equipment was functional?	☐Agree ☐Disagree	☑Agree ☐Disagree	
Special needs were identified and the assessment plan was adjusted	☐Agree ☐Disagree	☑Agree ☐Disagree	
Feedback was constructive against the evidence required	☐Agree ☐Disagree	☑Agree ☐Disagree	
An opportunity to appeal was given	☐Agree ☐Disagree	☑Agree ☐Disagree	
The evidence was recorded	☐Agree ☐Disagree	☑Agree ☐Disagree	

LEARNER'S DECLARATION OF UNDERSTANDING

I am aware of the moderation process and understand that the moderator could declare the assessment decision invalid

Learner Date	Assessor Date	Moderator Date
Sasa MG		

MG