

1. Document

1.1 Change notice CN-2026-03 for feedwater pump FP-200, revision C.

2. Interval change

2.1 The service interval moves from 1,500 operating hours to 2,000 operating hours with effect from revision C.

3. Superseded revision

3.1 Revision B is superseded and must not be used to schedule work on this pump.