

1. Document

1.1 Scheduled maintenance for feedwater pump FP-200, revision B.

2. Service interval

2.1 Perform the full service procedure every 1,500 operating hours.

3. Seal replacement

3.1 Before replacing the mechanical seal, isolate the unit and fully depressurise the casing. Confirm zero pressure at gauge PG-11 before removing any fastener.

4. Duty rating

4.1 The pump is rated for continuous duty at 2.4 MPa discharge pressure, and inspection points are listed in table 12.1.