

FABRICATED REINFORCEMENT INSPECTION

Minimum Frequency - EACH DELIVERY

1. Review delivery docket to confirm quantity and other specific information.
2. Check each delivery conforms to the relevant drawing or specific requirements including relevant AS (i.e., AS 4671, AS 3679, AS 4291 etc).
3. Check at rate of 1 in 50 (min 2 per type, per delivery) or 1 in 200 (min 1 per type, per delivery) if supplier is a Quality Endorsed Company.
4. Check all critical dimensions and features as specified. (Visual comparison to existing sample is recommended).
5. Initial PASS or FAIL box.

If non-conforming do the following:

- a. Advise the designated quality coordinator of non-conformance and provide them with a copy of this form. – *NCR shall be raised.*
b. Check a further 2 items (in the sample size).
c. If any of these samples do not conform reject the delivery - or test 100% and accept all satisfactory items.
d. Isolate and identify all defective reinforcing or batches of reinforcing.

[illegible]

Document ID: POLES_QA_FOR_008_Fabricated Reinforcement Inspection	Version No.: 1	Approved By: Joshua Myhill (Operations Supervisor)	
This is a controlled document managed by Civilmart. UNCONTROLLED if printed		Effective Date: 02/07/2024	Revision Date: 02/07/2024

FABRICATED REINFORCEMENT INSPECTION

Document History:

Version No.:	Date:	Description	Made by	Reviewed by	Approved by
1	02/072024	Initial Issue	Joshua Myhill	Joshua Myhill	Joshua Myhill