

 <div style="display: inline-block; vertical-align: middle;"> <b>Arc Plastering (Aust) Pty Ltd</b>  <small>ABN 18 091 630 670</small> </div>	<h2 style="margin: 0;">Inspection and Test Plan</h2>	BLL ITP No. 02
		Reviewed by:
		Review date:

### Wall Framing

Framing is installed in accordance with:

- AS 4100 – Steel Structures
- AS/NZS 4600 – Cold-formed steel structures

**Project:** Frankston Hospital Redevelopment

**Area/Zone:** \_\_\_\_\_

**Level:** \_\_\_\_\_

**PREPARED BY:** Inez Giannetti

**Date:** 21/02/2024

Signature: \_\_\_\_\_



**ITP Revision No:** 01

**Position:** Project Administrator

**APPROVED BY:** Pat Moore

**Date:** 21/02/2024

Signature: \_\_\_\_\_



**Position:** Company Director

### KEY

**H** – Hold Point (mandatory)

**H(A)** Local Authority Inspection

**X** – Self Inspection by performer of work    **H(C)** Consultant Inspection

**S** – Surveillance or Monitoring

**Inspection Frequency:** To be completed at zone completion

Item No.	INSPECTION & TEST ITEMS <i>(Include Description, Characteristics &amp; Necessary Inspections)</i>	Inspection Procedure	ACCEPTANCE CRITERIA Specification / Standard / Drawings	RECORD AND COMMENTS				
				Arc Plastering		Lendlease		Comments
				Key	Sign	Key	Sign	

1.	<b>Approve Samples as follows:</b> <ul style="list-style-type: none"> <li>- Manufacturer's / supplier's recommendations</li> <li>- Product Data</li> <li>- Review CiDD Alerts and Guidelines</li> <li>- Engineering design recommendations</li> </ul> <p>If applicable, ensure prototype is built / supplied on site</p>	Prior to Delivery	<b>At project commencement, ensure samples reflect:</b> <ul style="list-style-type: none"> <li>- Architectural specifications and latest:</li> <li>- Material finishes schedule</li> <li>- Drawings</li> </ul> <p><b>Drawings:</b> _____</p> <p><b>Rev:</b> _____</p>	S		S		
----	--	-------------------	---	---	--	---	--	--



4.	<b>Installation of Framing as follows:</b> <ul style="list-style-type: none"> <li>- Frames installed to set out</li> <li>- Fixings as per manufacturer's guidelines</li> <li>- True and plumb</li> <li>- Installation of top bracket as per engineers' details for the wall type</li> </ul>	Visual Inspection prior to fixing ceiling linings	<b>Ensure framing is installed in accordance with:</b> <ul style="list-style-type: none"> <li>- Architectural Drawings</li> <li>- Design Specifications</li> <li>- Latest Drawing References and Revisions</li> </ul> <p>Progression photos to be documented</p> <b>Hold point. Sign off by other trades witnessed</b> <p>Drawings: _____</p> <p>Rev: _____</p>	H		S		
5.	<b>Overall lining installation as follows:</b> <ol style="list-style-type: none"> <li><u>Wall Linings</u> <ul style="list-style-type: none"> <li>- Type and Material</li> <li>- Colour and Finish</li> <li>- Size and Thickness</li> <li>- Neatness of Cutting</li> <li>- Fixing and Jointing</li> <li>- Squareness and Flatness</li> <li>- Smoothness and Uniformity</li> <li>- Lapping and Staggering</li> </ul> </li> <li><u>Control Joint</u> <ul style="list-style-type: none"> <li>- Control Joint Locations</li> </ul> </li> <li><u>Insulation</u> <ul style="list-style-type: none"> <li>- Insulation is installed as per acoustic and thermal requirements</li> </ul> </li> <li><u>Noggings as required</u></li> </ol>	Visual Inspection upon installation of lining	<b>Ensure the lining, joints and insulation is installed in accordance with:</b> <ul style="list-style-type: none"> <li>- Architectural Drawings</li> <li>- Design Specifications</li> <li>- Latest Drawing References and Revisions</li> </ul> <p>Progression photos to be documented</p> <b>Hold point. Sign off by other trades witnessed</b> <p>Drawings: _____</p> <p>Rev: _____</p>	H		S		Date:

6.	<p>External Works / Inspections to be completed <b>Prior to Closure of Walls:</b></p> <ul style="list-style-type: none"> <li>- Services rough in completed</li> <li>- Insulation Installed</li> </ul>	<p>Visual Inspection Prior to Closure</p>	<p><b>Ensure the completed works is installed in accordance with:</b></p> <ul style="list-style-type: none"> <li>- Architectural Drawings</li> <li>- Design Specifications</li> <li>- Latest Drawing References and Revisions</li> </ul> <p>Progression photos to be documented</p> <p><b>Hold point. Sign off by other trades witnessed</b></p> <p>Drawings: _____</p> <p>Rev: _____</p>	H				
7.	<p><b>Closing in of Walls:</b></p> <ul style="list-style-type: none"> <li>- Type and Material</li> <li>- Colour and Finish</li> <li>- Size and Thickness</li> <li>- Neatness of Cutting</li> <li>- Fixing and Jointing</li> <li>- Squareness and Flatness</li> <li>- Smoothness and Uniformity</li> <li>- Lapping and Staggering</li> <li>- Set and Sand Linings</li> <li>- Control Joint Locations</li> </ul>	<p>Visual Inspection upon completion of works</p>	<p><b>Ensure the completed works is installed in accordance with:</b></p> <ul style="list-style-type: none"> <li>- Architectural Drawings</li> <li>- Design Specifications</li> <li>- Latest Drawing References and Revisions</li> </ul> <p>Progression photos to be documented</p> <p><b>Hold point. Sign off by other trades witnessed</b></p> <p>Drawings: _____</p> <p>Rev: _____</p>	H		H(C)		
				H		H		

8.	<b>ARCHITECTURAL NOTIFICATION OF FINAL INSPECTION</b> Notice of Inspection: <ul style="list-style-type: none"> <li>- Correct all Defects</li> <li>- Supply Certificate of Compliance</li> </ul>	Upon Completion	<b>Ensure Final Works Completion is in accordance with:</b> <ul style="list-style-type: none"> <li>- Client Defects List</li> <li>- Architectural Drawings</li> </ul> <b>Drawings:</b> _____  <b>Rev:</b> _____	H				
				H				

VERIFICATION IDENTITY	COMPANY REP. WITH AUTHORITY	SIGNATURE / INITIAL	ATTACH
Lendlease			<input type="checkbox"/> Product Details
Arc Plastering			<input type="checkbox"/> Sample Material