

## Inspection & Test Checklist ITC: 3 MSB AND DISTRIBUTION PANELS

Heyday5 Pty Ltd ABN 85 158 865 091

Locked Bag 2228 North Ryde NSW 1670

Phone: (02) 9855 6666 Facsimile: (02) 9855 6655

Client: John Holland Group						Pro	Project Name: Shoalhaven Hospital Redevelo					pment Job No:			: NEC00138			Sheet	: <u> </u>	Of				
Contract Manager: Brett Lavorato P							Project Manager: Michael McGeehan					Site Supervisor: Andrew Cairns				Date:								
Check Authorised By: Michael McGeehan						Sigi	Signature:					Check Delegated To:				Signature:								
CONNECTIONS CORPECT ALL CABLE BOARD SEALED LARGES																								
BOARD TYPE OR NUMBER OR AREA			MFG QA		DAMAGE		LOCATION TO DRAWING		EQUIPMENT TO DRAWING		CONNECTIONS INCOMING & OUTGOING BY HEYDAY.		NEUTRAL CONNECTIONS CORRESPOND		CORRECT EARTHING AND SOLIDLY FIXED		POLE FILLERS INSTALLED		ENTRIES WITH ESCUTCHEON PLATES AND SEALS FITTED		AND LOCKED FOR SAFETY INC: FRONT AND REAR PANELS		SCHEDULE LIST CORRECT AND INSTALLED	
	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE	CHECK BY	DATE
																								<u> </u>
	<u> </u>				-																		<b></b>	<u> </u>
	<u> </u>					<u> </u>			-															1
	1					 																		1
	<u> </u>				1								<u> </u>		-								<u> </u>	<del>                                     </del>
	<u> </u>	<u> </u>				<u> </u>					-						-	<u> </u>					<b></b>	<u> </u>
	<u> </u>		-												-									<del> </del>
	1																							
COMMENTS:	COMMENTS:																							
																					NC	R No:		

FINAL ACCEPTANCE	NAME	SIGNATURE	POSITION	APPROVED (YES/NO)	DATE
HEYDAY GROUP (REPRESENTATIVE):					
CLIENT (REPRESENTATIVE):					
AUTHORITY (IF APPLICABLE):					

(Client and Authority may elect or not elect to sign the acceptance).

ACCEPTANCE CRITERIA: AS PER ITP = (1) AS3000 WIRING RULES. (2) SPECIFICATION. (3) LATEST ISSUE OF DRAWINGS. (5) SUPPLY AUTHORITY APPROVAL.

<sup>\*</sup> Proprietary purchased switchboards excluded