

Inspection & Test Plan (ITP) (Electrical)

Heyday5 Pty Ltd ABN 85 158 865 091 Locked Bag 2228 North Ryde, NSW 1670

North Ryde NSW 1670 Phone: (02) 9855 6666 Facsimile: (02) 9855 6655

AS/NZS ISO9001, AS/NZS4801, AS/NZS14001

	ACCEPTANCE CRITERIA							
CLIENT:	BESIX Watpac (1) AS3000 WIRING RULES (D)	(6) SUBCONTRACTORS CHECK LIST (H)					
PROJECT:	New Shellharbour Hospital (3) SPECIFICATION (D)) LATEST ISSUE OF DRAWINGS (D)) INSULATION TESTING (I)	(7) CLIENT OR NOMINEE APPROVAL (H) (8) CLIENT OR NOMINEE WITNESS (W) (9) AS/NZS3080 (W)					
JOB No:	NEC00148) SUPPLY AUTHORITY APPROVAL (W) (10) AS/NZS3012 (W)					
THE FOLLOWING	ABBREVIATIONS MAY BE PLACED IN ANY COLUMN OF ITC'S TO INDICATE CLIENT'S REQUIREMEN	T: (I) INSPECTION POINT (D) DOCUMENT VERIFICATION	TION (H) HOLD POINT (W) WITNESS POINT					

ITC No	DESCRIPTION	ACCEPTANCE CRITERIA	CHECK BY	ITC No.	DESCRIPTION	ACCEPTANCE CRITERIA	CHECK BY
1	DRAWINGS (FOR CONSTRUCTION)	3,7					
2	MAIN AND DISTRIBUTION PANELS	1,2,3,5					
3	MAINS AND SUBMAINS	1,2,3,5					
4	CABLE TRAY / LADDER	2,3					
5	INGROUND CONDUITS	1,2,3					
6	LIGHTING CIRCUITS	1,2,3					
7	POWER CIRCUITS	1,2,3					
8	ELECTRICAL EQUIPMENT / ACCESSORIES	1,2,3					
9	MAIN EARTHING SYSTEM	1,2,3,9					
10	CARDIAC EARTHING	1,2,3,9					
30	TESTING / COMMISSIONING	2					
31	AS BUILT DRAWINGS / MANUALS	2					

NOTE: "CHECK BY" MAY BE: PROJECT MANAGER, SITE MANAGEMENT OR CLIENT'S REPRESENTATIVE.

REMARKS/COMMENTS:

PREPARED BY: DATE: SHEET: 1 OF 1 REVISION: A

(ITC's with suffix "A" to be used for Subcontractors if their QA is unacceptable or unavailable for the project).