

<b>Scope:</b> Frame All Walls		<b>ITP Document No.:</b> 2	<b>Revision No.</b> A	<b>Date of Revision:</b> 24/05/2025
<b>Project Name:</b> St John of God Midland Private Hospital			<b>Organization Name:</b> Built	
<b>Project Address:</b> Lot 787 & Lot 788 Workshop Avenue Midland, WA, 6056				
<b>Prepared by</b>				
<b>Name:</b> Austin Han		<b>Position:</b> Contract Administrator	<b>Signature:</b>	<b>Date:</b> 24/05/2025
<b>Approved by</b>				
<b>Name:</b> Shiyong Lim		<b>Position:</b> Site Foreman	<b>Signature:</b>	<b>Date:</b> 24/05/2025

<b>Level:</b>		<b>Room No./Area:</b>	
<b>Wall Type:</b>		<b>DWG No:</b>	<b>Rev:</b>
Project Specification: STH-AR-SPC-0001   Australian Standards: AS2589		Project Drawings: STH-A03, STH-A08Series	

W = Witness, HP = Hold Point, S = Surveillance, R = Review								
Item	Activity	Reference Documents	Acceptance Criteria	Frequency	Verification Records/Comments	Inspection By		
						Subcontractor	Built	Client
1	Set out walls	STH-A03, STH-A08, Series	Light Weight Wall Plan approved by Built.  Studco Wall design & installation manual Volume 3.2  Dwg No: Rev:	Each unit	Visual Checklist Attached marked off drawings and photos	S	S	
2	Furring channel to walls	STH-A03, STH-A08, Series	Light Weight Wall Plan approved by Built.  Studco Wall design & installation manual Volume 3.2	Each unit	Visual Checklist Attached marked off drawings and photos	S	S	
3	Metal stud wall frame	STH-A03, STH-A08, Series	Light Weight Wall Plan approved by Built.  Studco Wall design & installation manual Volume 3.2	Each unit	Visual Checklist Attached marked off drawings and photos	S	S	

Item	Activity	Reference Documents	Acceptance Criteria	Frequency	Verification Records/Comments	Inspection By		
						Subcontractor	Built	Client
4	Install and fire rate PMDF	Architect drawings	Architect GA plan & door schedule approved by Built. PMDF installation guide provided by builder	Each location	Visual Checklist Attached marked off drawings and photos	S	S	
5	Noggins		As per scope of work. Studco Wall design & installation manual Volume 3.2	Each location	Visual Checklist Attached marked off drawings and photos	S	S	
6	Check no screws in deflection head		No screws in deflection head	Each location	Visual Checklist Attached marked off drawings and photos	S	S	
7	Clean up		Waste all cleaned. Tools and materials placed well.	Each location	Visual Checklist Attached marked off drawings and photos		R	

Comments:

Date of Inspection:

Carried out by:

## Verification Statement

This is to confirm that the nominated representative of L&D Commercial Interiors Pty Ltd, responsible for overseeing the works, has carried out all necessary inspections as listed above, and will be able to verify with documented evidence that the work has been completed and confirms to the contract specification(s)

Signed :

## Attachments

- |   |   |
|---|---|
| <input type="checkbox"/> Checklists                 | <input type="checkbox"/> Photos                   |
| <input type="checkbox"/> Dockets                    | <input type="checkbox"/> Sample Material          |
| <input type="checkbox"/> Drawings                   | <input type="checkbox"/> Calibration Certificates |
| <input type="checkbox"/> Test Results / Certificate | <input type="checkbox"/> Others:                  |
| <input type="checkbox"/> Inspection reports         |   |

Date: