

## CRL-ITR-005 - Fan Coil Units

## Site QA - CRL-ITR-005 - Fan Coil Units

First Activity: 17 Oct 2022 11:35am  
 Last Activity: 17 Oct 2022 11:35am

Checklist: no activity

Passed: 0  
 Failed: 0  
 N/A: 0

## 1.0 Unit First Fix QA

1.1	Correct Unit Installed
1.2	u/s of Unit at correct height
1.3	Correct mountings / Springs Installed

Add here prompt /  
 line  
 Model Number +  
 Serial Number

## 2.0 Unit Second Fix QA

2.1	Unit Plenum Boxes to be installed
2.2	Filters installed & clearance checked
2.3	Seismic Bracing Installed
Drawing Reference Number	
2.4	P - trap installed if required
2.5	Drip tray installed if required
2.6	Condensate Drains installed
2.7	Correct Fall to tundish , and water flow tested
2.8	Label to be installed

Under 1.4 Correct  
 mountings / springs  
 installed and unit  
 confirmed level.

## 3.0 E4M QA

3.1	Electrical Isolators installed in correct location
3.2	Units Terminated
3.3	Units Tested and Running