



# **TILING INSPECTION & TEST PLAN**

Date: DD/MM/YY

QA-TM-ITP-001

Revision 1

<b>PROJECT NAME:</b>	B&B	<b>BUILDING</b>			
<b>SUBCONTRACTOR:</b>	Teammembers Project P/L	<b>LEVEL</b>			
<b>BUILDER:</b>	Hickory Constructions	<b>ROOM</b>			
Ref	Nature of Inspection	Inspection	Inspect By	Date	Pass/Fail
<b>1</b>	<b>CHECK DRAWING</b>				
	Confirm current drawing, specification and revision #	admin			
<b>2</b>	<b>SUBSTRATE PREP - WALL</b>				
	Inspect for wall quality to accept tiles and ensure that substrate free from debris	visual			
	Clean and dry	visual			
	Joints set and sealed	visual			
<b>3</b>	<b>SUBSTRATE PREP - FLOOR</b>				
	Check FFL from substrate	laser / visual			
	Check angle termination position	visual			
<b>4</b>	<b>SAND &amp; CEMENT BEDDING</b>				
	Floorwastes protected to prevent debris entering into drains with compressible sponges	visual			
	Falls to waste as per drawing / isolate falls to waste	visual			
	Ensure slurry material is correct and is not dry prior to screeding	visual			
	Screed mixed by machine ratio 1:4	100L stand mixer			
	Ensure minimum screed is 15mm.	visual / guage			
	24hrs curing minimum				
	For large areas - check concrete porosity and de-dust	visual			
<b>5</b>	<b>HOLD POINT</b>				
	setout and starting point verified with Builder and Drawings	laser / visual / chalk line			
<b>6</b>	<b>INSPECT TILE LAYING</b>				
	Penetrations checked prior to cuts	admin / visual			
	Installation of waste covers	visual			
	General lipping wall/floor	visual			
	Confirmation of removal of floorwaste sponge	visual			
<b>7</b>	<b>PRESEAL</b>				
	Any material to be sealed to be cleaned free of dust	visual			
	Allow preseal to cure minimum 8 hours before grouting.	visual			
	Area to be baricaded off from entering.				
<b>8</b>	<b>GROUTING</b>				
	Ensure approved grout colour is used	visual			
	Secure watersource and discharge location	visual			
	Grout mixed without lumpiness	visual			
	Joints free from debris / spacers	visual			
	Surface is uniform and clean / no grout build up / internal corners free of grout	visual			
<b>9</b>	<b>PROTECTION</b>				
	Corflute taped down (no black corflute) cover entire tiled surface	visual			
	Photo record of protection	admin			
	Builders acceptance	photo / signature			
<b>10</b>	<b>Notes</b>				

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Prepared by: Mario Denaro

Position: Manager

Date: DD/MM/YY