

CRL-ITR-006 - Chilled Water Pipe Systems



Site QA - CRL-ITR-006 - Chilled Water Pipe Systems

First Activity: 17 Oct 2022 11:35am
Last Activity: 17 Oct 2022 11:35am

Checklist: no activity

Passed: 0
Failed: 0
N/A: 0

1.0 CRL-ITR-006 - Chilled Water Pipe Systems

1.1	Pipework installed as per Drawing
	Installation done by
1.2	Valve arrangement installed as per schematic
1.3	Insulation blocks installed where required
1.4	Correct hanger spacing
1.5	Drains installed at low points
	Air vents installed at all high points
1.6	The pipe OD and groove dimensions are within tolerance range as per victaulic specification
1.7	The correct coupling has been used for the correct joint i.e flexible or rigid
1.8	Visual indicators verified - Positive overlap - Joint Square
1.9	Steel is primed and weld painted after works are completed (PA10)
1.10	Pipework Seismic to be installed
	Drawing Reference Number

Modify to include
Steel is primed
(two coats)

Add item - Confirm
all bolts in the
system are
Galvanised