### **Inspection and Test Plan**



| Client: AIAL                        | Subcontractor: TBC | Work Area: SCH, HOSR              |
|-------------------------------------|--------------------|-----------------------------------|
| Project Name: Domestic Jet Terminal | Job No: HA0423     | Subcontractor Representative: TBC |

1. ITP Element: Utility Services Ducting – High Voltage, Low Voltage and Communication systems

#### 2. Revision Records

| Rev No. | Revision Description  | Name of Author | Authorized by: | Date |
|---------|-----------------------|----------------|----------------|------|
| net no. | ne vision Description |                |                | Ducc |
| Α       | For Approval          | Rohit Sen      | Matt Cheyne    |      |
| В       |                       |                |                |      |
| С       |                       |                |                |      |
| 0       |                       |                |                |      |
| 1       |                       |                |                |      |

#### 3. Relevant Documents

| Doc No. | Specification/ Drwgs/ Standards  | Additional Info | Document No. | Specification/ Drwgs/ Standards | Additional Info |
|---------|----------------------------------|-----------------|--------------|---------------------------------|-----------------|
| 1       | DP001-MMD-SPC-CV-Z-Z-0001        | Rev 02          | 6            |                                 |                 |
| 2       | DP001-MMD-DRW-UT-B-Z-3031 - 3055 | Rev 01, 02 & 03 | 7            |                                 |                 |
| 3       | DP001-MMD-DRW-UT-B-Z-3071 - 3091 | Rev 01, 02 & 03 | 8            |                                 |                 |
| 4       | DP001-MMD-DRW-UT-B-Z-3137 - 3139 | Rev 01          | 9            |                                 |                 |
| 5       | DP001-MMD-DRW-UT-B-Z-3010-3018   | Rev 02 & 03     | 10           |                                 |                 |

HAWKINS Inspection and Test Plan | Page 1 of 5

# **Inspection and Test Plan**



#### 4. Process

|       |   |              |   | Acceptance Criteria  | Devices |                                       | Ins | specte | ed by*  | Hold               | Remarks   |
|-------|---|--------------|---|----------------------|---------|---------------------------------------|-----|--------|---------|--------------------|---|
| No.   | Description<br>Inspection / test                            | Frequency    | Spec/standard                           |                      |         | Reporting<br>Format                   | HCL | SC     | Consult | Points Sign<br>off |   |
| 1     | Material Compliance   |              |   |                      |         |                                       |     |        |         |                    |   |
| 1.1   | Fill Materials  |              |   |                      |         |                                       |     |        |         |                    |   |
| 1.1.1 | Bedding material<br>PAP 7 for PE pipes<br>AP40 for Chambers | Per Batch    | CIV Spec - S12.3.4                      | Accept/<br>Reject    | N/A     | Dockets /<br>Material Data<br>Sheets  | R   | SUB    | R       | Hold Point         |   |
| 1.1.1 | Backfill Material<br>GAP65 or TNZ M/4 AP40                  |              | CIV Spec - S12.3.5<br>CIV Spec - S4.4.5 | Accept /<br>Reject   | N/A     | Dockets /<br>Material Data<br>Sheets  | R   | SUB    | R       | Hold Point         |   |
| 1.2   | Pipes   |              |   |                      |         |                                       |     |        |         |                    |   |
| 1.2.1 | <u>Pipes:</u><br>110 OD PE SDR 17<br>160 OD PE SDR 17       | Each Pipe    | CIV Spec - S12.3.3                      | Accept/Reject        | N/A     | Dockets /<br>Technical Data<br>Sheets |     | SUB    | R       | Hold Point         | All the PE pipe colors<br>must comply with the<br>respective service as<br>mentioned in S12.3.3 |
| 1.2.2 | Bends:<br>Pre-Fabricated HDPE<br>bends                      | Each Bend    | CIV Spec - S12.4.5                      | Accept/Reject        | N/A     | Dockets /<br>Technical Data<br>Sheets |     | SUB    | R       | Hold Point         |   |
| 1.2.3 | Electrofusion Couplers                                      | Each coupler | CIV Spec – S12.4.6                      | Accept/Reject        | N/A     | Dockets /<br>Technical Data<br>Sheets |     | SUB    | R       | Hold Point         |   |
| 2     | Construction  |              |   |                      |         |                                       |     |        |         |                    |   |
| 2.1   | Pre-Condition Assessme                                      | nts          |   |                      |         |                                       |     |        |         |                    |   |
| 2.1.1 | Existing ducts/chambers to be removed                       | Each pipe    | CIV Spec - S12.4.1                      | Removed and disposed | N/A     | Photos /<br>Asbuilts                  |     | SUB    | R       |                    | Once removed, all<br>trenches to be<br>backfilled to Subgrade<br>level                          |

HAWKINS Inspection and Test Plan | Page 2 of 5

# **Inspection and Test Plan**



| 2.2   | Pipe alignments, Position, Heights  Ducting  Excavation Extents     |                       | CIV Spec - S12.4.2<br>CIV Spec - S4.5.9<br>(earthworks section) | Survey Setout Pipe alignments, Position, Manholes Position and Heights  N/A |  | Setout CSV<br>file,<br>Photos/Visual<br>N/A | M |     |   |               | Setout model and CSV provided by HCL  |
|-------|---|-----------------------|---|---|--|---|---|-----|---|---------------|---|
| 2.2.2 | HDPE Ground Mat   |                       | Note 10 – DP0001-<br>MMD-DRW-UT-F-Z-<br>3137 - 3139             | Accept/Reject   | Photos, Dockets  | N/A   | I | SUB | R |               | HDPE ground protection Mat will be installed only in areas shown in the drawings.                             |
| 2.2.2 | Bedding, surround   |                       | As per drwgs min/<br>max fill                                   | N/A   | Rotating level /<br>tape / staff   | Photos, QVC                                 | М | SUB | R |               | PAP7 for PE   |
| 2.2.3 | Pipe installation,<br>Connection and jointing<br>Electrofusion weld | Each pipe             | CIV Spec - S12.4.5<br>CIV Spec - S12.4.6                        | N/A   | Observation  | QVC,<br>As-Builts                           | I | SUB | R |               | Caps to be used if lines not complete, All Welding to be performed under controlled Environmental conditions. |
| 2.2.4 | Weld Testing  | All welding<br>Joints | CIV Spec - S12.5.2  | N/A   | Visual Checks for<br>each Weld and Peel<br>Decohesion Testing<br>for one in every 20<br>welds or Min 2<br>welds per line |   | R | SUB | R | Witness Point |   |

HAWKINS Inspection and Test Plan | Page 3 of 5

# **Inspection and Test Plan**



| F      |   |                    |  |   |   |                              |   |     |   |               | HAWKII                                    |
|--------|---|--------------------|--|---|---|------------------------------|---|-----|---|---------------|---|
| 2.2.5  | Tracer Wires                              | Comms duct         | CIV Spec - S12.4.9<br>DP001-MMD-DRW-<br>UT-F-Z-3137 - 3139                                     | Tracer Wire to 4mm <sup>2</sup><br>multi-Strand<br>Accept/Reject  | Continuity Test<br>(electronically<br>generated tone and<br>detector probe) | Photos, Test<br>results, QC  | l | SUB | R |               |   |
| 2.2.6  | Inspection for Duct size, color, spacing, | All ducts          | CIV Spec - S12.4.5<br>DP001-MMD-DRW-<br>UT-F-Z-3137 - 3139                                     | N/A   | N/A   | Photos, QVC                  | M | SUB | l | Witness Point | Engineer to inspect<br>before backfilling |
| 2.2.7  | Warning Tapes/ marker<br>tapes            | Each Pipe          | CIV Spec - S12.3.9<br>DP001-MMD-DRW-<br>UT-F-Z-3137 - 3139                                     | Warning Tapes must refer to respective Services. Installation heights must follow the typical trench details. | N/A   | Photos                       | l | SUB | R |               |   |
| 2.2.8  | Mag Slabs/Polymeric<br>Slabs              | HV and LV<br>ducts | CIV Spec - S12.3.10<br>DP001-MMD-DRW-<br>UT-F-Z-3137 - 3139                                    | Installation heights<br>must follow the<br>typical trench details.  | N/A   | Photos                       | I | SUB | R |               |   |
| 2.2.9  | Draw Cord                                 | Each pipe          | CIV Spec - S12.3.8<br>S12.4.8<br>DP001-MMD-DRW-<br>UT-F-Z-3137 - 3139                          | Continuous draw<br>cord and excess to be<br>left at the ends of<br>each duct                                  | l '   | Photos                       | l | SUB | R |               |   |
| 2.2.10 | Pipe Cover and<br>Backfilling             | Each Pipe          | CIV Spec - S4.4.5<br>Table 4.3 (Earthworks<br>Section)<br>DP001-MMD-DRW-<br>UT-F-Z-3137 - 3139 | Backfilling CIV > 25<br>Bedding CIV to be<br>confirmed  | Clegg Hammer  | Photos, QVC,<br>Clegg Sheets | M | SUB | I |               |   |

HAWKINS Inspection and Test Plan | Page 4 of 5

### **Inspection and Test Plan**



|        |                              | _         |                    |   |                    |  |   |     |   |               | <u>HAWKI</u> NS   |
|--------|------------------------------|-----------|--------------------|---|--------------------|--|---|-----|---|---------------|---|
| 2.2.11 | 3m Marker Balls              | Each Item | CIV Spec – S12.4.5 | Installed above the<br>HV ducts at each side<br>of the point of<br>crossing | · •                | Photos                                     | I | SUB | R |               | Programmed 3m<br>marker balls to be<br>supplied by<br>principal/client. |
| 3      | Post Construction            |           | •                  | •   |                    |  |   |     |   |               |   |
| 3.1    | As-Builts                    |           |                    |   |                    |  |   |     |   |               |   |
| 3.1.1  | As built Works               | Each pipe | N/A                | -   | Equipment, Total   | Certified As-<br>built PDF and<br>DWG file | R | Sub | R |               |   |
| 3.2    | Duct Condition               |           |                    |   |                    |  |   |     |   |               |   |
|        | Duct Cleaning and<br>Proving | Each Duct | N/A                | N/A   | Brush and Mandrill | Photos/Videos                              | M | SUB | R | Witness Point |   |

5. Document Deliverables (The documents listed below shall be completed and compiled during the course of the construction)

### 6. Distribution Records

| Name                             | Position | Company        | Date        |
|----------------------------------|----------|----------------|-------------|
| ТВА                              |          | Mott McDonalds |             |
| ТВА                              |          | BECA           |             |
| HAWKINS Inspection and Test Plan |          |                | Page 5 of 5 |
| ТВА                              |          | AIAL           |             |
|                                  |          |                |             |

### **Inspection and Test Plan**



- Inspect (I) To visually examine or measure an item or contracted work operation to verify its conformance to predetermined quality requirements
- Review (R) To examine any form of documentation to establish its acceptability against specified requirements
- Surveillance (S) To observe in-process activities to the degree necessary to be assured that they comply with the established criteria
- Test (T) To subject a component, structure, or system to a controlled set of physical, chemical, environmental or operational conditions to determine or verify its capability to meet specified requirements
- Witness (W) To watch over, observe or visually examine a specific work operation or test performed by others under Contractor supervision
- Monitor (M) General oversight of work in progress with no need to document formally.
- Submission (Sub) Submission of a document

Note: The Engineer shall be provided a minimum of two (2) working days' notice ahead of a requested inspection

HAWKINS Inspection and Test Plan | Page 6 of 5