



## **CRL - Link Alliance**

**Site QA ITP List  
CRL-ITR-016 - DX Units**

# Report summary



Name	Status	Last Activity
CRL-ITR-016 - DX Units - <a href="#">page 3</a>	na	15 Apr 2024 4:22am

## CRL-ITR-016 - DX Units



## Site QA ITP List - CRL-ITR-016 - DX Units -

First Activity: 17 Mar 2023 1:10pm

Last Activity: 15 Apr 2024 4:22am

Checklist: no activity

Passed: 0

Failed: 0

N/A: 0

## DX Units

	<b>Pre-check equipment for damage prior to installation</b>
	<b>Correct Unit Installed</b>
	Model Number
	Serial Number
	<b>Out door Unit Installed</b>
	<b>U/S of Unit at correct height and unit level</b>
	<b>Refrigeration Pipework installed as per drawings</b>
	Installation done by
	<b>Pipework Installed from DX unit box to Outdoor unit</b>
	Schematic markups drawings
	<b>Condensate Piping installed</b>
	<b>Pressure Tested</b>
	<b>Signed off By AE Smith</b>
	Name of person
	Date
	<b>Photo's of Pressure test</b>
	Start of Pressure test
	Time / Date
	Pressure test after recored Duration
	Time / Date
	<b>Triple Evacuation procedure to be done.Final below 500 Microns</b>

	Refrigeration (Scale) charge unit completed - According to Calculation for Pipe Size & Length
	Insulation Complete for Piping and Condensate lines
	Seismic Bracing Installed
	Drawing Reference Number

Unit Second Fix QA

	Filters Installed
	Unit Labelled

E4M QA

	Electrical Isolators installed in correct location
	Units Terminated
	Units Tested and Running
	Location
	Add details
	Level
	Add details
	Room Number
	Add details
	BIM Tag ID #
	Add details
	Asset #
	Add details
	Serial #
	Add details

# Attachments

