



CRL - Link Alliance

Site QA ITP List
CRL-ITR-006 - Chilled Water Pipe Systems

Report summary



Name	Status	Last Activity
CRL-ITR-006 - Chilled Water Pipe Systems - page 3	na	15 Apr 2024 5:29am

CRL-ITR-006 - Chilled Water Pipe Systems



Site QA ITP List - CRL-ITR-006 - Chilled Water Pipe Systems -

First Activity: 17 Oct 2022 11:35am

Last Activity: 15 Apr 2024 5:29am

Checklist: no activity

Passed: 0

Failed: 0

N/A: 0

CRL-ITR-006 - Chilled Water Pipe Systems

	Pre-check equipment for damage prior to installation
	Pipework installed as per Drawing
	Installation done by
	Valve arrangement installed as per schematic
	Insulation blocks installed where required
	Correct hanger spacing
	Drains installed at low points
	Air vents installed at all high points
	The pipe OD and groove dimensions are within tolerance range as per victaulic specification
	The correct coupling has been used for the correct joint i.e flexible or rigid
	Visual indicators verified - Positive overlap - Joint Square
	Steel is primed (two coats) and weld painted after works are completed (PA10)
	Confirm all bolts in the system are Galvanised
	Pipework Seismic to be installed
	Drawing Reference Number

Attachments

