


Inspection and Test Plan - Stainless Steel Pipework Installation - Pump 3

ITP Reference Number 561482-ITP-006.3

SECTION 1 - GENERA	L DETAILS										
Project Name:	IDCC 1101/1 Water Plimn Station Renewals - SILVERSTREAM					Use in sections 3, 4 and		Responsibilities Use in sections 3, 4 and 5.			
Project Number:	561482					А	Action	Role Key	Name	Signature/ Initial	
Customer:	Dunedin City Council	Dunedin City Council				В	Report by Breach	CM Construction Manager	Stephen Vorgers		
Contract Number:	DCC11014-WPS002	DCC11014-WPS002					Check	CR Cust. Representative	Joff Riley / Mark Todd		
Area/ Sub-System:	Pipework Installation - Sil	lverstream	tream		N/A	D	Dimension Inspection	IP Inspection Personnel	Aaron Sutherland		
7 trout out Gyotom.	Number:					Е	Examine	MC Material Controller			
ITP Number:	561482-ITP-006.3	561482-ITP-006.3 Version : Draft				н	Hold Point	OP Operations Manager			
ITP Description:	Pipework Installation Pur	Pipework Installation Pump 3 - Inspection Test Plan					Inspection	PM Project Manager	Matt Paterson		
Discipline:	Stainless Steel Pipework - Installation					М	Monitor on Random Basis	PS Project Supervisor			
	C11014 Water Pump Station Renewals Specification 12581908					0	Operation	QE Quality Engineer			
Specification:						R	Review	QM QA Manager			
	Construction Issue Drawings as issued by GHD - Silverstream Pump Station					s	Subcontractor	SP Supervisor	Bruce Allan		
Drawings:	Project Ref: 12581908-GHD-PS-SS-DRG-GN Drawings: G0001, M0001 to M0004 & P0001						Visual Verification	ST Superintendent			
Prepared By: (Name)	Matt Paterson			Date:	10/12/2024	4 w	Witness Point	SV Surveyor			
Quality Specified:	None - As per Specificati	on requirements						WS Welding Supervisor	Matt York		
SECTION 2 - SIGNATU	IRES - CLOSE-OUT & AF	PROVAL									
ITP Close-Out by Dow	ner	Name:	Bruce Allan	Signatu		nature:			Date:		
Downer Approval		Name:	Matt Paterson/Stephen V	Vorgers Signa		gnature:			Date:		
Customer Approval		Name:	Joff Riley / Bruce Buxton	off Riley / Bruce Buxton		Signature:			Date:		





SECTION 3 - RECEIVING INSPECTIONS Insert additional or delete unused rows as required. Include reference to specification. Inspection **Inspection Point: Quality Activity/ Task** Inspection Type (Visual, Item No. **Acceptance Criteria Verifying Document** Frequency Description **Control Activity** other) By (Role Key) Key Obtain the mill certificates for the Stainless Steel Pipe Documents from the Mill Certificates & 3.1 materials used - 316L Stainless Once Documentation С IΡ supplier/Manufacturer Welding certificates components Steel Drawing M0001 Take delivery of components Stainless Steel Pipe Quantities as shown on Drawing M0002 from Supplier. Verify all С IΡ 3.2 Once Visual components the drawings Drawing M0003 components have been delivered Drawing M0004 Take delivery of components Drawing M0001 from Supplier. Verify all Dimensions & Stainless Steel Pipe Drawing M0002 Visual Dimension 3.3 components have been orientation as shown on Once D ΙP components Drawing M0003 Inspection manufactured to the correct the drawings Drawing M0004 dimensions Check and verify that the Must be on the Specification -ΙP 3.4 Valves & Ancillaries Manufacturer & Type is approved С Once Visual Approved Materials list Approved Products list for use by the client Check and verify that the dress sets are compatible with the Dress Sets (gaskets & flanges and the gasket material Must be on the Specification -3.5 Once Visual С ΙP is correct. Check correct Approved Materials list fasteners) Approved Products list quantities/sizes/flange patterns





CTION 4 – IN-PRO								Inspection	
Item No.	Activity/ Task Description	Inspection Point: Quality Control Activity	Acceptance Criteria	Verifying Document	Frequency	Inspection Type (Visual, other)	Key	By (Role Key)	
4.1	Fasten Wet Well side/pick-up to spool (cast in wall) Item # 1	Install gasket, bolts & nuts and tighten. Torque fasteners	Use diametrically opposed touque sequence	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Each flange	Record & attach to ITP	Inspection	IP	
4.2	from spool (cast in wall)	Install gasket, bolts & nuts and tighten. Torque fasteners to relevant water standards	Use diametrically opposed touque sequence	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Each Flange	Record & attach to ITP	Inspection	IP	
4.3	Isolation Valve 150mm	Install gasket, bolts & nuts and tighten. Torque fasteners to relevant water standards	Use diametrically opposed touque sequence	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Each Side of Valve	Record & attach to ITP	Inspection	IP	
4.4	150mm Dismantling joint (suction side) Item#4	Torque fasteners to relevant water standards	Use diametrically opposed touque sequence and manufactruers instructions	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Once	Record & attach to ITP	Inspection	IP	
4.5	Spool.	Install gasket, bolts & nuts and tighten. Torque fasteners to relevant water standards	Use diametrically opposed touque sequence	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Once	Record & attach to ITP	Inspection	IP	
4.6	Sweeping Flange	Install gasket, bolts & nuts and tighten. Torque fasteners to relevant water standards	Use diametrically opposed touque sequence	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Once	Record & attach to ITP	Inspection	IP	
4.7	valve.	Install gasket, bolts & nuts and tighten. Torque fasteners to relevant water standards	Use diametrically opposed touque sequence	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Each Side of Valve	Record & attach to ITP	Inspection	IP	



Inspection and Test Plan

4.8	, , ,	and tighten. Torque fasteners	Use diametrically	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Once	Record & attach to ITP	Inspection	ΙΡ
4.9	150mm Dismantling joint (discharge side) Item#4		Use diametrically opposed touque sequence and manufactruers instructions	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Once	Record & attach to ITP	Inspection	IP
4.10	Isolation Valve 150mm Item # 3 (discharge side)	Install gasket, bolts & nuts and tighten. Torque fasteners to relevant water standards	Use diametrically	As per WSA-109 Australiann Water Standards Guidelines - 80N.m	Each Side of Valve	Record & attach to ITP	Inspection	ΙΡ
4.11	Pipework bracketing installed and is secure.	At completion of pipework	Pipework complete and installed. Adjustable brackets	As indicated on the drawings	once	Visual	I	IP



Inspection and Test Plan

SECTION 5 – FINAL INSPECTION AND HANDOVER Insert additional or delete unused rows as required. Include reference to specification.										
Item No.		Inspection Point: Quality Control Activity	Acceptance Criteria		Frequency	Inspection Type (Visual, other)	Inspection			
	Activity/ Task Description			Verifying Document			Key	By (Role Key)		
5.1	Final inspection to installed pipework	At completion of pipework	Flanges are straight and bolts tightened all threads sealed and leak free	As per drawings	once	Visual	I	IP		
5.2	Instrumentation. e.g. Pressure transducers and sensors are fitted correctly - No Damage	At completion of pipework	Pipework is installed and correct fittings installed to accept the instrumentation	As per drawing schematics	once	Visual	I	IP		
5.3	Pipework bracketing installed and is secure.	At completion of pipework	Pipework complete and installed	As per drawings	once	Visual	I	IP		
SECTION 6 - COMMEN	TS									

Customer Release Granted:

Certificate Number:

☐ Yes

☐ No

Date: