

Where multipliers are applied to a meter reading prior to output:

PASS

FAIL

N/A

Can the meter multiplier be interrogated on the meter face?

Yes

No

If so, record the meter multiplier and attach photographic evidence

If not, use tong-testing or a hand-held meter to compare measured current and meter face current per phase

Sub-meter current per phase

Red Phase

White Phase

Blue Phase

Comparison meter current per phase

Red Phase

White Phase