

Adaptive Weighted Dual-Channel PCNN Multi-Representation Fusion with Multi-Scale Attention for Vibration Signal Fault Diagnosis

Chen Yang, Zonglong Bai, Zhiyuan Xie, Chenggang Liu, Junyan Zhang and Yihe Guo

Abstract—Non-stationary vibration signals from rotating machinery pose significant challenges for intelligent fault diagnosis, as conventional single-representation methods often fail to capture the full spectrum of discriminative fault information. This paper presents an Adaptive Weighted Dual-Channel Pulse-Coupled Neural Network (AW-DPCNN) for multi-representation fusion, coupled with a Multi-Scale Channel Attention enhanced VGG16 (MSCA-VGG16) classifier. The AW-DPCNN adaptively fuses STFT spectrograms and Gramian Angular Difference Field via contrast-guided dynamic weighting, dual-channel pulse-coupled dynamics, and representation-specific convolutional kernels. The fused representations are classified by MSCA-VGG16, which augments a VGG16 backbone with multi-scale convolution, squeeze-and-excitation channel attention, and a compact embedding head. Extensive experiments on the Case Western Reserve University bearing dataset demonstrate that the full pipeline achieves 99.85% accuracy on the 12 kHz drive-end benchmark, with strong cross-sensor generalization (97.45% on fan-end data) and cross-sampling-rate robustness (94.81% at 48 kHz). Comprehensive ablation studies, representation comparisons, and noise robustness evaluations collectively validate the effectiveness and generalizability of the proposed framework.

Index Terms—Fault diagnosis, Gramian angular difference field (GADF), multi-representation fusion, pulse coupled neural network (PCNN), rotating machinery, short-time Fourier transform (STFT), time-frequency analysis.

I. INTRODUCTION

ROTATING machinery, including bearings, gears, and shafts, constitutes the core of modern industrial systems [1], [2]. Unexpected failures of these critical components can lead to catastrophic breakdowns, substantial economic losses, and severe safety hazards. Consequently, reliable and intelligent fault diagnosis techniques have become indispensable for condition-based maintenance and operational safety assurance [3]. Among various diagnostic modalities, vibration-based monitoring has received the most extensive research attention due to its rich fault-related information content, non-intrusive sensor deployment, and well-established physical understanding of fault-induced vibration signatures [4] [5].

Despite the practical success of vibration-based diagnosis, the non-stationary nature of real-world machinery signals remains a fundamental challenge. Under variable speed, fluctuating load, and time-varying operating conditions, vibration signals exhibit pronounced non-stationary characteristics, as their spectral content and statistical properties evolve over time in complex ways that cannot be adequately captured by conventional stationary signal processing techniques [6] [7]. Single time-domain or frequency-domain representations each capture only partial aspects of these rich signals: time-domain features may overlook critical spectral information, while frequency-domain representations discard temporal evolution patterns that are

essential for distinguishing transient fault events from steady-state operating conditions [8] [9].

To address the limitations of single-representation approaches, researchers have explored complementary representation strategies. Time-frequency representations such as the Short-Time Fourier Transform (STFT) spectrogram, Mel spectrogram, and continuous wavelet transform (CWT) scalogram provide joint time-frequency energy distributions that reveal how spectral content evolves temporally [10], [11], [12]. In parallel, temporal encoding methods such as the Gramian Angular Field (GAF), Markov Transition Field (MTF), and Recurrence Plot (RP) transform one-dimensional time series into two-dimensional images by encoding pairwise temporal relationships, thereby preserving global temporal correlation structures that time-frequency methods may not explicitly capture [13], [14] [15]. However, most existing studies adopt a single representation for downstream classification, and the complementary nature of time-frequency and temporal-encoded representations remains largely underexploited.

Multi-representation fusion offers a natural avenue to combine the strengths of heterogeneous representations, yet existing fusion strategies face critical limitations. Simple concatenation or pixel-wise averaging ignores the distinct statistical properties and structural characteristics of different representations, potentially introducing destructive interference rather than constructive complementarity [16] [17]. Fixed-weight fusion schemes lack the adaptivity to emphasize discriminative representations while suppressing less informative ones on a per-sample or per-region basis [18]. Furthermore, conventional deep learning classifiers, while powerful, often lack explicit architectural mechanisms to exploit the multi-scale and channel-wise characteristics of fused representations [19] [20].

To address these gaps, this paper proposes a two-stage framework comprising an Adaptive Weighted Dual-branch Pulse-Coupled Neural Network (AW-DPCNN) for multi-representation fusion, and a Multi-Scale Channel Attention enhanced VGG16 (MSCA-VGG16) classifier for robust fault identification. The main contributions are:

- An AW-DPCNN fusion mechanism is proposed to adaptively integrate time-frequency representations (STFT spectrogram) and temporal-encoded representations (GADF). The mechanism introduces contrast-guided adaptive weighting to dynamically regulate per-channel contributions, dual-channel external stimuli with representation-specific convolutional kernels, and iterative pulse-coupled dynamics for feature reinforcement.
- An MSCA-VGG16 classification network is constructed to further exploit the complementary information encoded in the fused representations. The architecture integrates

multi-scale convolution for capturing fault patterns at multiple temporal and spectral granularities, squeeze-and-excitation channel attention for dynamic frequency-band recalibration, and a compact embedding head for enhanced discriminability.

- Extensive experiments on the CWRU bearing dataset, including backbone comparisons, comprehensive ablation studies, representation comparisons across twelve time-frequency and temporal encoding combinations, and noise robustness evaluations, systematically validate each component of the proposed framework. Cross-sensor and cross-sampling-rate generalization is further demonstrated on the 12 kHz fan-end and 48 kHz drive-end datasets, confirming robustness beyond the primary benchmark.

The remainder of this paper is organized as follows. Section II reviews related work. Section III presents the proposed AW-DPCNN fusion mechanism and MSCA-VGG16 classifier. Section IV describes the experimental setup and comprehensive performance evaluation. Finally, conclusions are drawn in Section V.

II. RELATED WORK

A. Signal Representations for Fault Diagnosis

Time-frequency representations have been extensively applied to vibration-based bearing fault diagnosis. STFT spectrograms combined with 2-D CNNs have demonstrated effective classification of bearing defects by converting raw vibration signals into time-frequency images that convolutional architectures can process [21], [22]. CWT scalograms have been employed to achieve improved time-frequency localization for transient fault signatures, with multi-resolution analysis offering advantages over fixed-resolution STFT for certain non-stationary conditions [23]. Mel spectrograms have also been explored for their perceptually motivated frequency compression, particularly for harmonic-rich fault patterns [24]. Despite these successes, time-frequency representations fundamentally characterize local spectral energy distributions and do not explicitly model long-range temporal dependencies that may contain complementary diagnostic information.

In a parallel direction, temporal encoding methods have been introduced to transform one-dimensional vibration signals into two-dimensional images that preserve pairwise temporal relationships. Xiong et al. applied GAF encoding to complementary ensemble empirical mode decomposition-preprocessed vibration signals, enabling CNN-based classification of the resulting temporal correlation images [25]. MTF and RP encodings have similarly been adopted to capture sequential transition dynamics and recurrent phase-space patterns, respectively [26], [27]. However, these temporal encoding methods primarily preserve correlation structures and lack explicit frequency-domain specificity, which is critical for distinguishing faults with similar temporal patterns but distinct spectral signatures.

A limited number of recent studies have explored combining multiple representations for fault diagnosis. Representative efforts include channel-wise concatenation of time-frequency and temporal-encoded images for CNN-based classification,

and pixel-level averaging of complementary representation pairs [28], [29]. However, these approaches employ fixed fusion strategies that treat all spatial locations and feature channels uniformly, without adaptively regulating the relative contribution of each representation. Given that time-frequency and temporal-encoded representations possess fundamentally different statistical properties and structural characteristics, naive fusion may introduce destructive interference rather than constructive complementarity. The systematic exploration and adaptive fusion of heterogeneous representations for vibration signal fault diagnosis therefore remains an open research problem, motivating the AW-DPCNN framework proposed in this work.

B. PCNN and Multi-Representation Fusion

Pulse-coupled neural networks (PCNNs) are neural models originally developed to simulate the synchronous firing behavior observed in the mammalian visual cortex [30]. Unlike conventional convolutional neural networks, PCNNs employ a pulse-based activation mechanism in which neurons interact through local coupling and dynamic thresholds [31]. Owing to these characteristics, PCNNs exhibit strong capability in preserving structural information while suppressing background interference, and have been widely applied in image segmentation, edge detection, and feature enhancement tasks [32], [33], [34].

However, conventional PCNNs are typically driven by a single external stimulus, which limits their ability to effectively exploit complementary information from multiple representations. To address this limitation, dual-channel PCNN (DPCNN) architectures have been introduced to enable multi-representation fusion by incorporating multiple external stimuli within the neuronal feeding mechanism, and later extended with adaptive parameter estimation via fractal dimension to eliminate manual tuning [35]. Through this mechanism, heterogeneous feature maps can be jointly processed, thereby facilitating the integration of information from different representations. Nevertheless, the fusion process in such architectures generally relies on fixed or predefined coupling strategies, making it difficult to adaptively regulate the relative contributions of different channels. As a result, the model may not effectively emphasize discriminative representations while suppressing less relevant ones, thereby limiting the effectiveness of multi-representation fusion. Although DPCNN-based fusion has been preliminarily explored in image processing, its application to machinery fault diagnosis, where heterogeneous time-frequency and temporal-encoded representations must be jointly exploited, remains largely uninvestigated.

C. Deep Learning for Fault Diagnosis

With the rapid advancement of deep learning techniques, a variety of neural network architectures have been applied to vibration signal fault diagnosis, demonstrating superior automatic feature extraction capability compared with traditional handcrafted methods [36], [37]. Early studies commonly adopted baseline convolutional neural networks as benchmark architectures for acoustic and vibration fault classification, verifying the feasibility of end-to-end feature learning for




Fig. 1: Overall framework of the proposed vibration signal fault diagnosis method. The vibration signal is first converted into STFT spectrogram and GADF images. These heterogeneous representations are then adaptively fused through the proposed AW-DPCNN mechanism. Finally, the fused feature is fed into the MSCA-VGG16 network for fault classification.

fault diagnosis tasks [38]. Subsequently, classical deep convolutional backbones, including EfficientNet, ViT, MobileNet, ConvNeXt and ResNet, were introduced into intelligent fault diagnosis frameworks and achieved notable improvements in hierarchical feature representation and classification accuracy across machinery health monitoring applications [39], [40], [41]. Among these, VGG16's purely sequential topology with no skip connections or built-in attention mechanisms provides a clean architectural foundation for attaching auxiliary modules such as multi-scale convolution and channel attention, making it particularly suitable as a backbone for the MSCA enhancement strategy pursued in this work [42]. More recently, advanced architectures such as ConvNeXt, which incorporate modernized convolutional design principles, have further enhanced representation learning capability and demonstrated competitive performance in fault diagnosis and image-based classification tasks [43]. In addition, publicly available benchmark datasets, such as the CWRU bearing fault dataset, have been extensively employed to evaluate the effectiveness and generalization ability of deep learning-based diagnostic models, serving as a standard reference in fault diagnosis research [44].

Despite these advances, most existing deep learning approaches for fault diagnosis are designed to process a single input representation and lack dedicated architectural mechanisms, such as multi-scale receptive fields and dynamic channel attention, for jointly exploiting the heterogeneous features produced by multi-representation fusion. Consequently, their capacity to fully leverage the complementary information encoded in fused time–frequency and temporal representations remains limited, motivating the design of the MSCA-VGG16 classifier proposed in this work.

III. METHODOLOGY

A. Overview

The proposed framework comprises two sequential stages: multi-representation signal fusion and fused representation classification, as illustrated in Fig. 1. In the fusion stage, the raw vibration signal is first transformed into two complementary representations, namely the STFT spectrogram and the Gramian Angular Difference Field (GADF) image, to capture time–frequency energy distributions and global temporal correlation structures, respectively. These heterogeneous representations are then adaptively integrated through the proposed AW-DPCNN mechanism, which employs contrast-guided adaptive

weighting and dual-channel pulse-coupled dynamics to produce a unified fused representation. In the classification stage, the fused representation is fed into the MSCA-VGG16 network, which incorporates multi-scale convolution and channel attention to enhance feature discrimination, followed by a compact embedding head for robust fault classification.

Formally, let $\mathbf{x} \in \mathbb{R}^L$ denote a raw vibration signal segment of length L . The signal is first mapped to two heterogeneous representations as

$$\mathbf{S}_{\text{STFT}} = \mathcal{T}_{\text{STFT}}(\mathbf{x}), \quad \mathbf{S}_{\text{GADF}} = \mathcal{T}_{\text{GADF}}(\mathbf{x}), \quad (1)$$

where $\mathcal{T}_{\text{STFT}}(\cdot)$ and $\mathcal{T}_{\text{GADF}}(\cdot)$ denote the STFT spectrogram and GADF transformation operators, respectively, both producing pseudo-color RGB images. The two representations are then fused via the AW-DPCNN operator $\mathcal{F}_{\text{AW}}(\cdot, \cdot)$ as

$$\mathbf{S}_{\text{fused}} = \mathcal{F}_{\text{AW}}(\mathbf{S}_{\text{STFT}}, \mathbf{S}_{\text{GADF}}; \Theta_{\text{AW}}), \quad (2)$$

where Θ_{AW} denotes the set of AW-DPCNN hyperparameters. Finally, the fused representation is passed through the MSCA-VGG16 classifier $\mathcal{C}(\cdot)$ to produce the predicted fault class probabilities

$$\hat{\mathbf{y}} = \mathcal{C}(\mathbf{S}_{\text{fused}}; \Theta_{\text{CLS}}), \quad (3)$$

where Θ_{CLS} denotes the trainable parameters of the classification network and $\hat{\mathbf{y}} \in \mathbb{R}^K$ is the predicted probability vector over K fault categories. The following subsections detail each component of this pipeline.

B. Signal Representation

The raw vibration signal segment $\mathbf{x} \in \mathbb{R}^L$, introduced in (1), serves as the common input from which both representations are derived. The STFT spectrogram $\mathbf{S}_{\text{STFT}}$ captures local time–frequency energy distributions through short-time spectral analysis, while the GADF image $\mathbf{S}_{\text{GADF}}$ encodes global temporal correlation structures through pairwise angular relationships. Their respective constructions are detailed below.

1) *STFT Spectrogram*: The STFT spectrogram is a linear time–frequency representation that preserves uniform frequency resolution across the entire spectrum. Let $x[k]$ denote the k -th sample of the vibration signal segment $\mathbf{x}$. The construction involves dividing $\mathbf{x}$ into overlapping frames of length n_{fft} , applying a Hann window $w(\cdot)$ to each frame, and computing the discrete Fourier transform. The magnitude spectrum of each




Fig. 2: Vibration signal representations. (a) STFT spectrogram. (b) GADF image.

frame is arranged chronologically to form a two-dimensional time–frequency representation $\mathcal{S}_{\text{STFT}}(t, f)$, defined as

$$\mathcal{S}_{\text{STFT}}(t, f) = \left| \sum_{k=0}^{n_{\text{fft}}-1} x[k] w(k-t) e^{-j2\pi f k / n_{\text{fft}}} \right|^2. \quad (4)$$

The STFT spectrogram is parameterized by the FFT window size n_{fft} and hop length n_{hop} , which jointly determine the temporal resolution and frequency resolution $\Delta f = f_s / n_{\text{fft}}$ at a given sampling rate f_s .

2) *Gramian Angular Field*: The GAF transforms the same vibration signal segment $\mathbf{x}$ into a two-dimensional image that preserves temporal correlation information through pairwise angular encoding. Let x_i denote the i -th sample of $\mathbf{x}$. For the purpose of GADF construction, a sequence of n samples $\{x_1, x_2, \dots, x_n\}$ drawn from $\mathbf{x}$ is first normalized to $[-1, 1]$ via min–max scaling,

$$\tilde{x}_i = \frac{(x_i - \min_i x_i) + (x_i - \max_i x_i)}{\max_i x_i - \min_i x_i}. \quad (5)$$

The normalized values are then mapped to polar coordinates, where each $\tilde{x}_i$ is encoded as an angular coordinate ϕ_i and its temporal position is preserved as the radial coordinate r_i ,

$$\begin{cases} \phi_i = \arccos(\tilde{x}_i), & -1 \leq \tilde{x}_i \leq 1 \\ r_i = \frac{i}{n}, & i = 1, \dots, n \end{cases}. \quad (6)$$

This polar encoding ensures that the temporal ordering of the signal is preserved through the radial coordinate, while signal amplitude variations are encoded as angular deviations. Finally, pairwise angular differences or sums are aggregated to form the Gramian Angular Summation Field (GASF) and Gramian Angular Difference Field (GADF). The GADF variant,

$$\mathcal{G}_d(i, j) = \sin(\phi_i - \phi_j), \quad i, j = 1, \dots, n, \quad (7)$$

is adopted in this study due to its higher sensitivity to abrupt temporal variations.

The GAF representation offers several advantages that complement the STFT spectrogram. First, by encoding pairwise angular relationships between all time points, the GAF captures global temporal correlation structures that extend beyond the local receptive field of STFT-based representations. Second, the min–max normalization in (5) inherently suppresses the

TABLE I: Key Hyperparameters of AW-DPCNN

Parameter	Symbol	Value
Iteration number	N	20
Decay coefficient	α_L	0.001
Threshold decay	α_T	0.001
Amplification coefficient	V_T	20
Stabilization constant	σ	0.1
Contrast amplification factor	γ	10
Local neighborhood window size	Ω	3×3
Kernel size of STFT channel	$\mathbf{W}_1$	3×5
Kernel size of GADF channel	$\mathbf{W}_2$	3×3
Coupling matrix	$\mathbf{M}$	0.25 I

influence of absolute signal amplitude, making the GAF representation more robust to variations in signal gain and background noise levels. Furthermore, the polar encoding in (6) provides a bijective mapping, ensuring that temporal information is preserved without loss.

Both representations are subsequently converted to pseudo-color RGB images of spatial dimensions $H \times W$ for compatibility with standard CNN input architectures, through logarithmic amplitude compression and colormap mapping. Fig. 2 illustrates representative examples of the STFT spectrogram and GADF image. The concrete parameter values, including n_{fft} , n_{hop} , f_s , n , H , and W , are provided in Section IV-A.

C. AW-DPCNN for Multi-Representation Fusion

Owing to their distinct statistical properties and structural characteristics, directly combining the STFT spectrogram and GADF image using conventional pixel-wise averaging or simple feature concatenation may introduce destructive interference rather than constructive complementarity, as demonstrated in the ablation study (Section IV). To address this issue, the proposed AW-DPCNN introduces a PCNN-inspired fusion mechanism with three key innovations: (i) dual-channel external stimuli that independently process STFT and GADF representations through representation-specific convolutional kernels; (ii) a contrast-guided adaptive weighting scheme that dynamically adjusts the relative contribution of each representation based on local saliency; and (iii) iterative pulse-coupled dynamics that propagate and reinforce structurally consistent features across multiple iterations while suppressing spurious activations. The key hyperparameters of the AW-DPCNN are summarized in Table I, and the detailed formulation of each component is presented below.

1) *Input Normalization*: To eliminate scale differences between two representations, each input is first normalized to the interval $[0, 1]$ as

$$\tilde{\mathcal{S}}_k(i, j) = \frac{\mathcal{S}_k(i, j) - \min_{i,j}(\mathcal{S}_k(i, j))}{\max_{i,j}(\mathcal{S}_k(i, j)) - \min_{i,j}(\mathcal{S}_k(i, j)) + \epsilon}, \quad k \in \{1, 2\} \quad (8)$$

where $\mathcal{S}_1$ and $\mathcal{S}_2$ denote the STFT spectrogram and GADF image, respectively, and ϵ is a small positive constant.

2) *Contrast-Guided Adaptive Weighting*: For each representation, the local mean of the normalized representation is computed as

$$\mu_k(i, j) = \frac{1}{|\Omega|} \sum_{(p,q) \in \Omega} \tilde{\mathcal{S}}_k(p, q), \quad (9)$$

where Ω denotes the local neighborhood centered at each pixel location, and $|\Omega|$ represents the number of elements in the neighborhood.

The corresponding local contrast is defined as the local standard deviation

$$C_k(i, j) = \sqrt{|\mathbb{E}_\Omega [\tilde{S}_k^2] - \mu_k^2(i, j)|}, \quad (10)$$

where $\mathbb{E}_\Omega[\cdot]$ denotes local averaging within Ω . A contrast amplification factor γ is then introduced to construct adaptive fusion weights

$$\beta_1(i, j) = \frac{\gamma C_1(i, j)}{\gamma C_1(i, j) + C_2(i, j) + \epsilon}, \quad (11)$$

$$\beta_2(i, j) = \frac{C_2(i, j)}{\gamma C_1(i, j) + C_2(i, j) + \epsilon}, \quad (12)$$

the above formulation ensures $\beta_1(i, j) + \beta_2(i, j) \approx 1$, enabling contrast-driven dynamic weighting.

3) *Dual-Channel PCNN*: Let $\mathbf{L}^n(i, j)$, $\mathbf{T}^n(i, j)$, and $\mathbf{Y}^n(i, j)$ denote the linking term, dynamic threshold, and binary pulse output, respectively, where n denotes the current iteration and $n \in [1, N]$, with N being the total number of iterations. The neural states are initialized as

$$\mathbf{L}^0(i, j) = \mathbf{0}, \quad \mathbf{T}^0(i, j) = \mathbf{0}, \quad \mathbf{Y}^0(i, j) = \mathbf{0}. \quad (13)$$

At the n -th iteration, the external stimulus from two channels is defined as

$$\mathbf{F}_1^n(i, j) = (\mathbf{W}_1 * \mathbf{Y}^{n-1})(i, j) + \tilde{\mathbf{S}}_1(i, j) \quad (14)$$

$$\mathbf{F}_2^n(i, j) = (\mathbf{W}_2 * \mathbf{Y}^{n-1})(i, j) + \tilde{\mathbf{S}}_2(i, j), \quad (15)$$

where $\mathbf{W}_1$ and $\mathbf{W}_2$ are representation-specific convolutional kernels: stripe-shaped kernels for the STFT channel to emphasize frequency continuity, and symmetric kernels for the GADF channel to capture temporal correlations, and $*$ denotes convolution.

The internal linking state is updated by

$$\mathbf{L}^n(i, j) = e^{-\alpha_L} \mathbf{L}^{n-1}(i, j) + (\mathbf{M} * \mathbf{Y}^{n-1})(i, j), \quad (16)$$

where α_L is the decay coefficient and $\mathbf{M}$ represents the coupling matrix.

The total neuron input is then given by

$$\mathbf{U}^n(i, j) = (1 + \mathbf{L}^n(i, j)) \left((1 + \beta_1 \mathbf{F}_1^n(i, j)) \left((1 + \beta_2 \mathbf{F}_2^n(i, j)) \right) + \sigma \right), \quad (17)$$

where σ is a stabilization constant.

The pulse output is determined by a threshold comparison as follows

$$\mathbf{Y}^n(i, j) = \begin{cases} 1, & \mathbf{U}^n(i, j) > \mathbf{T}^{n-1}(i, j) \\ 0, & \text{otherwise} \end{cases}. \quad (18)$$

The dynamic threshold evolves according to

$$\mathbf{T}^n(i, j) = e^{-\alpha_T} \mathbf{T}^{n-1}(i, j) + V_T \mathbf{Y}^n(i, j), \quad (19)$$

where α_T controls threshold decay and V_T is the amplification coefficient.




Fig. 3: Architecture of the proposed adaptive weighted dual-channel PCNN (AW-DPCNN) for multi-representation signal fusion.

4) *Fused Representation*: The accumulated neural response after N iterations is

$$\mathbf{U}_{\text{sum}}(i, j) = \sum_{n=1}^N \mathbf{U}^n(i, j), \quad (20)$$

and the final fused representation is obtained via normalization as

$$\mathbf{F}(i, j) = \frac{\mathbf{U}_{\text{sum}}(i, j) - \min_{i,j} \mathbf{U}_{\text{sum}}(i, j)}{\max_{i,j} \mathbf{U}_{\text{sum}}(i, j) - \min_{i,j} \mathbf{U}_{\text{sum}}(i, j) + \epsilon}. \quad (21)$$

The overall architecture of the proposed AW-DPCNN is illustrated in Fig. 3. The qualitative effectiveness of the adaptive fusion mechanism is further analyzed through feature visualization in Section IV.

D. MSCA-VGG16 for Fused Representation Classification

1) *Design Philosophy and Overview*: The AW-DPCNN fused representations contain heterogeneous features spanning multiple scales and frequency bands. To fully exploit this complementary information, we develop a Multi-Scale Channel Attention enhanced network (MSCA-VGG16) built upon three design principles: (i) *multi-scale receptive field alignment* to capture fault patterns at different temporal and spectral granularities; (ii) *dynamic channel recalibration* via squeeze-and-excitation to suppress noise-dominated frequency bands while amplifying fault-sensitive responses; and (iii) *compact discriminative embedding* to project high-dimensional convolutional features into a lower-dimensional space for enhanced intra-class compactness and inter-class separability.

The overall architecture is a modular composition of a convolutional backbone $\mathcal{B}(\cdot)$, a multi-scale channel attention module $\mathcal{M}(\cdot)$, global pooling $\mathcal{P}(\cdot)$, an embedding projection $\mathcal{E}(\cdot)$, and a linear classifier $\mathcal{F}_{cls}(\cdot)$. The forward mapping from input $\mathbf{X}$ to predicted class probabilities $\hat{\mathbf{y}}$ is

$$\hat{\mathbf{y}} = \mathcal{F}_{cls}(\mathcal{E}(\mathcal{P}(\mathcal{M}(\mathcal{B}(\mathbf{X}))))), \quad (22)$$

where $\mathbf{X} \in \mathbb{R}^{H_0 \times W_0 \times 3}$ denotes the AW-DPCNN fused pseudo-color image of spatial size $H_0 \times W_0$. The overall architecture is illustrated in Fig. 4. The following subsections detail each component.




Fig. 4: Architecture of the proposed MSCA-VGG16 network. The fused AW-DPCNN image is processed by a VGG16-BN backbone, followed by multi-scale convolution (MS), squeeze-and-excitation channel attention (SE), and a compact embedding head (EH) for fault classification.

2) *Convolutional Backbone*: VGG16 with batch normalization (VGG16-BN) is selected as the convolutional backbone. Its purely sequential topology without skip connections, built-in attention, or multi-scale processing provides a clean architectural baseline, ensuring that performance gains can be unambiguously attributed to the proposed MS, CA, and EH modules. The backbone maps the fused input image $X \in \mathbb{R}^{H_0 \times W_0 \times 3}$ to a feature map

$$F = B(X), \quad F \in \mathbb{R}^{H \times W \times C}, \quad (23)$$

where H , W , and C denote the spatial height, width, and number of channels, respectively. A comparative validation against alternative backbones is provided in Section IV-D.

3) *Multi-Scale Convolution Module*: Fault signatures in fused representations span multiple scales, from fine-grained local anomalies to long-range structural correlations. To align the network's receptive field with this multi-scale nature, we introduce a multi-scale convolution (MS) module comprising three parallel branches: a 3×3 convolution for local fine-grained textures, a 5×5 convolution for mid-range structural features, and a 3×3 dilated convolution with rate 2 that expands the receptive field without additional parameters for long-range dependencies. Each branch is formulated as

$$\begin{aligned} F_{ms}^{(1)} &= \Theta_3 * F, \\ F_{ms}^{(2)} &= \Theta_5 * F, \\ F_{ms}^{(3)} &= \Theta_d * F, \end{aligned} \quad (24)$$

where $*$ denotes convolution, $\Theta_3, \Theta_5, \Theta_d \in \mathbb{R}^{C \times C \times k \times k}$ are learnable kernels with sizes 3×3 , 5×5 , and 3×3 (dilation 2), respectively. Each branch preserves the channel dimensionality C through appropriate padding. The multi-scale features are fused via element-wise summation, which encourages each branch to specialize in complementary scales,

$$F_{ms} = F_{ms}^{(1)} + F_{ms}^{(2)} + F_{ms}^{(3)}. \quad (25)$$

The aggregated feature map is normalized and activated,

$$F_{act} = \delta(\text{BN}(F_{ms})), \quad (26)$$

where $\delta(\cdot) = \max(0, \cdot)$ is the ReLU activation and $\text{BN}(\cdot)$ denotes batch normalization.

4) *Squeeze-and-Excitation Channel Attention*: Different frequency bands in the fused representation carry unequal diagnostic information. Some channels encode fault-critical spectral components, while others are dominated by background noise or redundant textures. To dynamically recalibrate channel-wise responses, we adopt a squeeze-and-excitation (SE) mechanism after the multi-scale fusion stage.

Let $F_{act} \in \mathbb{R}^{H \times W \times C}$ be the input to the SE module. The *squeeze* operation aggregates spatial information into a channel descriptor $z \in \mathbb{R}^C$ via global average pooling,

$$z_c = \frac{1}{HW} \sum_{i=1}^H \sum_{j=1}^W F_{act}(i, j, c), \quad c = 1, \dots, C. \quad (27)$$

The *excitation* operation models channel-wise dependencies through a bottleneck structure,

$$\mathbf{s} = \sigma(\mathbf{U}_2 \delta(\mathbf{U}_1 \mathbf{z})), \quad (28)$$

where $\mathbf{U}_1 \in \mathbb{R}^{\frac{C}{r} \times C}$ and $\mathbf{U}_2 \in \mathbb{R}^{C \times \frac{C}{r}}$ are learnable weight matrices, r is the channel reduction ratio controlling the bottleneck capacity, and $\sigma(\cdot)$ is the sigmoid function. The output $\mathbf{s} = [s_1, \dots, s_C]^\top$ represents per-channel attention weights in $[0, 1]$. The refined feature map is obtained by channel-wise rescaling,

$$\mathbf{F}_{\text{att}}(i, j, c) = s_c \cdot \mathbf{F}_{\text{act}}(i, j, c). \quad (29)$$

This mechanism allows the network to emphasize channels containing fault-discriminative information while attenuating noise-dominated channels. The reduction ratio r is specified in the experiment configuration.

5) *Compact Discriminative Embedding Head*: To promote intra-class compactness and inter-class separation while limiting parameter count, we replace conventional large fully-connected layers with a compact embedding head.

First, the spatially refined feature map $\mathbf{F}_{\text{att}}$ is collapsed via global average pooling and flattened,

$$\mathbf{f}_0 = \text{Flatten}(\text{AvgPool}(\mathbf{F}_{\text{att}})) \in \mathbb{R}^C. \quad (30)$$

A fully-connected projection layer extracts high-level features,

$$\mathbf{f}_1 = \delta(\mathbf{W}_{fc1} \mathbf{f}_0), \quad \mathbf{W}_{fc1} \in \mathbb{R}^{D_1 \times C}, \quad (31)$$

followed by dropout for regularization. A compact embedding layer then projects $\mathbf{f}_1$ into a d -dimensional discriminative space,

$$\mathbf{e} = \delta(\text{BN}(\mathbf{W}_e \mathbf{f}_1)), \quad \mathbf{e} \in \mathbb{R}^d, \quad (32)$$

where $\mathbf{W}_e \in \mathbb{R}^{d \times D_1}$. Batch normalization is applied prior to ReLU to stabilize the feature distribution. Dropout is applied after each activation during training and disabled at inference. Finally, the class logits are obtained via a linear classifier,

$$\hat{\mathbf{y}} = \text{softmax}(\mathbf{W}_c \mathbf{e}), \quad \mathbf{W}_c \in \mathbb{R}^{K \times d}, \quad (33)$$

where K is the number of fault categories. The dimensions D_1 (projection layer width) and d (embedding dimensionality), as well as the dropout probability, are treated as hyperparameters whose concrete values are given in Section IV. The entire network is optimized by minimizing the cross-entropy loss,

$$\mathcal{L}_{\text{CE}} = - \sum_{k=1}^K y_k \log \hat{y}_k, \quad (34)$$

where $\mathbf{y} = [y_1, \dots, y_K]^\top$ is the one-hot ground-truth label. In practice, a class-weighted variant $\mathcal{L}_{\text{wCE}}$ is employed to counteract dataset imbalance (Section IV).

6) *Forward Pass Algorithm*: Algorithm 1 summarizes the complete forward pass of the proposed MSCA-VGG16 network from the fused input image to the predicted class probabilities.

Algorithm 1 Forward Pass of MSCA-VGG16

Require: Fused AW-DPCNN image $\mathbf{X} \in \mathbb{R}^{H_0 \times W_0 \times 3}$

- 1: Extract backbone feature map $\mathbf{F}$ using Eq. 23.
- 2: Compute multi-scale feature $\mathbf{F}_{\text{ms}}$ using Eq. 25.
- 3: Apply BatchNorm and ReLU to obtain $\mathbf{F}_{\text{act}}$ using Eq. 26.
- 4: Squeeze spatial information into channel descriptor $\mathbf{z}$ using Eq. 27.
- 5: Compute channel attention weights $\mathbf{s}$ using Eq. 28.
- 6: Obtain channel-refined feature $\mathbf{F}_{\text{att}}$ using Eq. 29.
- 7: Apply global average pooling and flatten to obtain $\mathbf{f}_0$ using Eq. 30.
- 8: Project to high-level features $\mathbf{f}_1$ using Eq. 31, then apply dropout.
- 9: Compute compact embedding $\mathbf{e}$ using Eq. 32, then apply dropout.
- 10: Produce class probabilities $\hat{\mathbf{y}}$ using Eq. 33.

Ensure: Predicted class probabilities $\hat{\mathbf{y}} \in \mathbb{R}^K$.




Fig. 5: CWRU bearing test stand. Vibration signals were collected from accelerometers at the drive-end and fan-end positions under four operating loads (0–3 hp).

IV. DATASET AND EXPERIMENTS

A. Dataset Construction and Preprocessing

The Case Western Reserve University (CWRU) bearing dataset [45] is employed as the primary benchmark. The test stand, illustrated in Fig. 5, comprises a 2-hp motor, a torque transducer/encoder, a dynamometer, and control electronics. Vibration data were collected using accelerometers placed at the 12 o'clock position on the drive-end (DE) and fan-end (FE) motor housing, digitized at 12 kHz for all experiments and additionally at 48 kHz for DE bearing faults.

Single-point faults of diameters 7, 14, and 21 mils were introduced to the ball, inner race, and outer race of bearings via electro-discharge machining. For the outer race, the fault was located at the 6 o'clock position (orthogonal to the load zone). Together with the healthy baseline, this yields ten categories listed in Table II.

For dataset construction, the raw vibration signals are segmented into overlapping windows and converted into pseudo-color fused images through the AW-DPCNN pipeline. Three dataset variants are constructed to support comprehensive evaluation:

- 1) **CWRU 12k DE (primary benchmark)**: 12 kHz drive-end signals, window length 2048 samples (170.7 ms), hop length 1024 samples (85.3 ms), $N_{\text{FFT}} = 1024$, yielding $\Delta f = 11.7$ Hz/bin and $f_{\text{max}} = 6$ kHz (Nyquist).
- 2) **CWRU 12k FE (cross-sensor generalization)**: 12 kHz fan-end signals with identical time–frequency parameters, enabling evaluation of sensor-position transferability.

TABLE II: Operating Conditions and Corresponding Labels of CWRU Bearing Dataset

Label	Description
Normal	Healthy Baseline
BF007	Ball Fault (0.007")
BF014	Ball Fault (0.014")
BF021	Ball Fault (0.021")
IF007	Inner Race Fault (0.007")
IF014	Inner Race Fault (0.014")
IF021	Inner Race Fault (0.021")
OF007	Outer Race Fault @6 (0.007")
OF014	Outer Race Fault @6 (0.014")
OF021	Outer Race Fault @6 (0.021")

3) CWRU 48k DE (cross-sampling-rate generalization):

48 kHz drive-end signals, window length 8192 samples (170.7 ms), hop length 4096 samples (85.3 ms), $N_{\text{FFT}} = 4096$, maintaining identical $\Delta f = 11.7$ Hz/bin with f_{max} extended to 24 kHz (Nyquist).

The window and hop lengths are scaled proportionally with the sampling rate to ensure that every fused image represents the same physical duration (170.7 ms) of vibration signal, eliminating temporal-scale confounds from cross-dataset comparisons. File-level stratified splitting is applied with a 60%/20%/20% (train/validation/test) ratio, using a fixed random seed (42) for reproducibility. All windows from a given source recording are assigned exclusively to a single split to prevent data leakage. The detailed dataset composition, including sample counts per class and per split, is provided in Table III.

For the primary benchmark (12k DE), the normal class contains substantially more windows than fault classes (708 train / 473 validation / 471 test vs. approximately 235 / 117 / 118 per fault class) because the normal baseline recordings are approximately four times longer. This inherent class imbalance is addressed through class-weighted cross-entropy loss and macro-averaged evaluation metrics. All datasets use the linear STFT spectrogram as the time–frequency representation and GADF as the temporal encoding, with the optimal combination validated through systematic representation comparison experiments in Section IV-C.

Fig. 6 illustrates the representations of different bearing conditions before and after adaptive fusion. The STFT spectrogram primarily reflects frequency-domain energy distributions, where different fault types exhibit distinct spectral patterns corresponding to their characteristic fault frequencies. In contrast, GADF images encode temporal correlations and periodic structures of the vibration signals, revealing complementary information that is not explicitly captured in the time–frequency domain.

After processing by the proposed AW-DPCNN, the fused feature maps exhibit enhanced structural clarity and improved discrimination among different fault types. Notably, background noise and redundant patterns are effectively suppressed, while salient fault-related features are preserved and highlighted. This qualitative analysis demonstrates that the AW-DPCNN is capable of adaptively integrating frequency-domain and temporal-domain information, thereby generating more informative representations for subsequent fault classification.

TABLE III: Class-wise sample distribution of three CWRU bearing datasets

Dataset	Class	Train	Val	Test
CWRU 12k DE	BF007	234	117	118
	BF014	236	117	118
	BF021	235	118	118
	IF007	236	117	119
	IF014	234	117	117
	IF021	235	117	118
	OF007	236	118	117
	OF014	234	118	118
	OF021	236	118	118
	Normal	708	473	471
	Total	2824	1530	1532
CWRU 12k FE	BF007	233	117	117
	BF014	235	118	117
	BF021	233	117	117
	IF007	234	117	117
	IF014	234	117	117
	IF021	234	117	117
	OF007	235	117	117
	OF014	69	22	22
	OF021	69	22	22
	Normal	708	473	471
	Total	2484	1337	1334
CWRU 48k DE	BF007	234	118	58
	BF014	234	59	117
	BF021	234	117	58
	IF007	234	58	117
	IF014	236	117	14
	IF021	235	118	58
	OF007	235	58	117
	OF014	175	117	118
	OF021	236	59	118
	Normal	175	117	117
	Total	2228	938	892

B. Implementation Details and Evaluation Metrics

The raw vibration signals are converted into STFT spectrograms and GADF images, fused via AW-DPCNN, and resized to 224×224 pseudo-color RGB images as input to the MSCA-VGG16 network.

To mitigate class imbalance, a class-weighted cross-entropy loss is adopted. The weight for class k is computed as

$$w_k = \frac{N_{\text{total}}}{K \cdot N_k}, \quad (35)$$

where N_{total} denotes the total number of training samples, K is the number of fault categories, and N_k is the number of training samples belonging to class k . The weighted cross-entropy loss is then formulated as

$$\mathcal{L}_{\text{wCE}} = -\frac{1}{B} \sum_{i=1}^B w_{y_i} \sum_{k=1}^K \mathbf{y}_{i,k} \log \hat{\mathbf{y}}_{i,k}, \quad (36)$$

where w_{y_i} is the class weight of the ground-truth label, $\mathbf{y}_{i,k}$ is the k -th entry of the one-hot encoded label vector, and $\hat{\mathbf{y}}_{i,k}$ is the predicted probability for class k . This weighting strategy ensures that minority classes receive proportionally larger loss contributions, preventing the model from being biased toward majority classes.




Fig. 6: Visualization of STFT spectrograms, GADF images, and adaptively fused representations generated by the proposed AW-DPCNN under different bearing conditions. (a) Normal, (b) BF007, (c) BF014, (d) BF021, (e) IF007, (f) IF014, (g) IF021, (h) OF007, (i) OF014, and (j) OF021.

All models are optimized using AdamW with an initial learning rate $\eta = 1 \times 10^{-4}$ and weight decay $\lambda = 1 \times 10^{-3}$. A ReduceLROnPlateau scheduler reduces the learning rate by a factor of 0.5 when the validation F1-score does not improve for 5 consecutive epochs, down to a minimum of $\eta_{\min} = 1 \times 10^{-6}$. Training uses a batch size of 32 for up to 30 epochs. Data augmentation consists of random horizontal flipping (probability 0.5) and random rotation within $\pm 10^\circ$. Input images are normalized using ImageNet statistics, which aligns with the pretrained VGG16-BN backbone. Early stopping is triggered if the validation macro-averaged F1-score does not improve for 15 consecutive epochs, and the model checkpoint with the highest validation F1-score is retained for final evaluation on the held-out test set.

To ensure statistical reliability and to account for performance variance due to random initialization, all key experiments are repeated over three independent trials with different random seeds (42, 123, 456). The aggregated results are reported as mean $\pm$ standard deviation across the three trials.

The experiments in this study were conducted on a system equipped with an Intel i9-14900K CPU and an NVIDIA RTX 5090 GPU. The software environment was based on PyTorch 2.11 and CUDA 13.0. Classification performance is evaluated using accuracy, precision, recall, macro-averaged F1-score, balanced accuracy (B-Acc), G-mean, Cohen's kappa, and the area under the receiver operating characteristic curve (ROC-AUC). For multi-class ROC-AUC, the One-vs-Rest (OvR) macro-averaged AUC is reported.

C. Representation Comparison

To empirically justify the choice of STFT and GADF as the input representations, twelve combinations of three time-frequency representations (STFT, Mel, and Morlet CWT spectrograms) and four temporal encoding methods (GADF, GASF, MTF, and RP) are systematically compared. All representations are fused through the identical AW-DPCNN pipeline ($\gamma = 10$,

$N = 20$) and classified using a standard VGG16 network trained from scratch, thereby isolating the effect of the input representation on diagnostic performance. All other training settings follow Section IV-A and are kept identical across runs.

Table IV reports the test-set performance of all twelve combinations. Several important observations emerge:


1) Time-frequency representation comparison. Among the three time-frequency methods, the STFT spectrogram consistently achieves the highest accuracy when paired with GADF (96.30%), substantially outperforming the best Mel-based combination (Mel and RP, 94.56%) and the best CWT-based combination (CWT and RP, 90.88%). The uniform frequency resolution of the linear STFT spectrogram preserves fine-grained high-frequency fault signatures that are essential for distinguishing between different bearing fault severities, whereas the Mel-scale's nonlinear frequency compression and the CWT's variable resolution may obscure these discriminative spectral details.

2) Temporal encoding comparison. Among the four temporal encoding methods, GADF achieves the best performance when paired with STFT (96.30%), significantly outperforming GASF (91.23%), MTF (90.16%), and RP (90.12%). The GADF's angular difference encoding captures more discriminative temporal transition patterns than the summation-based GASF, and the structured correlation matrix provides richer information than the quantized transition probabilities of MTF or the binary recurrence patterns of RP. Notably, GADF paired with STFT achieves a G-mean of 94.22%, far exceeding the next best combination (Mel and RP, 90.93%), confirming that the STFT and GADF pair provides the most balanced class-wise discrimination.


3) Optimal combination. The STFT spectrogram paired with GADF achieves the best overall performance across all metrics, with 96.30% accuracy, 95.02% F1-score, and 94.22% G-mean. This result empirically validates the choice of STFT and GADF as the input representation pair for the proposed AW-DPCNN framework. The STFT spectrogram provides uniform-




(a) convnext Tiny




(b) efficientnet B0




(c) ViT



(d) MobileNetV3-Small



(e) VGG16



(f) MSCA-VGG16 (Ours)

Fig. 7: Confusion matrices of different network backbones trained using the AW-DPCNN fusion representations. The proposed MSCA-VGG16 achieves the most accurate classification performance with significantly reduced inter-class confusion.

TABLE IV: Representation Comparison Across Time–Frequency and Temporal Encoding Methods. All combinations are fused via AW-DPCNN and classified by standard VGG16 network trained from scratch. Best values per metric are bolded.

TF Method	Temporal	Acc (%)	Prec. (%)	Rec. (%)	F1 (%)	G-mean (%)	Kappa (%)
Mel	GADF	89.18 ± 1.87	86.67 ± 3.99	85.97 ± 2.32	83.94 ± 3.64	77.27 ± 6.99	87.29 ± 2.19
	GASF	93.53 ± 2.22	91.56 ± 4.44	91.58 ± 2.87	90.52 ± 4.02	86.27 ± 8.92	92.40 ± 2.61
	MTF	94.08 ± 1.08	95.28 ± 0.75	92.25 ± 1.41	90.94 ± 2.08	86.27 ± 4.76	93.04 ± 1.27
	RP	94.56 ± 3.61	93.41 ± 4.69	92.91 ± 4.69	92.55 ± 4.96	90.93 ± 6.56	93.61 ± 4.23
STFT	GADF	96.30 ± 0.49	96.36 ± 0.15	95.17 ± 0.63	95.02 ± 0.40	94.22 ± 0.49	95.65 ± 0.58
	GASF	91.23 ± 0.65	93.63 ± 0.75	88.61 ± 0.85	85.86 ± 0.79	69.32 ± 8.26	89.70 ± 0.77
	MTF	90.16 ± 7.46	93.88 ± 1.38	87.21 ± 9.69	86.48 ± 9.50	78.92 ± 17.99	88.44 ± 8.75
	RP	90.12 ± 0.95	86.74 ± 4.72	87.17 ± 1.23	84.28 ± 0.95	39.34 ± 26.45	88.39 ± 1.12
CWT	GADF	89.70 ± 1.53	89.29 ± 1.49	86.57 ± 1.98	84.32 ± 2.55	76.01 ± 6.93	87.91 ± 1.79
	GASF	89.81 ± 1.30	89.44 ± 1.25	86.72 ± 1.70	85.75 ± 2.14	80.87 ± 3.91	88.03 ± 1.53
	MTF	90.01 ± 2.72	90.31 ± 2.80	86.96 ± 3.53	85.24 ± 4.42	77.00 ± 9.29	88.26 ± 3.19
	RP	90.88 ± 0.04	90.22 ± 0.42	88.13 ± 0.05	87.43 ± 0.39	83.95 ± 1.41	89.29 ± 0.04

resolution time–frequency energy distributions, while the GADF encodes complementary temporal correlation structures through angular differences, forming a jointly discriminative basis for bearing fault diagnosis. The representation comparison also reveals that some non-optimal pairs (e.g., Mel and RP at 94.56%) can achieve competitive accuracy, suggesting that the AW-DPCNN fusion mechanism is sufficiently robust to extract discriminative features from suboptimal input representations, though the optimal STFT and GADF pair provides the best performance with the lowest variance.

These results collectively demonstrate that the STFT and GADF combination provides the most effective input representation for the AW-DPCNN fusion framework, offering consistent advantages over alternative time–frequency and temporal encoding methods. The empirical evidence supports the representation design adopted in this work and further validates the robustness of the proposed diagnostic pipeline.

D. Backbone Comparison

To evaluate the effectiveness of the proposed classification network, seven representative deep learning backbones are compared under identical settings, with results reported as mean ± standard deviation over three independent trials in Table V.

MSCA-VGG16 achieves the highest overall performance: 99.85% accuracy, 99.80% F1-score, and 99.80% G-mean, outperforming the second-best VGG16 baseline by 0.66 pp (99.19%) and the widely-used ResNet18 by 1.46 pp (98.39%). This margin confirms that the multi-scale convolution, channel attention, and compact embedding modules each contribute meaningful gains beyond the VGG16 backbone alone. Among the remaining architectures, EfficientNet-B0 (95.74%), MobileNetV3-Small (93.69%), ConvNeXt-Tiny (92.93%), and ViT (82.35%) all underperform substantially, with ViT’s poor result confirming that transformer-based architectures are ill-suited for the small-scale CWRU dataset where convolutional inductive biases provide stronger priors.

E. Visualization and Qualitative Analysis

Qualitative analysis via confusion matrices (Fig. 7), ROC curves (Fig. 8), and t-SNE visualization (Fig. 9) corroborates these findings. The t-SNE projections in Fig. 9 reveal that raw input pixels exhibit substantial inter-class overlap, confirming that high accuracy is not attributable to inherent input separability. Among all backbones, MSCA-VGG16 produces the most compact, well-separated feature clusters, demonstrating that the proposed multi-scale convolution and channel attention mechanisms effectively transform the AW-DPCNN fused representations into a highly discriminative feature space.

F. Ablation Study


To isolate the contribution of each component, a systematic ablation study comprising eight configurations (B0–B7) is conducted in two tiers: B0–B3 examine the fusion pipeline with a standard VGG16 classifier to isolate representation-level effects; B4–B7 build upon the full AW-DPCNN fusion to evaluate individual MSCA-VGG16 components. All configurations use identical training settings (AdamW, $\eta = 1 \times 10^{-4}$, batch size 32, 30 epochs) and are evaluated over three independent trials reported as mean ± standard deviation. Table VI reports the results. Key findings are as follows.

1) Fusion-level ablation (B0–B3). The single-representation baselines establish performance bounds: B0 (STFT-only) achieves 93.37% accuracy, whereas B1 (GADF-only) reaches only 60.99%, confirming that temporal encoding alone lacks the frequency-domain specificity required for fine-grained fault classification. The naive concatenation strategy B2 improves accuracy to 96.28%, indicating complementary information between the two representations, but the high standard deviation ($\pm 4.49\%$) reveals instability from destructive interference. AW-DPCNN fusion (B3) achieves 96.30% accuracy with dramatically reduced variance ($\pm 0.49\%$), demonstrating that while AW-DPCNN does not substantially boost peak accuracy over concatenation at the fusion tier, it provides robust stabilization by adaptively regulating cross-representation contributions.

2) Classifier-level ablation (B4–B7). Using AW-DPCNN fusion as the fixed representation baseline (B3, 96.30%),

TABLE V: Performance Comparison with Different Backbone Networks (Mean $\pm$ Std over 3 Independent Trials)

Network	Acc (%)	Recall (%)	F1 (%)	G-mean (%)	B-Acc (%)	Kappa (%)
MSCA-VGG16 (Ours)	99.85 $\pm$ 0.10	99.80 $\pm$ 0.13	99.80 $\pm$ 0.13	99.80 $\pm$ 0.13	99.80 $\pm$ 0.13	99.82 $\pm$ 0.12
ResNet18	98.39 $\pm$ 1.32	97.91 $\pm$ 1.71	97.85 $\pm$ 1.81	97.66 $\pm$ 2.10	97.91 $\pm$ 1.71	98.11 $\pm$ 1.55
VGG16	99.19 $\pm$ 0.89	98.95 $\pm$ 1.16	98.95 $\pm$ 1.16	98.91 $\pm$ 1.22	98.95 $\pm$ 1.16	99.06 $\pm$ 1.05
EfficientNet-B0	95.74 $\pm$ 2.07	94.47 $\pm$ 2.68	94.14 $\pm$ 3.05	93.08 $\pm$ 4.09	94.47 $\pm$ 2.68	95.00 $\pm$ 2.43
ViT	82.35 $\pm$ 0.89	77.20 $\pm$ 1.06	74.71 $\pm$ 2.19	64.72 $\pm$ 7.53	77.20 $\pm$ 1.06	79.30 $\pm$ 1.04
MobileNetV3-Small	93.69 $\pm$ 1.64	91.81 $\pm$ 2.13	91.03 $\pm$ 2.69	87.82 $\pm$ 5.30	91.81 $\pm$ 2.13	92.60 $\pm$ 1.92
ConvNeXt-Tiny	92.93 $\pm$ 2.12	90.82 $\pm$ 2.76	90.63 $\pm$ 2.50	88.99 $\pm$ 3.11	90.82 $\pm$ 2.76	91.70 $\pm$ 2.49

**Fig. 8:** ROC curves of different backbone networks on the CWRU 12k DE dataset. The proposed MSCA-VGG16 achieves higher AUC on most classes, indicating superior discriminative capability and robustness across classes.

MSCA-VGG16 components are evaluated incrementally. Multi-scale convolution alone (B4, with MS) yields a marginal gain to 96.84% but reintroduces high variance ($\pm 4.01\%$), suggesting that unguided multi-scale processing introduces feature redundancy. Channel attention (B5, with CA) provides the largest single-component improvement, boosting accuracy to 98.97% (an increase of 2.67 pp), confirming that dynamic frequency-band recalibration effectively emphasizes fault-discriminative channels. The compact embedding head (B6, with EH) achieves 98.10%, a moderate improvement. The full MSCA-VGG16 (B7, combining MS, CA, and EH) attains 99.85% accuracy with the tightest standard deviation ($\pm 0.10\%$), demonstrating that the three modules function synergistically: CA drives discriminative channel selection, while MS and EH provide complementary

regularization that collectively stabilizes training.

3) Cumulative decomposition. From B1 (GADF-only, 60.99%) to B7 (full model, 99.85%), the total gain of 38.86 pp decomposes as follows: the STFT representation provides the foundational spectral discrimination (32.38 pp, from B1 to B0); AW-DPCNN fusion contributes robust integration (2.93 pp over STFT-only, from B0 to B3); and the MSCA-VGG16 classifier adds 3.55 pp (from B3 to B7), with channel attention accounting for the majority of this gain.

G. Noise Robustness Evaluation

To evaluate model robustness under realistic industrial conditions, zero-mean additive Gaussian noise is injected at SNR levels from 5.0 to 30.0 dB, with the clean (noise-free)




Fig. 9: t-SNE feature visualization of different backbone networks on the CWRU 12k DE bearing test set. The proposed MSCA-VGG16 produces the most compact and well-separated clusters, indicating superior discriminative representation learning.

TABLE VI: Unified Component Decomposition Ablation. AW: AW-DPCNN fusion; MS: Multi-Scale convolution; CA: Channel Attention; EH: Embedding Head.

Exp.	AW-DPCNN	MS	CA	EH	Acc (%)	F1 (%)	G-mean (%)	Kappa (%)
<i>Fusion-level ablation (VGG16 classifier)</i>								
B0	×	×	×	×	93.37 ± 1.32	91.49 ± 2.25	86.89 ± 5.47	92.58 ± 1.48
B1	×	×	×	×	60.99 ± 1.50	56.90 ± 2.13	12.93 ± 1.42	56.75 ± 1.37
B2	×	×	×	×	96.28 ± 4.49	94.91 ± 6.59	89.45 ± 15.78	95.83 ± 5.03
B3	✓	×	×	×	96.30 ± 0.49	95.02 ± 0.40	94.22 ± 0.49	95.65 ± 0.58
<i>Classifier-level ablation (full AW-DPCNN fusion)</i>								
B4	✓	✓	×	×	96.84 ± 4.01	95.83 ± 5.62	93.98 ± 8.77	96.46 ± 4.49
B5	✓	×	✓	×	98.97 ± 0.83	98.88 ± 0.91	98.81 ± 0.97	98.85 ± 0.93
B6	✓	×	×	✓	98.10 ± 3.09	97.72 ± 3.72	97.13 ± 4.75	97.87 ± 3.46
B7	✓	✓	✓	✓	99.85 ± 0.10	99.80 ± 0.13	99.80 ± 0.13	99.82 ± 0.12

baseline also reported. Fig. 10 presents the accuracy, F_1 -score, and AUC of each backbone network across SNR levels.

The proposed MSCA-VGG16 achieves the highest clean accuracy (100.0%) and fully recovers to perfect classification by 20.0 dB. At 10.0 dB it retains 94.8% accuracy, and even at the most challenging 5.0 dB level it maintains 48.6%, substantially outperforming VGG16 (15.4%) and EfficientNet-B0 (11.2%), which suffer near-complete performance collapse. This resilience is attributed to the multi-scale channel attention mechanism, which dynamically suppresses noise-dominated frequency bands while preserving fault-discriminative spectral components.

ConvNeXt-Tiny exhibits the flattest degradation profile, with accuracy varying only between 91.2% and 95.1% across all SNR levels, indicating that its modernized convolutional design with larger kernels provides inherent noise immunity at the cost of lower peak performance. ResNet18 offers a strong balance, retaining 76.3% at 5.0 dB while achieving 96.9% clean accuracy. ViT, despite the lowest clean accuracy (83.4%), degrades modestly under noise. These results confirm that MSCA-VGG16 achieves the best balance between peak discriminative performance and noise robustness, making it suitable for practical industrial deployment where signal quality cannot be guaranteed.




Fig. 10: Noise robustness comparison across seven backbone networks under additive Gaussian noise injection. Panels (a)–(c) report accuracy, F_1 -score, and AUC respectively as functions of SNR level (clean, 5.0–30.0 dB). The proposed MSCA-VGG16 achieves the highest clean accuracy (100.0%) and fully recovers to perfect classification by 20.0 dB.

TABLE VII: Performance Comparison Across Two CWRU Datasets and Seven Backbone Networks.

Model	CWRU 12k FE			CWRU 48k DE		
	Acc	F1	FPR	Acc	F1	FPR
MSCA-VGG16	97.45 $\pm$ 1.44	97.01 $\pm$ 1.72	2.91 $\pm$ 1.64	94.81 $\pm$ 1.74	86.43 $\pm$ 1.59	13.50 $\pm$ 1.41
ConvNeXt-Tiny	91.68 $\pm$ 0.94	88.60 $\pm$ 2.13	9.61 $\pm$ 1.11	87.44 $\pm$ 2.03	82.73 $\pm$ 2.00	14.88 $\pm$ 2.10
EfficientNet-B0	91.30 $\pm$ 2.41	89.69 $\pm$ 2.82	9.91 $\pm$ 2.75	79.00 $\pm$ 5.35	68.79 $\pm$ 3.89	28.95 $\pm$ 4.57
MobileNetV3-S	91.30 $\pm$ 1.73	88.84 $\pm$ 1.47	9.91 $\pm$ 1.97	78.29 $\pm$ 5.18	66.92 $\pm$ 3.76	32.47 $\pm$ 3.84
ResNet18	95.08 $\pm$ 1.28	93.41 $\pm$ 2.37	5.61 $\pm$ 1.46	94.21 $\pm$ 0.62	87.56 $\pm$ 0.66	13.22 $\pm$ 0.15
VGG16	95.33 $\pm$ 3.06	93.49 $\pm$ 5.04	5.33 $\pm$ 3.49	89.46 $\pm$ 3.99	78.56 $\pm$ 5.95	20.91 $\pm$ 5.50
ViT	85.81 $\pm$ 2.26	81.10 $\pm$ 2.94	16.63 $\pm$ 3.37	69.25 $\pm$ 1.02	56.30 $\pm$ 3.84	39.87 $\pm$ 1.99

H. Generalization Validation

To assess generalization beyond the primary benchmark, experiments are conducted on the 12k FE dataset and the 48k DE dataset. The same AW-DPCNN pipeline and MSCA-VGG16 classifier are applied without architectural modifications, with only the signal-processing parameters adjusted per Section IV-A to maintain consistent temporal duration and frequency resolution. Table VII reports the results. Key findings are:

1) Cross-sensor generalization (12k FE). The proposed MSCA-VGG16 achieves the highest accuracy (97.45%) and F1-score (97.01%) on the fan-end dataset, outperforming ResNet18 (95.08%) and VGG16 (95.33%). This confirms that the multi-scale channel attention mechanism transfers effectively across sensor positions, with the dynamic channel recalibration suppressing sensor-specific noise patterns while preserving fault-discriminative spectral features.

2) Cross-sampling-rate generalization (48k DE). MSCA-VGG16 again achieves the best accuracy (94.81%), followed closely by ResNet18 (94.21%). VGG16 degrades substantially (89.46%), and the lightweight architectures (MobileNetV3-Small, 78.29%; EfficientNet-B0, 79.00%) suffer severe performance collapse. This pattern demonstrates that the multi-scale branches in MSCA-VGG16 are particularly beneficial at higher sampling rates, simultaneously capturing fine-grained high-frequency fault signatures and broader spectral patterns.

3) Architecture robustness ranking. Across both generalization datasets, the performance ranking is consistent: MSCA-VGG16 leads, followed by ResNet18 and VGG16, with

ConvNeXt-Tiny intermediate (87–92%), and ViT consistently trailing (69–86%). The lightweight backbones (MobileNetV3-Small, EfficientNet-B0) are competitive at 12k FE but collapse at 48k DE, indicating that their efficiency-driven design choices limit capacity for complex high-bandwidth spectral modeling.

These results confirm that MSCA-VGG16 generalizes robustly across sensor positions and sampling rates without dataset-specific tuning, validating its practical applicability under varying data acquisition configurations.

V. CONCLUSION

This paper has presented a two-stage framework for vibration-based bearing fault diagnosis comprising AW-DPCNN for adaptive multi-representation fusion and MSCA-VGG16 for fused representation classification. AW-DPCNN introduces contrast-guided dynamic weighting, dual-channel representation-specific convolutional stimuli, and iterative pulse-coupled dynamics to adaptively integrate STFT spectrograms with GADF temporal encodings. MSCA-VGG16 augments a VGG16 backbone with multi-scale convolution, squeeze-and-excitation channel attention, and a compact embedding head to exploit the complementary information in the fused representations.

Extensive experiments on the CWRU bearing dataset demonstrate that the full pipeline achieves 99.85% accuracy on the 12 kHz drive-end primary benchmark, outperforming seven baseline architectures including ResNet18 (98.39%) and VGG16 (99.19%). Systematic ablation confirms that AW-DPCNN fusion contributes 2.93 pp over single-representation baselines and that channel attention is the single most impactful

classifier module (2.67 pp gain). Representation comparisons across twelve time–frequency and temporal encoding combinations validate STFT with GADF as the optimal input pair (96.30% accuracy). Noise robustness evaluations at SNR levels from 5.0 to 30.0 dB demonstrate that MSCA-VGG16 maintains discriminative performance under realistic conditions, substantially outperforming competing architectures at low SNR. Cross-sensor generalization to the fan-end position (97.45%) and cross-sampling-rate generalization to 48 kHz (94.81%) confirm the robustness of the learned representations without dataset-specific tuning.

These results collectively demonstrate that adaptive multi-representation fusion combined with multi-scale channel attention provides an effective and generalizable approach to non-stationary vibration signal fault diagnosis. Future work will explore multi-sensor extensions of the AW-DPCNN framework into the adaptive weighting mechanism.

REFERENCES

- [1] D. Liu, L. Cui, and H. Wang, "Rotating machinery fault diagnosis under time-varying speeds: A review," *IEEE Sensors Journal*, vol. 23, no. 24, pp. 29 969–29 990, 2023.
- [2] S. Sowmya, M. Saimurugan, and I. Edinbarough, "Rotational machine fault diagnosis using artificial intelligence (ai) strategies for the operational challenges under variable speed condition: A review," *IEEE Access*, vol. 12, pp. 144 870–144 889, 2024.
- [3] M. Kang, J. Kim, J.-M. Kim, A. C. C. Tan, E. Y. Kim, and B.-K. Choi, "Reliable fault diagnosis for low-speed bearings using individually trained support vector machines with kernel discriminative feature analysis," *IEEE Transactions on Power Electronics*, vol. 30, no. 5, pp. 2786–2797, 2015.
- [4] A.-S. Qin, H.-L. Mao, Q. Hu, and Q.-H. Zhang, "Bearing fault diagnosis method based on ensemble composite multi-scale dispersion entropy and density peaks clustering," *IEEE Access*, vol. 9, pp. 24 373–24 389, 2021.
- [5] Y. Peng, W. Qiao, F. Cheng, and L. Qu, "Wind turbine drivetrain gearbox fault diagnosis using information fusion on vibration and current signals," *IEEE Transactions on Instrumentation and Measurement*, vol. 70, pp. 1–11, 2021.
- [6] S. Fong, J. Harmouche, S. Narasimhan, and J. Antoni, "Mean shift clustering-based analysis of nonstationary vibration signals for machinery diagnostics," *IEEE Transactions on Instrumentation and Measurement*, vol. 69, no. 7, pp. 4056–4066, 2020.
- [7] C. Sun, H. Yin, Y. Li, and Y. Chai, "A novel rolling bearing vibration impulsive signals detection approach based on dictionary learning," *IEEE/CAA Journal of Automatica Sinica*, vol. 8, no. 6, pp. 1188–1198, 2021.
- [8] X. Chen and Z. Feng, "Time-frequency analysis of torsional vibration signals in resonance region for planetary gearbox fault diagnosis under variable speed conditions," *IEEE Access*, vol. 5, pp. 21 918–21 926, 2017.
- [9] C. Li, Z. Cao, S. Li, and J. Dai, "Frequency estimation of vibration signals: A subspace approach for bearing fault diagnosis," *IEEE Sensors Journal*, vol. 24, no. 1, pp. 449–459, 2024.
- [10] W. Liu, Y. Liu, Z. Zhai, and S. Li, "Time-reassigned multisynchrosqueezing s-transform for bearing fault diagnosis," *IEEE Sensors Journal*, vol. 23, no. 19, pp. 22 813–22 822, 2023.
- [11] M. Ahsan, M. Waqar Hassan, J. Rodriguez, and M. Abdelrahman, "Enhanced fault diagnosis in rotating machinery using a hybrid cwt-letnet-5-lstm model: Performance across various load conditions," *IEEE Access*, vol. 13, pp. 1026–1045, 2025.
- [12] T. Tran and J. Lundgren, "Drill fault diagnosis based on the scalogram and mel spectrogram of sound signals using artificial intelligence," *IEEE Access*, vol. 8, pp. 203 655–203 666, 2020.
- [13] H. Wang, X. Dai, L. Shi, M. Li, Z. Liu, R. Wang, and X. Xia, "Data-augmentation based cbam-resnet-gen method for unbalance fault diagnosis of rotating machinery," *IEEE Access*, vol. 12, pp. 34 785–34 799, 2024.
- [14] S. Huang, X. Guo, Z. Long, X. Ma, W. Chen, W. Lin, R. Jia, P. Duan, and X. Jiang, "Fault diagnosis of harmonic drives based on markov field graph information," *IEEE Sensors Journal*, vol. 24, no. 12, pp. 19 891–19 900, 2024.
- [15] Z. Chen, B. Xu, and Z. Zhang, "Rolling bearing fault diagnosis based on recurrence plot," *IEEE Access*, vol. 12, pp. 149 710–149 721, 2024.
- [16] H. Yu, K. Wang, and Y. Li, "Multiscale representations fusion with joint multiple reconstructions autoencoder for intelligent fault diagnosis," *IEEE Signal Processing Letters*, vol. 25, no. 12, pp. 1880–1884, 2018.
- [17] T. Lin, Y. Zhu, Z. Ren, K. Huang, and D. Gao, "Ccft: The convolution and cross-fusion transformer for fault diagnosis of bearings," *IEEE/ASME Transactions on Mechatronics*, vol. 29, no. 3, pp. 2161–2172, 2024.
- [18] H. Wang, H. Zhu, and H. Li, "A rotating machinery fault diagnosis method based on multi-sensor fusion and eca-cnn," *IEEE Access*, vol. 11, pp. 106 443–106 455, 2023.
- [19] Z. Jiang, M. Li, and J. Yu, "Multiscale and multiorientation log-gabor network for feature learning of vibration signals in bearing fault diagnosis," *IEEE Transactions on Instrumentation and Measurement*, vol. 75, pp. 1–12, 2026.
- [20] D. T. Hoang and H. J. Kang, "A motor current signal-based bearing fault diagnosis using deep learning and information fusion," *IEEE Transactions on Instrumentation and Measurement*, vol. 69, no. 6, pp. 3325–3333, 2020.
- [21] W. Cheng, X. Li, D. Di, X. Wu, L. Nie, D. Zhan, and L. Fan, "An open-set semi-supervised contrastive learning for bearing fault diagnosis," *IEEE Transactions on Instrumentation and Measurement*, vol. 74, pp. 1–10, 2025.
- [22] H. Geraei, E. A. V. Rodriguez, E. Majma, S. Habibi, and D. Al-Ani, "A noise invariant method for bearing fault detection and diagnosis using adapted local binary pattern (albp) and short-time fourier transform (stft)," *IEEE Access*, vol. 12, pp. 107 247–107 260, 2024.
- [23] M. Ahsan, J. Rodriguez, and M. Abdelrahman, "Bearing fault diagnosis in induction motors using low-cost triaxial adxl355 accelerometer and a hybrid cwt-dcn-lstm model," *IEEE Access*, vol. 13, pp. 101 037–101 050, 2025.
- [24] F. Tu, T. Zhang, T. Liu, D. Zhang, and S. Yang, "A novel acoustic-based framework for compound fault diagnosis in rotating machinery with limited samples," *IEEE Transactions on Instrumentation and Measurement*, vol. 74, pp. 1–15, 2025.
- [25] J. Xiong, M. Liu, C. Li, J. Cen, Q. Zhang, and Q. Liu, "A bearing fault diagnosis method based on improved mutual dimensionless and deep learning," *IEEE Sensors Journal*, vol. 23, no. 16, pp. 18 338–18 348, 2023.
- [26] C. Li, W. Feng, Y. Cao, G. Sun, and Y. Ma, "Mt-scgnnet: A spatiotemporal feature fusion-based multitask fault diagnosis model for rolling bearings," *IEEE Sensors Journal*, vol. 26, no. 3, pp. 4349–4364, 2026.
- [27] S. Sun, Z. Xia, J. Wang, H. Wang, and M. Lu, "Fault diagnosis of circuit breakers based on mcf-rps and deep residual knowledge incremental under distillation learning," *IEEE Sensors Journal*, vol. 24, no. 21, pp. 34 862–34 878, 2024.
- [28] R. Fu, Y. Bi, G. Han, X. Zhang, L. Liu, L. Zhao, and B. Hu, "Magva: An open-set fault diagnosis model based on multi-hop attentive graph variational autoencoder for autonomous vehicles," *IEEE Transactions on Intelligent Transportation Systems*, vol. 24, no. 12, pp. 14 873–14 889, 2023.
- [29] G. Gu, X. Yu, and C. Zhao, "Reformulating multi-source domain adaptation as single-source transfer for cross-condition bearing fault diagnosis," *IEEE Access*, vol. 14, pp. 82 676–82 691, 2026.
- [30] J. Johnson and M. Padgett, "Pcnn models and applications," *IEEE Transactions on Neural Networks*, vol. 10, no. 3, pp. 480–498, 1999.
- [31] G. Kuntimad and H. Ranganath, "Perfect image segmentation using pulse coupled neural networks," *IEEE Transactions on Neural Networks*, vol. 10, no. 3, pp. 591–598, 1999.
- [32] X. Gu, D. Yu, and L. Zhang, "Image shadow removal using pulse coupled neural network," *IEEE Transactions on Neural Networks*, vol. 16, no. 3, pp. 692–698, 2005.
- [33] J. Qian, L. Yadong, D. Jindun, F. Xiaofei, and J. Xiuchen, "Image fusion method based on structure-based saliency map and fdst-pcnn framework," *IEEE Access*, vol. 7, pp. 83 484–83 494, 2019.
- [34] S. Basar, M. Ali, G. Ochoa-Ruiz, A. Waheed, G. Rodriguez-Hernandez, and M. Zareei, "A novel defocused image segmentation method based on pcnn and lbp," *IEEE Access*, vol. 9, pp. 87 219–87 240, 2021.
- [35] C. Panigrahy, A. Seal, and N. K. Mahato, "Mri and spect image fusion using a weighted parameter adaptive dual channel pcnn," *IEEE Signal Processing Letters*, vol. 27, pp. 690–694, 2020.
- [36] S. Tang, S. Yuan, and Y. Zhu, "Deep learning-based intelligent fault diagnosis methods toward rotating machinery," *IEEE Access*, vol. 8, pp. 9335–9346, 2020.
- [37] X. Li and X. Song, "A comparative study of machine learning and deep learning models for fault diagnosis of traction motor bearings," *IEEE Access*, vol. 14, pp. 41 671–41 684, 2026.

- [38] W. Zhang, T. Zhang, G. Cui, and Y. Pan, "Intelligent machine fault diagnosis using convolutional neural networks and transfer learning," *IEEE Access*, vol. 10, pp. 50 959–50 973, 2022.
- [39] M. Umar, Z. Ahmad, S. Ullah, F. Saleem, M. Farooq Siddique, and J.-M. Kim, "Advanced fault diagnosis in milling machines using acoustic emission and transfer learning," *IEEE Access*, vol. 13, pp. 100 776–100 790, 2025.
- [40] J. Liu, Y. Tan, N. Yang, Y. Gao, and W.-Q. Zhao, "An anti-noise bearing's fault diagnosis method using adaptive deconvolution and mobile vit," *IEEE Sensors Journal*, vol. 25, no. 11, pp. 19 563–19 575, 2025.
- [41] W. Yu and P. Lv, "An end-to-end intelligent fault diagnosis application for rolling bearing based on mobilenet," *IEEE Access*, vol. 9, pp. 41 925–41 933, 2021.
- [42] X. Yin, Z. Mou, and Y. Wang, "Fault diagnosis of wind turbine gearbox based on multiscale residual features and eca-stacked resnet," *IEEE Sensors Journal*, vol. 23, no. 7, pp. 7320–7333, 2023.
- [43] C. Ma, Z. Jiang, Z. Jia, and W. Song, "A data-driven monitoring method for stator insulation degradation in induction motors based on convnext network," *IEEE Transactions on Energy Conversion*, vol. 40, no. 4, pp. 3163–3174, 2025.
- [44] W. A. Smith and R. B. Randall, "Rolling element bearing diagnostics using the case western reserve university data: A benchmark study," *Mechanical Systems and Signal Processing*, vol. 64-65, pp. 100–131, 2015. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S0888327015002034>
- [45] Case Western Reserve University Bearing Data Center, "Case western reserve university bearing data center," <https://engineering.case.edu/bearingdatacenter>.