

RESULTADOS

IEEE 39 barras

Tabela 1 – Tensoes nas barras - caso base

Barra	Nome	Tipo	V (pu)	Ang. (graus)	Pg (MW)	Qg (Mvar)	Carga P (MW)	Carga Q (Mvar)
1	BUS 01	0	1.048	-8.4	0.0	0.0	0.0	0.0
2	BUS 02	0	1.050	-5.8	0.0	0.0	0.0	0.0
3	BUS 03	0	1.031	-8.6	0.0	0.0	322.0	2.4
4	BUS 04	0	1.004	-9.6	0.0	0.0	500.0	184.0
5	BUS 05	0	1.006	-8.6	0.0	0.0	0.0	0.0
6	BUS 06	0	1.008	-7.9	0.0	0.0	0.0	0.0
7	BUS 07	0	0.997	-10.1	0.0	0.0	233.8	84.0
8	BUS 08	0	0.996	-10.6	0.0	0.0	522.0	176.0
9	BUS 09	0	1.028	-10.3	0.0	0.0	0.0	0.0
10	BUS 10	0	1.017	-5.4	0.0	0.0	0.0	0.0
11	BUS 11	0	1.013	-6.3	0.0	0.0	0.0	0.0
12	BUS 12	0	1.001	-6.2	0.0	0.0	7.5	88.0
13	BUS 13	0	1.015	-6.1	0.0	0.0	0.0	0.0
14	BUS 14	0	1.012	-7.7	0.0	0.0	0.0	0.0
15	BUS 15	0	1.016	-7.7	0.0	0.0	320.0	153.0
16	BUS 16	0	1.033	-6.2	0.0	0.0	329.0	32.0
17	BUS 17	0	1.035	-7.3	0.0	0.0	0.0	0.0
18	BUS 18	0	1.032	-8.2	0.0	0.0	158.0	30.0
19	BUS 19	0	1.050	-1.0	0.0	0.0	0.0	0.0
20	BUS 20	0	0.991	-2.0	0.0	0.0	628.0	103.0
21	BUS 21	0	1.033	-3.8	0.0	0.0	274.0	115.0
22	BUS 22	0	1.050	0.7	0.0	0.0	0.0	0.0
23	BUS 23	0	1.046	0.5	0.0	0.0	247.5	84.0
24	BUS 24	0	1.038	-6.1	0.0	0.0	308.6	-92.0
25	BUS 25	0	1.059	-4.4	0.0	0.0	224.0	47.0
26	BUS 26	0	1.055	-5.5	0.0	0.0	139.0	17.0
27	BUS 27	0	1.040	-7.5	0.0	0.0	281.0	75.0
28	BUS 28	0	1.054	-2.1	0.0	0.0	206.0	27.0
29	BUS 29	0	1.053	0.7	0.0	0.0	283.5	26.0
30	BUS 30	1	1.048	-3.3	250.0	144.0	0.0	0.0
31	BUS 31	2	0.982	-0.0	520.7	196.9	9.2	4.6
32	BUS 32	1	0.983	2.6	650.0	203.0	0.0	0.0
33	BUS 33	1	0.997	4.2	632.0	106.9	0.0	0.0
34	BUS 34	1	1.012	3.2	508.0	164.0	0.0	0.0
35	BUS 35	1	1.049	5.6	650.0	205.4	0.0	0.0
36	BUS 36	1	1.064	8.3	560.0	98.7	0.0	0.0

Continua na proxima pagina

Tabela 1 – Tensoes nas barras - caso base (continua)

Barra	Nome	Tipo	V (pu)	Ang. (graus)	Pg (MW)	Qg (Mvar)	Carga P (MW)	Carga Q (Mvar)
37	BUS 37	1	1.028	2.4	540.0	-3.6	0.0	0.0
38	BUS 38	1	1.027	7.7	830.0	7.1	0.0	0.0
39	BUS 39	1	1.030	-10.0	1000.0	86.2	1104.0	250.0

Tabela 2 – Comparacao de tensoes - ZIP 40/40/20 vs. caso base

Barra	Nome	V base	V ZIP	Delta V	Ang. base	Ang. ZIP	Delta ang.
1	BUS 01	1.048	1.048	0.000	-8.4	-12.9	-4.5
2	BUS 02	1.050	1.050	0.000	-5.8	-10.3	-4.5
3	BUS 03	1.031	1.030	-0.001	-8.6	-12.9	-4.3
4	BUS 04	1.004	1.003	-0.001	-9.6	-13.1	-3.5
5	BUS 05	1.006	1.003	-0.003	-8.6	-11.5	-2.9
6	BUS 06	1.008	1.006	-0.002	-7.9	-10.7	-2.8
7	BUS 07	0.997	0.995	-0.002	-10.1	-13.0	-2.9
8	BUS 08	0.996	0.994	-0.002	-10.6	-13.6	-3.0
9	BUS 09	1.028	1.027	-0.001	-10.3	-14.2	-3.9
10	BUS 10	1.017	1.016	-0.001	-5.4	-8.5	-3.1
11	BUS 11	1.013	1.011	-0.002	-6.3	-9.2	-2.9
12	BUS 12	1.001	0.999	-0.002	-6.2	-9.3	-3.1
13	BUS 13	1.015	1.013	-0.002	-6.1	-9.3	-3.2
14	BUS 14	1.012	1.010	-0.002	-7.7	-11.2	-3.5
15	BUS 15	1.016	1.015	-0.001	-7.7	-12.0	-4.3
16	BUS 16	1.033	1.032	-0.001	-6.2	-10.7	-4.5
17	BUS 17	1.035	1.034	-0.001	-7.3	-11.9	-4.6
18	BUS 18	1.032	1.031	-0.001	-8.2	-12.7	-4.5
19	BUS 19	1.050	1.050	0.000	-1.0	-5.5	-4.5
20	BUS 20	0.991	0.991	0.000	-2.0	-6.4	-4.4
21	BUS 21	1.033	1.031	-0.002	-3.8	-8.4	-4.6
22	BUS 22	1.050	1.050	0.000	0.7	-4.0	-4.7
23	BUS 23	1.046	1.045	-0.001	0.5	-4.3	-4.8
24	BUS 24	1.038	1.038	0.000	-6.1	-10.7	-4.6
25	BUS 25	1.059	1.057	-0.002	-4.4	-9.1	-4.7
26	BUS 26	1.055	1.053	-0.002	-5.5	-10.6	-5.1
27	BUS 27	1.040	1.039	-0.001	-7.5	-12.4	-4.9
28	BUS 28	1.054	1.053	-0.001	-2.1	-7.5	-5.4
29	BUS 29	1.053	1.052	-0.001	0.7	-4.8	-5.5
30	BUS 30	1.048	1.048	0.000	-3.3	-7.9	-4.6
31	BUS 31	0.982	0.982	0.000	-0.0	-0.0	0.0
32	BUS 32	0.983	0.983	0.000	2.6	-0.5	-3.1
33	BUS 33	0.997	0.997	0.000	4.2	-0.3	-4.5
34	BUS 34	1.012	1.012	0.000	3.2	-1.2	-4.4
35	BUS 35	1.049	1.049	0.000	5.6	0.9	-4.7
36	BUS 36	1.064	1.064	0.000	8.3	3.6	-4.7

Continua na proxima pagina

Tabela 2 – Comparacao de tensoes - ZIP 40/40/20 vs. caso base (continua)

Barra	Nome	V base	V ZIP	Delta V	Ang. base	Ang. ZIP	Delta ang.
37	BUS 37	1.028	1.028	0.000	2.4	-2.3	-4.7
38	BUS 38	1.027	1.027	0.000	7.7	2.3	-5.4
39	BUS 39	1.030	1.030	0.000	-10.0	-14.5	-4.5

Tabela 3 – Comparacao de tensoes - ZIP 110% vs. ZIP original

Barra	Nome	V ZIP	V ZIP 110%	Delta V	Ang. ZIP	Ang. ZIP 110%	Delta ang.
1	BUS 01	1.048	1.000	-0.048	-12.9	9.2	22.1
2	BUS 02	1.050	1.037	-0.013	-10.3	1.8	12.1
3	BUS 03	1.030	1.016	-0.014	-12.9	-3.2	9.7
4	BUS 04	1.003	0.987	-0.016	-13.1	-4.9	8.2
5	BUS 05	1.003	0.986	-0.017	-11.5	-3.5	8.0
6	BUS 06	1.006	0.990	-0.016	-10.7	-3.0	7.7
7	BUS 07	0.995	0.973	-0.022	-13.0	-4.2	8.8
8	BUS 08	0.994	0.969	-0.025	-13.6	-4.1	9.5
9	BUS 09	1.027	0.968	-0.059	-14.2	6.5	20.7
10	BUS 10	1.016	1.005	-0.011	-8.5	-0.7	7.8
11	BUS 11	1.011	0.999	-0.012	-9.2	-1.5	7.7
12	BUS 12	0.999	0.987	-0.012	-9.3	-1.6	7.7
13	BUS 13	1.013	1.001	-0.012	-9.3	-1.5	7.8
14	BUS 14	1.010	0.998	-0.012	-11.2	-3.3	7.9
15	BUS 15	1.015	1.005	-0.010	-12.0	-4.6	7.4
16	BUS 16	1.032	1.024	-0.008	-10.7	-3.4	7.3
17	BUS 17	1.034	1.023	-0.011	-11.9	-3.8	8.1
18	BUS 18	1.031	1.019	-0.012	-12.7	-4.1	8.6
19	BUS 19	1.050	1.047	-0.003	-5.5	1.2	6.7
20	BUS 20	0.991	0.988	-0.003	-6.4	-0.2	6.2
21	BUS 21	1.031	1.025	-0.006	-8.4	-1.4	7.0
22	BUS 22	1.050	1.046	-0.004	-4.0	3.0	7.0
23	BUS 23	1.045	1.041	-0.004	-4.3	2.7	7.0
24	BUS 24	1.038	1.031	-0.007	-10.7	-3.5	7.2
25	BUS 25	1.057	1.042	-0.015	-9.1	2.1	11.2
26	BUS 26	1.053	1.041	-0.012	-10.6	-1.6	9.0
27	BUS 27	1.039	1.026	-0.013	-12.4	-3.9	8.5
28	BUS 28	1.053	1.045	-0.008	-7.5	0.9	8.4
29	BUS 29	1.052	1.047	-0.005	-4.8	3.6	8.4
30	BUS 30	1.048	1.048	0.000	-7.9	4.3	12.2
31	BUS 31	0.982	0.982	0.000	-0.0	-0.0	0.0
32	BUS 32	0.983	0.983	0.000	-0.5	7.4	7.9
33	BUS 33	0.997	0.997	0.000	-0.3	6.5	6.8
34	BUS 34	1.012	1.012	0.000	-1.2	5.0	6.2
35	BUS 35	1.049	1.049	0.000	0.9	8.0	7.1
36	BUS 36	1.064	1.064	0.000	3.6	10.6	7.0

Continua na proxima pagina

Tabela 3 – Comparacao de tensoes - ZIP 110% vs. ZIP original (continua)

Barra	Nome	V ZIP	V ZIP 110%	Delta V	Ang. ZIP	Ang. ZIP 110%	Delta ang.
37	BUS 37	1.028	1.028	0.000	-2.3	9.0	11.3
38	BUS 38	1.027	1.027	0.000	2.3	10.6	8.3
39	BUS 39	1.030	0.964	-0.066	-14.5	13.9	28.4

Tabela 4 – Comparacao de fluxos - ZIP 40/40/20 vs. caso base

De	Para	Circ.	P base	P ZIP	Delta P	Q base	Q ZIP	Delta Q	Perdas base	Perdas ZIP	Delta perdas
1	2	1	-124.3	-121.1	3.2	-29.8	-30.1	-0.3	0.50	0.47	-0.03
1	39	1	124.3	121.1	-3.2	29.8	30.2	0.4	0.19	0.18	-0.01
2	3	1	364.4	333.5	-30.9	91.7	98.6	6.9	1.70	1.46	-0.24
2	25	1	-239.2	-205.1	34.1	79.8	72.5	-7.3	4.13	3.08	-1.05
2	30	1	-250.0	-250.0	0.0	-130.3	-129.9	0.4	0.00	0.00	0.00
3	4	1	93.0	22.4	-70.6	112.4	121.5	9.1	0.29	0.22	-0.07
3	18	1	-52.3	-24.3	28.0	-15.0	-14.6	0.4	0.03	0.01	-0.02
4	5	1	-136.9	-216.8	-79.9	-6.7	3.9	10.6	0.15	0.38	0.23
4	14	1	-270.4	-262.5	7.9	-46.8	-47.8	-1.0	0.59	0.56	-0.03
5	6	1	-454.3	-546.5	-92.2	-54.6	-46.0	8.6	0.41	0.60	0.19
5	8	1	317.3	329.3	12.0	59.2	57.4	-1.8	0.83	0.90	0.07
6	7	1	420.6	447.1	26.5	91.6	89.9	-1.7	1.10	1.24	0.14
6	11	1	-363.8	-311.0	52.8	-32.4	-44.7	-12.3	0.92	0.68	-0.24
6	31	1	-511.5	-683.3	-171.8	-114.9	-94.6	20.3	0.00	0.00	0.00
7	8	1	185.7	213.5	27.8	2.1	-1.3	-3.4	0.14	0.18	0.04
8	9	1	-20.0	23.4	43.4	-105.4	-110.9	-5.5	0.18	0.21	0.03
9	39	1	-20.1	23.2	43.3	-69.3	-75.3	-6.0	0.00	0.01	0.01
10	11	1	365.2	316.7	-48.5	70.2	78.2	8.0	0.54	0.41	-0.13
10	13	1	284.7	333.2	48.5	36.9	35.9	-1.0	0.32	0.44	0.12
10	32	1	-650.0	-650.0	0.0	-107.1	-114.1	-7.0	0.00	0.00	0.00
11	12	1	-0.1	4.7	4.8	43.0	42.7	-0.3	0.03	0.03	0.00
12	13	1	-7.6	-2.9	4.7	-45.8	-45.9	-0.1	0.03	0.03	0.00
13	14	1	276.8	329.9	53.1	-5.8	-8.2	-2.4	0.67	0.95	0.28
14	15	1	5.1	65.9	60.8	-37.9	-44.1	-6.2	0.01	0.09	0.08
15	16	1	-314.9	-259.9	55.0	-153.3	-163.3	-10.0	1.05	0.80	-0.25
16	17	1	230.1	241.3	11.2	-47.6	-47.0	0.6	0.36	0.39	0.03
16	19	1	-502.7	-509.3	-6.6	-43.7	-46.4	-2.7	3.80	3.91	0.11
16	21	1	-329.5	-312.8	16.7	14.5	13.3	-1.2	0.82	0.74	-0.08
16	24	1	-42.8	-21.6	21.2	-98.2	-103.7	-5.5	0.03	0.03	0.00
17	18	1	210.7	188.5	-22.2	11.9	11.7	-0.2	0.29	0.23	-0.06
17	27	1	19.1	52.4	33.3	-49.8	-49.4	0.4	0.02	0.05	0.03
19	20	1	122.6	115.9	-6.7	-8.8	-10.6	-1.8	0.11	0.10	-0.01
19	33	1	-629.1	-629.1	0.0	-48.2	-50.6	-2.4	2.89	2.90	0.01
20	34	1	-505.5	-505.5	0.0	-114.0	-114.4	-0.4	2.50	2.51	0.01
21	22	1	-604.4	-598.0	6.4	-87.2	-91.5	-4.3	2.78	2.73	-0.05
22	23	1	42.9	49.3	6.4	37.0	38.3	1.3	0.02	0.03	0.01
22	35	1	-650.0	-650.0	0.0	-145.0	-149.8	-4.8	0.00	0.00	0.00
23	24	1	353.9	346.7	-7.2	0.5	0.3	-0.2	2.53	2.43	-0.10

Continua na proxima pagina

Tabela 4 – Comparacao de fluxos - ZIP 40/40/20 vs. caso base (continua)

De	Para	Circ.	P base	P ZIP	Delta P	Q base	Q ZIP	Delta Q	Perdas base	Perdas ZIP	Delta perdas
23	36	1	-558.6	-558.6	0.0	-21.0	-24.3	-3.3	1.43	1.43	0.00
25	26	1	71.0	90.6	19.6	-21.4	-23.4	-2.0	0.15	0.24	0.09
25	37	1	-538.3	-538.3	0.0	67.6	60.3	-7.3	1.66	1.66	0.00
26	27	1	262.9	242.6	-20.3	68.7	71.2	2.5	0.95	0.83	-0.12
26	28	1	-140.9	-123.9	17.0	-24.6	-27.7	-3.1	0.78	0.60	-0.18
26	29	1	-190.1	-176.4	13.7	-26.6	-30.3	-3.7	1.90	1.64	-0.26
28	29	1	-347.7	-343.7	4.0	33.1	30.1	-3.0	1.55	1.52	-0.03
29	38	1	-824.8	-824.8	0.0	94.8	89.4	-5.4	5.23	5.23	0.00

Tabela 5 – Comparacao de fluxos - ZIP 110% vs. ZIP original

De	Para	Circ.	P ZIP	P ZIP 110%	Delta P	Q ZIP	Q ZIP 110%	Delta Q	Perdas ZIP	Perdas 110%	Delta perdas
1	2	1	-121.1	313.4	434.5	-30.1	-131.7	-101.6	0.47	3.77	3.30
1	39	1	121.1	-313.4	-434.5	30.2	131.7	101.5	0.18	1.27	1.09
2	3	1	333.5	623.7	290.2	98.6	107.6	9.0	1.46	4.88	3.42
2	25	1	-205.1	-64.0	141.1	72.5	-14.8	-87.3	3.08	0.27	-2.81
2	30	1	-250.0	-250.0	0.0	-129.9	-196.2	-66.3	0.00	0.00	0.00
3	4	1	22.4	144.8	122.4	121.5	118.5	-3.0	0.22	0.48	0.26
3	18	1	-24.3	113.1	137.4	-14.6	-43.1	-28.5	0.01	0.15	0.14
4	5	1	-216.8	-185.9	30.9	3.9	12.1	8.2	0.38	0.29	-0.09
4	14	1	-262.5	-211.2	51.3	-47.8	-74.2	-26.4	0.56	0.40	-0.16
5	6	1	-546.5	-292.6	253.9	-46.0	-118.6	-72.6	0.60	0.20	-0.40
5	8	1	329.3	106.4	-222.9	57.4	139.2	81.8	0.90	0.27	-0.63
6	7	1	447.1	224.5	-222.6	89.9	165.7	75.8	1.24	0.49	-0.75
6	11	1	-311.0	-325.2	-14.2	-44.7	-78.0	-33.3	0.68	0.79	0.11
6	31	1	-683.3	-192.1	491.2	-94.6	-204.7	-110.1	0.00	0.00	0.00
7	8	1	213.5	-24.9	-238.4	-1.3	83.9	85.2	0.18	0.04	-0.14
8	9	1	23.4	-471.9	-495.3	-110.9	60.1	171.0	0.21	5.60	5.39
9	39	1	23.2	-477.5	-500.7	-75.3	7.3	82.6	0.01	2.48	2.47
10	11	1	316.7	330.2	13.5	78.2	112.4	34.2	0.41	0.49	0.08
10	13	1	333.2	319.8	-13.4	35.9	47.9	12.0	0.44	0.42	-0.02
10	32	1	-650.0	-650.0	0.0	-114.1	-160.2	-46.1	0.00	0.00	0.00
11	12	1	4.7	3.7	-1.0	42.7	40.9	-1.8	0.03	0.03	0.00
12	13	1	-2.9	-4.5	-1.6	-45.9	-46.5	-0.6	0.03	0.04	0.01
13	14	1	329.9	314.9	-15.0	-8.2	3.3	11.5	0.95	0.89	-0.06
14	15	1	65.9	102.4	36.5	-44.1	-56.5	-12.4	0.09	0.22	0.13
15	16	1	-259.9	-251.7	8.2	-163.3	-188.4	-25.1	0.80	0.85	0.05
16	17	1	241.3	79.2	-162.1	-47.0	-4.7	42.3	0.39	0.04	-0.35
16	19	1	-509.3	-449.8	59.5	-46.4	-79.8	-33.4	3.91	3.15	-0.76
16	21	1	-312.8	-276.1	36.7	13.3	-2.6	-15.9	0.74	0.58	-0.16
16	24	1	-21.6	21.8	43.4	-103.7	-123.3	-19.6	0.03	0.04	0.01
17	18	1	188.5	64.8	-123.7	11.7	43.3	31.6	0.23	0.04	-0.19
17	27	1	52.4	14.3	-38.1	-49.4	-34.5	14.9	0.05	0.01	-0.04
19	20	1	115.9	176.1	60.2	-10.6	-15.0	-4.4	0.10	0.22	0.12
19	33	1	-629.1	-629.1	0.0	-50.6	-70.6	-20.0	2.90	2.93	0.03
20	34	1	-505.5	-505.5	0.0	-114.4	-128.0	-13.6	2.51	2.55	0.04
21	22	1	-598.0	-587.3	10.7	-91.5	-110.3	-18.8	2.73	2.70	-0.03
22	23	1	49.3	60.0	10.7	38.3	44.3	6.0	0.03	0.04	0.01
22	35	1	-650.0	-650.0	0.0	-149.8	-174.2	-24.4	0.00	0.00	0.00
23	24	1	346.7	332.7	-14.0	0.3	7.3	7.0	2.43	2.26	-0.17

Continua na proxima pagina

Tabela 5 – Comparacao de fluxos - ZIP 110% vs. ZIP original (continua)

De	Para	Circ.	P ZIP	P ZIP 110%	Delta P	Q ZIP	Q ZIP 110%	Delta Q	Perdas ZIP	Perdas 110%	Delta perdas
23	36	1	-558.6	-558.6	0.0	-24.3	-40.0	-15.7	1.43	1.45	0.02
25	26	1	90.6	215.0	124.4	-23.4	-40.0	-16.6	0.24	1.37	1.13
25	37	1	-538.3	-538.3	0.0	60.3	-3.2	-63.5	1.66	1.68	0.02
26	27	1	242.6	305.9	63.3	71.2	73.5	2.3	0.83	1.30	0.47
26	28	1	-123.9	-97.8	26.1	-27.7	-39.4	-11.7	0.60	0.38	-0.22
26	29	1	-176.4	-155.1	21.3	-30.3	-43.6	-13.3	1.64	1.27	-0.37
28	29	1	-343.7	-337.3	6.4	30.1	14.1	-16.0	1.52	1.47	-0.05
29	38	1	-824.8	-824.8	0.0	89.4	56.1	-33.3	5.23	5.24	0.01

Tabela 6 – Níveis de curto-circuito no caso base ANAFAS

Barra	Nome	FT (kA)	FF (kA)	FFT (kA)	Simetrica (kA)
1	BUS 01	4.614	7.166	7.351	8.274
2	BUS 02	9.658	10.655	11.433	12.303
3	BUS 03	6.805	9.255	9.617	10.687
4	BUS 04	6.370	8.481	8.816	9.793
5	BUS 05	6.894	8.434	8.850	9.739
6	BUS 06	7.325	8.568	9.064	9.893
7	BUS 07	5.396	7.132	7.411	8.236
8	BUS 08	5.557	7.410	7.694	8.556
9	BUS 09	4.475	6.945	7.123	8.019
10	BUS 10	7.023	7.969	8.485	9.202
11	BUS 11	6.677	7.844	8.288	9.057
12	BUS 12	3.757	3.734	4.091	4.311
13	BUS 13	6.385	7.666	8.069	8.852
14	BUS 14	6.233	8.175	8.514	9.439
15	BUS 15	5.679	7.924	8.213	9.150
16	BUS 16	8.277	10.400	10.905	12.009
17	BUS 17	6.717	9.192	9.547	10.614
18	BUS 18	5.716	8.127	8.409	9.384
19	BUS 19	7.002	7.253	7.878	8.375
20	BUS 20	5.119	4.928	5.464	5.690
21	BUS 21	5.625	7.300	7.611	8.429
22	BUS 22	7.142	7.591	8.186	8.765
23	BUS 23	6.647	7.173	7.706	8.283
24	BUS 24	5.998	8.051	8.369	9.297
25	BUS 25	7.416	8.547	9.096	9.870
26	BUS 26	4.698	6.429	6.663	7.423
27	BUS 27	4.404	6.386	6.589	7.374
28	BUS 28	3.058	3.863	4.036	4.460
29	BUS 29	4.178	4.402	4.774	5.083
30	BUS 30	9.134	8.605	9.639	9.937
31	BUS 31	5.439	5.259	5.812	6.072
32	BUS 32	6.176	6.009	6.623	6.939
33	BUS 33	6.881	6.561	7.299	7.576
34	BUS 34	4.064	3.752	4.221	4.332
35	BUS 35	6.618	6.395	7.066	7.385
36	BUS 36	5.997	5.607	6.268	6.475
37	BUS 37	6.016	5.796	6.468	6.693
38	BUS 38	4.529	4.452	4.914	5.140
39	BUS 39	30.608	27.271	31.107	31.490

Tabela 7 – Corrente de falta FT na barra 4

Falta	Barra	Nome	Corrente de falta (kA)	Barras com tensao no relatorio
FT	4	BUS 04	6.370	10

Tabela 8 – Tensoes reportadas para a falta FT na barra 4

Barra	Nome	Va (pu)	Ang. A	Vb (pu)	Ang. B	Vc (pu)	Ang. C
2	BUS 02	0.766	-0.3	1.004	-120.6	1.007	120.5
3	BUS 03	0.511	0.0	1.065	-125.9	1.070	125.7
4	BUS 04	0.000	0.0	1.211	-134.5	1.215	134.4
5	BUS 05	0.360	-1.4	1.088	-127.0	1.084	127.2
6	BUS 06	0.416	-1.5	1.069	-125.6	1.063	125.8
8	BUS 08	0.438	-1.3	1.071	-125.8	1.067	126.0
13	BUS 13	0.431	-1.5	1.064	-125.2	1.058	125.4
14	BUS 14	0.311	-0.7	1.107	-128.6	1.108	128.5
15	BUS 15	0.579	-0.6	1.046	-124.2	1.047	124.1
18	BUS 18	0.606	-0.4	1.042	-124.0	1.045	123.9