


Autodesk Docs: \\Micron HQ Campus 2022\PAE-B4E-E-MAIN-XXXX.nt



TEL 971.277.237



A. CIRCUIT ALL NORMAL 277V LIGHTING FIXTURES TO PANEL M3B24B, CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.

B. CIRCUIT ALL EMERGENCY 277V LIGHTING FIXTURES TO PANEL E3B23A, CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.

C. CIRCUIT ALL NORMAL 120V LIGHTING FIXTURES TO PANEL M3B24B, CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.

- A. SEE THE ARCHITECTURAL DRAWINGS FOR EXACT LOCATION OF ALL DEVICES AND LUMINAIRES. REQUEST CLARIFICATIONS IN WRITING TO THE ARCHITECT. UNCOORDINATED ELEMENTS SHALL BE RELOCATED PER THE DIRECTION OF THE ARCHITECT WITHOUT ADDITIONAL COST TO THE PROJECT. OWNER OR DESIGN TEAM IF REQUIRED.
- B. EGRESS LIGHTING SHALL BE PER CODE MINIMUM IN ALL SPACES WHERE EMERGENCY EGRESS LIGHTING IS REQUIRED INCLUDING ALL EXTERIOR SPACES. LUMINAIRES USED FOR EGRESS LIGHTING SHALL BE IDENTIFIED IN THE CONSTRUCTION DOCUMENT AND PERMIT PROCESS. IN STAIRS, ELECTRICAL ROOMS, ID/DM ROOMS, MECHANICAL ROOMS AND MACHINE ROOMS 50% LIGHTING IS TO BE ON EMERGENCY POWER. IN STAIRS, CORRIDORS, AND OTHER AREAS PROVIDING PARTIAL-OUT LIGHTING, EMERGENCY LIGHTING IS TO BE CONTROLLED WITH OCCUPANCY SENSORS TO ALLOW 50% DIMMING WHEN THE SPACE IS UNOCCUPIED.
- C. PROVIDE UL324 DEVICES IN APPLICABLE AREAS FOR EGRESS LIGHTS TO OPERATE ON NORMAL POWERED LIGHTS DURING NORMAL POWER CONDITION AND OVERRIDE TO FULL OUTPUT ON DURING EMERGENCY POWER CONDITIONS.
- D. EXIT SIGNS ARE TO BE PROVIDED TO MEET CODE REQUIREMENTS AND TO BE LOCATED PER THE LIFE SAFETY DIAGRAM. THE NUMBER OF EXIT SIGNS SHALL BE QUANTITY TO NOT EXCEED CODE MAXIMUM DISTANCES BETWEEN SIGNS. ALL EXIT SIGNS ARE TO BE ON EMERGENCY POWER.
- E. REFER TO ELECTRICAL LEGEND SHEET FOR DESIGNATION OF LUMINAIRES USED FOR EGRESS EMERGENCY LIGHTING. PROVIDE THE ARCHITECT WITH EMERGENCY LIGHTING PLAN, CONNECTED TO GENERATOR.
- F. REFER TO DRAWINGS [E20.01](#), [E20.02](#), [E2.03](#) AND [E20.04](#) FOR LUMINAIRE SCHEDULES.
- G. REFER TO THE LIGHTING CONTROL SCHEDULE ON SHEET [E20.05](#) FOR SPECIFIC CONTROL REQUIREMENTS.
- H. COORDINATE LIGHTING IN BACK-OF-HOUSE SPACES AND EQUIPMENT ROOMS WITH EQUIPMENT, PIPING, AND OTHER DISCIPLINES PRIOR TO ROUGH-IN. PROVIDE MAIN OR RERUN LIGHT SUPPORT TO PROVIDE UNOBSTRUCTED ILLUMINATION. PROVIDE LOW VOLTAGE CABLING AND SUPPORTS FOR ALL LIGHT CONTROLS AS REQUIRED BY MANUFACTURER. SEE SPECIFICATIONS FOR ADDITIONAL INFORMATION.
- J. MULTIPLE SWITCHES AT THE SAME LOCATION SHALL BE GANGED TOGETHER. PROVIDE INTERMEDIATE BARRIERS FOR MIXED VOLTAGE AND BARRIERS OF POWER ARE NECESSARY.

△	Date	Description
	12/16/2022	INTERIORS 100% DESIGN DEVELOPMENT
	02/03/2023	CONSOLIDATED PROGRESS SET
	06/02/2023	PROGRESS SET
	12/22/2023	CD PROGRESS SET FOR PERMIT AND PRICING
	02/22/2024	CD - MEP BID SET
	03/29/2024	Issue for Permit
1	10/11/2024	ISSUE FOR CONSTRUCTION
2	12/06/2024	BULLETIN #1
3	01/27/25	RFI #28

Seal / Signature

MICRON BUILDING B42

Project Number

22-1717

Description
LIGHTING PLAN LEVEL 3 - SECTOR B

Scale

As indicated

E1.103B

