


2 ENLARGED POWER PLAN - PIZZA & SALAD STATION
1/4" = 1'-0"



1 ENLARGED POWER PLAN - THE MARKET
1/4" = 1'-0"

KITCHEN EQUIPMENT CONNECTION SCHEDULE											
EQUIPMENT DESCRIPTIONS		ELECTRICAL CHARACTERISTICS				FEEDER CHARACTERISTICS				PANEL INFORMATION	NOTES
TAG	DESCRIPTION	LOAD (KW)	LOAD (AMPS)	VOLTS	PHASE	CONDUIT	PHASE CONDUCTORS	GROUND CONDUCTORS	DISCONNECT	PANEL	
2342	WALK IN COOLER (120 V) TYPICAL	0.2	2.0	120	1	3/4"	(2)W12	#12	HARDWARE	SL2B22B	
2343	EVAPORATOR COIL	0.2	2.0	120	1	3/4"	(2)W12	#12	HARDWARE	SL2B22B	
2347	REFRIGERATED CASE	2.5	12.0	208	1	3/4"	(2)W12	#12	6-20R	NL2B33A	
2348	BACK WORK COUNTER W/SINK			120/208	1	3/4"	(2)W12	#12	(2) 5-20R & (1) 6-20R	NL2B33A	
2351	REFRIGERATOR, UNDERCOUNTER	0.3	2.5	120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2354	REFRIGERATED PREP TABLE	0.7	6.2	120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2355	WORK COUNTER W/ WOOD TOP			120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2357	PIZZA OVEN	1.4	12.0	120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2361	PIZZA/SALAD SERVING COUNTER			120/208	1	3/4"	(2)W12	#12	(3) 5-20R & (1) 6-20R	NL2B33A	
2362	REFRIGERATOR, UNDERCOUNTER	0.3	2.5	120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2365	DROP IN HEATED SHELF	0.9	7.9	120	1	3/4"	(2)W12	#12	HARDWARE	NL2B33A	
2366	PRO REGISTER			120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2367	REFRIGERATED CASE, SELF SERVE	1.4	12.0	120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2371	COLD PAN, DROP-IN	0.5	3.9	120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2371	COLD PAN, DROP-IN	0.5	3.9	120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2372	COLD PAN, DROP-IN	0.5	3.9	120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	
2374	CONDIMENT COUNTER			120/208	1	3/4"	(2)W12	#12	(1) 5-20R & (1) 6-20R	NL2B33A	
2378	REMOTE CHILLER	1.8	14.9	120	1	3/4"	(2)W12	#12	5-20R	NL2B33A	

KITCHEN EQUIPMENT CONNECTION SCHEDULE											
EQUIPMENT DESCRIPTIONS			ELECTRICAL CHARACTERISTICS				FEEDER CHARACTERISTICS			PANEL INFORMATION	NOTES
TAG	DESCRIPTION	LOAD (KW)	LOAD (AMPS)	VOLTS	PHASE	CONDUIT	PHASE CONDUCTORS	GROUND CONDUCTORS	DISCONNECT	PANEL	
2378	REMOTE CHILLER	1.8	14.9	120	1	3/4"	(2)W12	#12	5-20R	NL2824B	DEDICATED
2381	POS REGISTER	0.2	2	120	1	3/4"	(2)W12	#12	5-20R	NL2824B	
2382	REFRIGERATED CASE	2.5	12.0	208	1	3/4"	(2)W12	#12	6-20R	NL2824B	
2382	REFRIGERATED CASE	2.5	12.0	208	1	3/4"	(2)W12	#12	6-20R	NL2824B	
2381	REFRIGERATED CASE	2.5	12.0	208	1	3/4"	(2)W12	#12	6-20R	NL2824B	
2382	REFRIGERATED CASE	2.5	12.0	208	1	3/4"	(2)W12	#12	6-20R	NL2824B	
2382	REFRIGERATED CASE	2.5	12.0	208	1	3/4"	(2)W12	#12	6-20R	NL2824B	
2383	REFRIGERATED CASE	2.5	12.0	208	1	3/4"	(2)W12	#12	6-20R	NL2824B	
2383	FREEZER, REACH-IN	0.9	7.5	120	1	3/4"	(2)W12	#12	5-20R	NL2824B	

SHEET NOTES 

8000 South Federal Way
Boise ID 83707

Gensler

811 SW 6TH AVE
SUITE 300
PORTLAND, OR 97204

TEL 971.277.2370



pae-engineers.com

LUMA

Lumald.com

GENERAL NOTES

- A. REFER TO THE KITCHEN CONSULTANT DOCUMENTS FOR FURTHER DETAILS, NOTES AND ELECTRICAL INSTALLATION INSTRUCTIONS.
- B. ALL RECEPTABLES WITHIN THE KITCHEN AREA SHALL BE GFCI TYPE PER NEC.
- C. PROVIDE CONTROLS INTERLOCK CONNECTION BETWEEN THE HOOD EXHAUST FAN PANEL AND THE HOOD EXHAUST FAN STARTER AS RECOMMENDED BY THE HOOD MANUFACTURER.
- D. PROVIDE CONTROLS INTERLOCK CONNECTION BETWEEN THE DISHWASHER CONTROL PANEL AND THE HOOD EXHAUST FAN STARTER AS RECOMMENDED BY THE DISHWASHER MANUFACTURER.
- E. FOR EACH PIECE OF HARDWARE EQUIPMENT, PROVIDE SUITABLE DISCONNECTING MEANS IN ACCESSIBLE CONCEALED, SEPARATE LOCATION.
- F. PROVIDE POWER AND GAS SHUTOFF FOR EQUIPMENT LOCATED UNDER THE HOOD.
- G. PROVIDE FIRE ALARM SYSTEM MONITORING OF THE HOOD FIRE SUPPRESSION PANEL.
- H. CIRCUITS IN PIZZA AND SALAD STATION FED FROM MB-2B334 UNLESS OTHERWISE NOTED.
- I. CIRCUITS IN THE MARKET FEE FROM MB-2B249 UNLESS OTHERWISE NOTED.

△	Date	Description
	05/02/2023	PROGRESS SET
	12/22/2023	CD PROGRESS SET FOR PERMIT AND PRICING
	02/22/2024	CD - MEP BID SET
	03/29/2024	Issue for Permit
1	10/11/2024	ISSUE FOR CONSTRUCTION

Seal / Signature

Project Name

MICRON BUILDING B42

Project Number

22-1717

Description
ENLARGED PLANS - ELECTRICAL

Scale

$$1/4'' = 1'-0''$$

E3.009

City of Boise Stamps