

SHEET NOTES \bigcirc

PROVIDE FURNITURE FEED POWER WHIPS. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN. COORDINATE WITH TECHNOLOGY AND A/V DRAWINGS FOR ADDITIONAL REQUIREMENTS.

CIRCUIT RECEPTACLES WITHIN BOUNDARY TO NL4B24B, UNLESS

OTHERWISE NOTED. 3. CIRCUIT RECEPTACLES WITHIN BOUNDARY TO NL4B34B, UNLESS

OTHERWISE NOTED.



811 SW 6TH AVE SUITE 300 PORTLAND, OR 97204



TEL 971.277.2370

pae-engineers.com

Lumald.com

GENERAL NOTES

- A. REFER TO EQUIPMENT CONNECTION SCHEDULES FOR EQUIPMENT CONNECTION REQUIREMENTS.
- B. PROVIDE #10 CONDUCTORS FOR RECEPTACLE CIRCUITS EXCEEDING TOTAL LENGTH OF 100 FEET BETWEEN DEVICE AND
- C. PROVIDE 3/4-INCH CONDUIT AND #12 AWG CONDUCTORS FOR 20-AMP BRANCH CIRCUITS UNLESS NOTED OTHERWISE.
- D. COORDINATE ELECTRICAL INSTALLATION WITH MECHANICAL AND PLUMBING PLANS FOR EQUIPMENT LOCATIONS PRIOR TO
- E. LOCATE STARTERS/DISCONNECTS WITHIN SIGHT OF AND ADJACENT TO EQUIPMENT SERVED UNLESS OTHERWISE NOTED.
- F. PROVIDE EXTERIOR DEVICES WITH LOCKABLE WEATHERPROOF WHILE-IN-USE
- G. REFER TO DEVICE SCHEDULE ON SHEET E0.207 FOR MORE INFORMATION ON FLOOR DEVICES.

11/18/2022 INTERIORS 50% DESIGN DEVELOPMENT 12/16/2022 INTERIORS 100% DESIGN DEVELOPMENT 02/03/2023 CONSOLIDATED PROGRESS SET 05/02/2023 PROGRESS SET 12/22/2023 CD PROGRESS SET FOR PERMIT AND PRICING 02/22/2024 CD - MEP BID SET 03/29/2024 Issue for Permit 1 10/11/2024 ISSSUE FOR CONSTRUCTION 2 12/06/2024 BULLETIN #1

Seal / Signature

MICRON BUILDING B42

22-1717

ELECTRICAL PLAN LEVEL 4 - SECTOR C

Scale 1/8" = 1'-0"

E1.304C

© 2022 Gensler

City of Boise Stamps