

SHEET NOTES

1. PROVIDE DEDICATED 120V EMERGENCY POWER CONNECTION TO FIRE ALARM EQUIPMENT.
2. PROVIDE 120V CONNECTION FOR DDC CONTROLS.



8000 South Federal Way
Boise ID 83707

Gensler

811 SW 6TH AVE
SUITE 300
PORTLAND, OR 97204

L 971.277.2370



pae-engineers.com

LUMA

Lumald.com

GENERAL NOTES

- A. PROVIDE AND MAINTAIN REQUIRED SPACE, ADEQUATE ILLUMINATION, ACCESS TO WORK SPACE AND HEAD ROOM ABOUT ELECTRICAL EQUIPMENT IN ACCORDANCE WITH IDAHO ELECTRICAL CODE 110.20
- B. FOR ELECTRICAL EQUIPMENT RATED 800 AMPERES OR MORE THAT CONTAINS MOVING PARTS, THE DOORWAYS WITHIN 25' OF THE NEAREST EDGE OF WORK SPACE SHALL OPEN IN THE DIRECTION OF EGRESS AND BE PROTECTED WITH LISTED SAFETY HARDWARE IN ACCORDANCE WITH IDAHO ELECTRICAL CODE 110.20(C)(3).
- C. PROVIDE ARC FLASH HAZARD MARKINGS PER IDAHO ELECTRICAL CODE 110.16. MARKINGS SHALL MEET THE REQUIREMENTS OF 110.21(B) AND SHALL BE CLEARLY VISIBLE TO QUALIFIED PERSONNEL BEFORE EXAMINATION, SERVICING, OR MAINTENANCE OF EQUIPMENT.

△	Date	Description
	11/18/2022	INTERIORS 50% DESIGN DEVELOPMENT
	12/16/2022	INTERIORS 100% DESIGN DEVELOPMENT
	02/03/2023	CONSOLIDATED PROGRESS SET
	05/02/2023	PROGRESS SET
	12/22/2023	CD PROGRESS SET FOR PERMIT AND PRICING
	02/22/2024	CD - MEP BID SET
	03/29/2024	Issue for Permit
A	07/11/2024	PLAN CHECK RESPONSE 1
1	10/11/2024	ISSUE FOR CONSTRUCTION

Seal / Signature

Project Name

MICRON BUILDING B42

Project Number

22-1717

ENLARGED PLANS - ELECTRICAL

Scale

NOT TO SCALE

E3.003

City of Boise Stamps

