

1. TRACK SURFACE MOUNTED AT UNDERSIDE OF SHELVES ON CASEWORK.



811 SW 6TH AVE
SUITE 300
PORTLAND, OR 97204

TEL 971.277.2370



Lumald.com

A. CIRCUIT ALL NORMAL 277V LIGHTING
FIXTURES TO PANEL NH7B21A, CIRCUIT
NUMBER INDICATED UNLESS NOTED
OTHERWISE

- A. CIRCUIT ALL NORMAL 277V LIGHTING FIXTURES TO PANEL NH7B21A. CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.
- B. CIRCUIT ALL EMERGENCY 277V LIGHTING FIXTURES TO PANEL EH7B13A. CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.
- C. CIRCUIT ALL NORMAL 120V LIGHTING FIXTURES TO PANEL NL7B11A. CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.
- D. CIRCUIT ALL EMERGENCY 120V LIGHTING FIXTURES TO PANEL EL7B23A. CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.

A. SEE THE ARCHITECTURAL DRAWINGS FOR EXACT LOCATION OF ALL DEVICES AND LUMINAIRES. REQUEST CLARIFICATIONS IN WRITING PRIOR TO ROUGH-IN. INSTALLED, UNCOORDINATED ELEMENTS SHALL BE RELOCATED PER THE DIRECTION OF THE ARCHITECT WITHOUT ADDITIONAL COST TO THE PROJECT, OWNER OR DESIGN TEAM IF REQUIRED.

- B. EGRESS LIGHTING SHALL BE PER CODE MINIMUM IN ALL SPACES WHERE EMERGENCY EGRESS LIGHTING IS REQUIRED AND INCLUDING ALL EXTERIOR AREAS. LUMINAIRE TYPES AND EGRESS ILLUMINATION WILL BE DESIGNATED IN THE CONSTRUCTION DOCUMENT AND PERMIT PROCESS. IN STAIRS, ALL PHYSICAL ROOMS, IDENTIFIER ROOMS, MECHANICAL ROOMS, ELEVATOR MACHINE ROOMS 50% LIGHTING TO BE ON EMERGENCY POWER. IN STAIRS, IDENTIFIER ROOMS AND OTHER AREAS REQUIRING PART-OFF LIGHT REDUCTION, EMERGENCY LIGHTING SHALL BE CONTROLLED WITH OCCUPANCY PROCESSING TO ALLOW 60% DIMMING WHEN THE SPACE IS UNOCCUPIED.
- C. PROVIDE ULSD DEVICES IN APPLICABLE AREAS FOR EGRESS LIGHTS TO OPERATE WITH NORMAL POWERED LIGHTS DURING NORMAL POWER CONDITIONS. PROVIDE ULSD DEVICES TO FALL BACK TO EMERGENCY POWER CONDITIONS.
- D. EXIST SIGNS ARE TO BE MODIFIED TO MEET THE REQUIREMENTS OF THE LIFE SAFETY CODE LOCATED PER THE LIFE SAFETY DIAGRAM PROVIDED BY THE ARCHITECT IN QUANTITY TO NOT EXCEED CODE MAXIMUM. THE DIFFERENCE BETWEEN EXISTING SIGNS ARE TO BE ON EMERGENCY POWER.

- E. REFER TO ELECTRICAL LEGEND SHEET FOR DESIGNATION OF LUMINAIRES USED FOR EGRESS. EMERGENCY LIGHTING POWER SHALL BE PROVIDED BY A SEPARATE EMERGENCY LIGHTING PANEL, CONNECTED TO GENERATOR.
- F. REFER TO DRAWINGS **50.201**, **50.202**, **50.203**, AND **50.204** FOR LUMINAIRE SCHEDULES.
- G. REFER TO THE LIGHTING CONTROL SCHEDULE ON SHEET **50.205** FOR SPECIFIC CONTROL REQUIREMENTS.
- H. COORDINATE LIGHTING IN BACK-OF-HOUSE AREAS AND EQUIPMENT ROOMS WITH EQUIPMENT, PIPING, AND OTHER DISCIPLINES PRIOR TO ROUGH-IN. PROVIDE CHAIN OR PENDANT SUPPORT TO PROVIDE UNOBSTRUCTED ILLUMINATION.
- I. PROVIDE LOW VOLTAGE CABLEING AND CONDUITING FOR LIGHTING CONTROLS AS REQUIRED BY MANUFACTURER. SEE SPECIFICATIONS FOR ADDITIONAL INFORMATION.
- J. MULTIPLE SWITCHES AT THE SAME LOCATION SHALL BE GANGED TOGETHER. PROVIDE INTERNAL BRANCHES FOR MIXED VOLTAGE CIRCUITS OR BRANCHES OF POWER AS NECESSARY.

Scale

As indicated

E1.107C