

1. UTILITY EQUIPMENT IS BY OTHERS.
2. PROVIDE CONNECTION FOR ELECTRIC METERING EQUIPMENT. LOCATION IS DIAGRAMMATIC TO SHOW CIRCUITING INTENT AS METERS WILL BE INTEGRAL TO SWITCHBOARDS.

- A. PROVIDE AND MAINT REQUIRED SPACE, ADEQUATE ILLUMINATION, ACCESS TO WORK SPACE AND HEAD ROOM ABOUT ELECTRICAL EQUIPMENT IN ACCORDANCE WITH IDAHO ELECTRICAL CODE 110.26
- B. FOR ELECTRICAL EQUIPMENT RATED 800 AMPERES OR MORE THAT CONTAINS OVERCURRENT DEVICES, THE DOOR(S) WITHIN 25' OF THE NEAREST EDGE OF WORK SPACE SHALL OPEN IN THE DIRECTION OF EGRESS AND BE PROVIDED WITH LISTED PANIC HANDBARS IN ACCORDANCE WITH IDAHO ELECTRICAL CODE 110.26(C)(3).
- C. PROVIDE ARC-FLASH HAZARD MARKINGS PER IDAHO ELECTRICAL CODE 110.16. MARKINGS SHALL MEET THE REQUIREMENTS OF 110.12(B) AND SHALL BE CLEARLY VISIBLE TO QUALIFIED PERSONS BEFORE EXAMINATION, SERVICING, OR MAINTENANCE OF EQUIPMENT.

△	Date	Description
	11/18/2022	INTERIORS 50% DESIGN DEVELOPMENT
	12/16/2022	INTERIORS 100% DESIGN DEVELOPMENT
	02/03/2023	CONSOLIDATED PROGRESS SET
	05/02/2023	PROGRESS SET
	12/22/2023	CD PROGRESS SET FOR PERMIT AND PRICING
	02/22/2024	CD - MEP BID SET
	03/29/2024	Issue for Permit
1	10/11/2024	ISSUE FOR CONSTRUCTION

Seal / Signature

Project Name

MICRON BUILDING B42

Project Number

22-1717


**ENLARGED PLANS -
ELECTRICAL**

Scale


NOT TO SCALE

E3.001


City of Boise Stamps



1 ENLARGED PLAN - UTILITY YARD - ELECTRICAL
1/4" = 1'-0"



3 ENLARGED PLAN - UPS - ELECTRICAL
1/2" = 1'-0"



2 ENLARGED PLAN - MAIN ELEC - ELECTRICAL
1/4" = 1'-0"