

A. CIRCUIT ALL NORMAL 277V LIGHTING FIXTURES TO PANEL NH3B24B. CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.

- A. CIRCUIT ALL NORMAL 277V LIGHTING FIXTURES TO PANEL NH3B24B, CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.
- B. CIRCUIT ALL NORMAL 120V LIGHTING FIXTURES TO PANEL NL4B34B, CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.
- C. CIRCUIT ALL EMERGENCY 277V LIGHTING FIXTURES TO PANEL EH4B23A, CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.

A. SEE THE ARCHITECTURAL DRAWINGS FOR EXACT LOCATION OF ALL DEVICES AND LUMINAIRES. REQUEST CLARIFICATIONS IN WRITING PRIOR TO ROUGH-IN. INSTALLED, UNCOORDINATED ELEMENTS SHALL BE RELOCATED PER THE DIRECTION OF THE ARCHITECT WITHOUT ADDITIONAL COST TO THE PROJECT, OWNER OR DESIGN TEAM IF REQUIRED.

- B. EGRESS LIGHTING SHALL BE PER CODE MINIMUM IN ALL SPACES WHERE EMERGENCY EGRESS LIGHTING IS REQUIRED INCLUDING ALL EXTERIOR MINIMALLY REQUIRED FOR EGRESS ILLUMINATION WILL BE DESIGNATED IN THE CONSTRUCTION DOCUMENT AND PERMIT PROCESS IN STAIRS, ELECTRICAL ROOMS, MECHANICAL ROOMS AND ELEVATOR MACHINE ROOMS 50% LIGHTING TO BE ON EMERGENCY POWER IN STAIRS, ELECTRICAL, AND MECHANICAL ROOMS REQUIRING PARTIAL-OFF LIGHT REDUCTION. EMERGENCY LIGHTING IS TO BE CONTROLLED WITH OCCUPANCY SENSORS TO ALLOW 50% DIMMING WHEN THE SPACE IS UNOCCUPIED
- C. PROVIDE UL324 DEVICES IN APPLICABLE AREAS FOR EGRESS LIGHTS TO OPERATE WITH NORMAL POWERED LIGHTS DURING NORMAL POWER CONDITIONS, AND TO FALL BACK TO EMERGENCY DURING EMERGENCY POWER CONDITIONS.
- D. EXIT SIGNS ARE TO BE PROVIDED TO MEET CODE REQUIREMENT AND TO BE LOCATED PER THE LIFE SAFETY DIAGRAM PROVIDED BY THE ARCHITECT IN QUANTITY TO NOT EXCEED CODE MAXIMUM. THE DISTANCE BETWEEN EXIT SIGNS ARE TO BE ON EMERGENCY POWER
- E. REFER TO ELECTRICAL LEGEND SHEET FOR DESIGNATION OF LUMINAIRES USED FOR EGRESS EMERGENCY LIGHTING POWER SHALL BE PROVIDED BY ELECTRICAL LIGHTING PANEL, CONNECTED TO GENERATOR
- F. REFER TO DRAWINGS SEE [E201](#), [E202](#), [E203](#), AND [E204](#) FOR LUMINAIRE SCHEDULES.
- G. REFER TO THE LIGHTING CONTROL SCHEDULE ON SHEET [E201](#) FOR SPECIFIC CONTROL REQUIREMENT
- H. COORDINATE LIGHTING IN BACK-OF-HOUSE AREAS WITH EQUIPMENT ROOMS WITH EQUIPMENT, PIPING, AND OTHER DISCIPLINES PER TO ROUGH-IN. PROVIDE CHAIN OR PENDANT SUPPORT TO PROVIDE UNOBSTRUCTED ILLUMINATION.
- I. PROVIDE LOW VOLTAGE CABLING AND CONNECTIONS FOR LIGHTING CONTROLS AS REQUIRED BY MANUFACTURER. SEE SPECIFICATIONS FOR ADDITIONAL INFORMATION.
- J. MULTIPLE SWITCHES AT THE SAME LOCATION SHALL BE GANGED TOGETHER. PROVIDE INTERIOR BARRIERS FOR MIXED USE AREAS AND BRANCHES OF POWER AS NECESSARY.