

1 ELECTRICAL ROOF PLAN - SECTOR A
1/8" = 1'-0"

SHEET NOTES \bigcirc

PROVIDE FAA OBSTRUCTION MARKER
LIGHT AND ACCESSORIES. LOCATE PER
FAA PROJECT SPECIFIC GUIDANCE

LETTER COORDINATE WITH ARCHITECT PROVIDE L14-30R RECEPTACLE TO WINDOW WASHING EQUIPMENT. COORDINATE EXACT LOCATIONS AND QUANTITIES WITH THE ARCHITECT PRIOR TO PROCUREMENT OR INSTALLATION OF ANY ELECTRICAL EQUIPMENT.



Gensler

811 SW 6TH AVE SUITE 300 PORTLAND, OR 97204



pae-engineers.com

Lumald.com

TEL 971.277.2370

GENERAL NOTES

- A. REFER TO EQUIPMENT CONNECTION SCHEDULES FOR EQUIPMENT CONNECTION REQUIREMENTS.
- B. PROVIDE #10 CONDUCTORS FOR RECEPTACLE CIRCUITS EXCEEDING TOTAL LENGTH OF 100 FEET BETWEEN DEVICE AND
- PROVIDE 3/4-INCH CONDUIT AND #12 AWG CONDUCTORS FOR 20-AMP BRANCH CIRCUITS UNLESS NOTED OTHERWISE.
-). COORDINATE ELECTRICAL INSTALLATION WITH MECHANICAL AND PLUMBING PLANS FOR EQUIPMENT LOCATIONS PRIOR TO ROUGH-IN.
- LOCATE STARTERS/DISCONNECTS WITHIN SIGHT OF AND ADJACENT TO EQUIPMENT SERVED UNLESS OTHERWISE NOTED.
- PROVIDE EXTERIOR DEVICES WITH LOCKABLE WEATHERPROOF WHILE-IN-USE COVERS.
- G. CIRCUIT RECEPTACLES FROM PANEL NL7B31A, UNLESS OTHERWISE NOTED.

11/18/2022 CORE & SHELL 50% DESIGN DEVELOPMENT 12/16/2022 CORE & SHELL 100% DESIGN DEVELOPMENT 02/03/2023 CONSOLIDATED PROGRESS SET 05/02/2023 PROGRESS SET 12/22/2023 CD PROGRESS SET FOR PERMIT AND PRICING 02/22/2024 CD - MEP BID SET 03/29/2024 Issue for Permit 1 10/11/2024 ISSSUE FOR CONSTRUCTION

Seal / Signature

MICRON BUILDING B42

22-1717

ELECTRICAL ROOF PLAN -SECTOR A

Scale 1/8" = 1'-0"

E1.308A