


SHEET NOTES \bigcirc

PROVIDE FURNITURE FEED POWER WHIPS. COORDINATE EXACT REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN. COORDINATE WITH TECHNOLOGY AND A/V DRAWINGS FOR ADDITIONAL REQUIREMENTS.

CIRCUIT RECEPTACLES WITHIN BOUNDARY TO NL3B24B, UNLESS OTHERWISE NOTED.

3. CIRCUIT RECEPTACLES WITHIN BOUNDARY TO NL3B34B, UNLESS OTHERWISE NOTED.







TEL 971.277.2370

pae-engineers.com

Lumald.com

GENERAL NOTES

- A. REFER TO EQUIPMENT CONNECTION SCHEDULES FOR EQUIPMENT CONNECTION REQUIREMENTS.
- B. PROVIDE #10 CONDUCTORS FOR RECEPTACLE CIRCUITS EXCEEDING TOTAL LENGTH OF 100 FEET BETWEEN DEVICE AND
- C. PROVIDE 3/4-INCH CONDUIT AND #12 AWG CONDUCTORS FOR 20-AMP BRANCH CIRCUITS UNLESS NOTED OTHERWISE.
- D. COORDINATE ELECTRICAL INSTALLATION WITH MECHANICAL AND PLUMBING PLANS FOR EQUIPMENT LOCATIONS PRIOR TO ROUGH-IN.
- E. LOCATE STARTERS/DISCONNECTS WITHIN SIGHT OF AND ADJACENT TO EQUIPMENT SERVED UNLESS OTHERWISE NOTED.
- F. PROVIDE EXTERIOR DEVICES WITH LOCKABLE WEATHERPROOF WHILE-IN-USE G. REFER TO DEVICE SCHEDULE ON SHEET

E0.207 FOR MORE INFORMATION ON FLOOR DEVICES.

11/18/2022 INTERIORS 50% DESIGN DEVELOPMENT 12/16/2022 INTERIORS 100% DESIGN DEVELOPMENT 02/03/2023 CONSOLIDATED PROGRESS SET 05/02/2023 PROGRESS SET

12/22/2023 CD PROGRESS SET FOR PERMIT AND PRICING 02/22/2024 CD - MEP BID SET 03/29/2024 Issue for Permit 1 10/11/2024 ISSSUE FOR CONSTRUCTION 2 12/06/2024 BULLETIN #1

Seal / Signature

MICRON BUILDING B42

22-1717

ELECTRICAL PLAN LEVEL 3 - SECTOR C

E1.303C

