

- 

TEL 971.277.2370

811 SW 6TH AVE  
SUITE 300  
PORTLAND, OR 97204

TEL 971.277.2370



Lumald.com

A. CIRCUIT ALL NORMAL 277V LIGHTING FIXTURES TO PANEL NH5B24B. CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.

B. CIRCUIT ALL NORMAL 120V LIGHTING FIXTURES TO PANEL NL6B11A. CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.

C. CIRCUIT ALL EMERGENCY 277V LIGHTING FIXTURES TO PANEL EH7B23A. CIRCUIT NUMBER INDICATED UNLESS NOTED OTHERWISE.

A. SEE THE ARCHITECTURAL DRAWINGS FOR EXACT LOCATION OF ALL DEVICES AND LUMINAIRES. REQUEST CLARIFICATIONS IN WRITING PRIOR TO ROUGH-IN. INSTALLED, UNINSTALLED OR RELOCATED DEVICES MUST BE RELOCATED PER THE DIRECTION OF THE ARCHITECT WITHOUT ADDITIONAL COST TO THE PROJECT, OWNER OR DESIGN TEAM IF REQUIRED.

B. EGRESS LIGHTING SHALL BE PER CODE MINIMUM IN ALL SPACES WHERE EGRESS LIGHTING IS REQUIRED INCLUDING ALL EXTERIOR SPACES. LUMINAIRES USED FOR EGRESS LIGHTING WILL BE PROVIDED IN ACCORDANCE WITH THE CONSTRUCTION DOCUMENT AND PERMIT PROCESS. IN STAIRS, ELECTRICAL ROOMS, ID/MDf ROOMS, MECHANICAL ROOMS AND MACHINE ROOMS, 50% LIGHTING IS TO BE ON EMERGENCY POWER. IN STAIRS, CORRIDORS, AND OTHER AREAS REQUIRING PARTIAL-OFF LIGHTING, EMERGENCY LIGHTING IS TO BE CONTROLLED WITH OCCUPANCY SENSORS TO ALLOW 50% DIMMING WHEN THE SPACE IS UNOCCUPIED.

C. PROVIDE UL924 DEVICES IN APPLICABLE AREAS FOR EGRESS LIGHTING TO OPERATE WITH NORMAL POWERED LIGHTS DURING NORMAL POWER CONDITIONS AND OVERRIDE TO FULL OUTPUT ON DURING EMERGENCY POWER CONDITIONS.

D. EXIT SIGNS ARE TO BE PROVIDED TO MEET CODE REQUIREMENTS AND TO BE LOCATED PER THE LIFE SAFETY DIAGRAM AND THE AREA OF THE EXIT. MAXIMUM QUANTITY TO NOT EXCEED CODE MAXIMUM DISTANCES BETWEEN SIGNS. ALL EXIT SIGNS ARE TO BE ON EMERGENCY POWER.

E. REFER TO ELECTRICAL LEGEND SHEET FOR DESIGNATION OF LUMINAIRES USED FOR EGRESS EMERGENCY LIGHTING. EXIT SIGNS SHALL BE PROVIDED TO THE EMERGENCY LIGHTING PANEL, CONNECTED TO GENERATOR.

F. REFER TO DRAWINGS **5.02.01**, **5.02.02**, **E2.03** and **5.02.04** FOR LUMINAIRE SCHEDULES.

G. REFER TO THE LIGHTING CONTROL SCHEDULE ON SHEET **5.02.05** FOR SPECIFIC CONTROL REQUIREMENTS.

H. COORDINATE LIGHTING IN BACK-OF-HOUSE SPACES AND EQUIPMENT ROOMS WITH EQUIPMENT, PIPING, AND OTHER DISCIPLINES PRIOR TO ROUGH-IN. PROVIDE CHAIN OR RIGID SUPPORT TO PROVIDE UNOBSTRUCTED ILLUMINATION. PROVIDE LOW VOLTAGE CABLING AND WIRING FOR LIGHTING CONTROLS AS REQUIRED BY MANUFACTURER. SEE SPECIFICATIONS FOR ADDITIONAL INFORMATION.

J. MULTIPLE SWITCHES AT THE SAME LOCATION SHALL BE GANGED TOGETHER. PROVIDE INTERNAL BRANCHES FOR MIXED LINE AND NEUTRAL BARRIERS OF POWER AS NECESSARY.

△	Date	Description
	12/16/2022	INTERIORS 100% DESIGN DEVELOPMENT
	02/03/2023	CONSOLIDATED PROGRESS SET
	05/02/2023	PROGRESS SET
	12/22/2023	CD PROGRESS SET FOR PERMIT AND PRICING
	02/22/2024	CD - MEP BID SET
	03/29/2024	Issue for Permit
1	10/11/2024	ISSUE FOR CONSTRUCTION
2	12/06/2024	RIU1 LFTN #1

Seal / Signature

Project Name

MICRON BUILDING B42

Project Number

22-1717

Description
LIGHTING PLAN LEVEL 6 - SECTOR B

Scale

As indicated

**E1.106B**

City of Boise Stamp