

---

## CERTIFICATE OF APPROVAL

### No CAF 144

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

**Designated CERTIFIRE Approved Door and Blank Manufacturers  
as Converted by**

**BRIAN FELL (LEVEN) LIMITED**

**Elm Tree Workshop, West Street, Leven, East Yorkshire, HU17 5LE**  
**Tel: 01964 543333 Fax: 01964 543988**

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

#### SCOPE OF APPROVAL

Approved for processing of fire  
doors manufactured by  
CERTIFIRE approved companies  
as specified in this certificate:  
apertures; glazing of apertures  
and door frames

#### TECHNICAL SCHEDULE

TS10 Fire Resisting Door  
Assemblies with non- Metallic  
Leaves

**Signed and sealed for and on behalf of Exova (UK) Limited trading as  
Warrington Certification**



**Paul Duggan**  
**Certification Manager**



Issued: 3<sup>rd</sup> March 2003  
Reissued: 27<sup>th</sup> March 2018  
Valid to: 26<sup>th</sup> March 2023

Page 1 of 2



## CERTIFICATE No CAF 144 BRIAN FELL (LEVEN) LIMITED

### GLAZED APERTURES and DOOR FRAMES (Premdor Crosby Limited)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by Premdor Crosby Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Technical Handbook (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

| Premdor Crosby Certificate No | Timber Door Product              | Aperture Cutting | Glazing of Apertures | Manufacture of Frames | MDF Frames | Resizing |
|-------------------------------|----------------------------------|------------------|----------------------|-----------------------|------------|----------|
| CF195                         | FD30 Premdor Fireshield          | ✓                | ✓                    | ✓                     | ✓          | ✗        |
| CF198                         | FD30 Moulded Skin Chipboard Core | ✓                | ✓                    | ✓                     | ✓          | ✗        |
| CF240                         | FD30 Premcore                    | ✓                | ✓                    | ✓                     | ✓          | ✓        |
| CF240A                        | FD30 Strebord 44                 | ✓                | ✓                    | ✓                     | ✓          | ✓        |
| CF241                         | FD60 Premcore                    | ✓                | ✓                    | ✓                     | ✗          | ✓        |
| CF241A                        | FD60 Strebord 54                 | ✓                | ✓                    | ✓                     | ✗          | ✓        |
| CF302                         | FD60 Flaxcore                    | ✗                | ✗                    | ✓                     | ✗          | ✗        |
| CF380                         | FD30 Tubecore Lite               | ✓                | ✓                    | ✓                     | ✓          | ✗        |
| CF625                         | FD30 PremCORE Lite (L)           | ✓                | ✓                    | ✓                     | ✓          | ✓        |

**Note:** The scope of approval and field of application for the doors is contained in the above referenced certificates.

4. Apertures, glazing and frames shall be in accordance with Premdor Crosby Limited construction specifications and data sheets for the above referenced products.
5. Processing is conducted in accordance with Premdor Crosby Limited procedures.
6. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
7. Inspection and surveillance of factory production control
8. The approval relates to on-going production.
9. Approved products carry both the original manufacturer's CERTIFIRE approval label and a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Page 2 of 2 Signed  
E/263



Issued: 3<sup>rd</sup> March 2003  
Reissued: 27<sup>th</sup> March 2018  
Valid to: 26<sup>th</sup> March 2023