



CERTIFICATE OF APPROVAL

No CAF 174

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

**Designated CERTIFIRE Approved Door and Blank Manufacturers
as Converted by**

ARBOR FOREST PRODUCTS LTD

Barrow Road, New Holland, North Lincolnshire, DN19 7RR
Tel: 01469 532300 Fax: 01469 531867

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

SCOPE OF APPROVAL

Approved for the manufacture
of door frames for use with
specified CERTIFIRE approved
fire doors

TECHNICAL SCHEDULE

TS10 Fire Resisting Door
Assemblies with non-
Metallic Leaves

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued: 1st June 2016
Reissued: 14th May 2021
Valid to: 13th May 2026

Page 1 of 3





CERTIFICATE No CAF 174

ARBOR FOREST PRODUCTS LTD

1. This approval relates to the manufacture of timber door frames for use with specified CERTIFIRE approved fire doors. Subject to the under mentioned conditions, the doors when fitted in the frame and with hardware and seals specified in the door leaf certificate are designed to meet the requirements as detailed in the relevant certificates.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. The timber door frames shall be of the following specifications/references:

Timber Fire Check Casings:

63 x 100 F/s 58 x 94
63 x 115 F/s 58 x 108
63 x 140 F/s 58 x 133
63 x 150 F/s 58 x 144
50 x 150 F/s 44 x 144
50 x 100 F/s 44 x 95
50 x 115 F/s 44 x 108
50 x 140 F/s 44 x 133
63 x 115 F/s 50 x 100

Timber Fire Check Linings:

38 x 115 F/s 30 x 108
38 x 140 F/s 30 x 133

The timber to be utilised is stated to be redwood or whitewood of nominal density 450 kg/m³, at nominal moisture content of 12%.

4. All timber frames shall be manufactured in accordance with the frame specification as defined in the door data sheet having regard to the maximum door leaf sizes and configurations permitted under the door certification.
5. Processing is conducted in accordance with Arbor Forest Products Ltd procedures.
6. The process is approved on the basis of production surveillance under ISO 9001: 2015.
7. The approval relates to on-going production.
8. Approved timber frames carry a label identified with Arbor Forest Products Ltd name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.



CERTIFICATE No CAF 174

ARBOR FOREST PRODUCTS LTD

9. The certified doors for which the provision of timber door frame kits is approved are as follows:

Manufacturer	Certificate Number	Timber Door Product – Timber Frame
Jeld-Wen UK Ltd	160	FD30 Flush timber door assemblies
	271	FD30 timber door assemblies
	192	FD30 Timber Door Assemblies with Non (Tubeboard Construction)
Vicaima Ltd	218	Timber Door Assemblies (Standard Duty Core)
J B Kind Limited & Irmade	154	FD30 timber door assemblies
Norma Doors Technologies S.A.	292	FD30 timber door assemblies
Corinthian Industries	433	FD30 Panelled door assemblies

The scope of approval and field of application for the doors assemblies is contained in the above referenced CERTIFIRE certificates of approval.

Issued: 1st June 2006

Reissued: 14th May 2021

Valid to: 13th May 2026