



CERTIFICATE OF APPROVAL No CAF 5008

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

Designated CERTIFIRE Approved Door and Blank Manufacturers as Converted by

PENDLE DOORS LTD

Anchor Mill, Mossfold Road, Darwen Lancashire, BB3 0AQ

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

SCOPE OF APPROVAL

Approved for processing of fire doors and/or blanks manufactured by CERTIFIRE approved companies as specified in this certificate: Blank conversion, apertures; glazing of apertures and door frames

TECHNICAL SCHEDULE

TS10 Fire Resisting Door Assemblies with non- Metallic Leaves

Signed and sealed for and on behalf of Exova (UK) Limited trading as Warrington Certification

Paul Duggan
Certification Manager



Issued: 17th July 2012
Reissued: 17th October 2018
Next audit test due: 16/10/2023
Frequency: Every 5 years
Valid to: 19th July 2022

Page 1 of 6







GLAZED APERTURES and DOOR FRAMES (Premdor Crosby Limited)

- This approval relates to the cutting of apertures with or without glazing in doors supplied by Premdor Crosby Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
- 2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

Premdor Crosby Certificate No	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	Resizing
CF195	FD30 Premdor Fireshield	✓	~	✓	×
CF198	FD30 Moulded Skin Chipboard Core	✓	~	~	×
CF240	FD30 Premcore	•	•	•	~
CF240A	FD30 Strebord 44	✓	✓	✓	✓
CF241	FD60 Premcore	✓	✓	✓	~
CF241A	FD60 Strebord 54	✓	✓	✓	✓
CF302	FD60 Flaxcore	×	×	✓	×
CF380	FD30 Tubecore Lite	~	✓	✓	×
CF625	FD30 PremCORE Lite (L)	✓	✓	✓	~

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

- 4. Apertures, glazing and frames shall be in accordance with Premdor Crosby Limited construction specifications and data sheets for the above referenced products.
- 5. Please refer to the relevant / current CERTIFIRE data sheet for suitable frame material options.
- 6. Processing is conducted in accordance with Premdor Crosby Limited procedures.
- 7. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
- 8. Inspection and surveillance of factory production control
- 9. The approval relates to on-going production.
- 10. Approved products carry both the original manufacturer's CERTIFIRE approval label, a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, and the CERTIFIRE certificate number and a unique serial number.

Page 2 of 6 Signed E/150

for logg-





GLAZED APERTURES and DOOR FRAMES (Vicaima Limited)

- This approval relates to the cutting of apertures with or without glazing in doors supplied by Vicaima Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
- 2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

Vicaima Certificate No	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	Resizing
CF218	FD30 'SDC'	✓	✓	✓	x
CF454	FD60	✓	✓	✓	x

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

- 4. Apertures, glazing and frames shall be in accordance with Vicaima Limited construction specifications and data sheets for the above referenced products.
- 5. Please refer to the relevant / current CERTIFIRE data sheet for suitable frame material options.
- 6. Processing is conducted in accordance with Vicaima Limited procedures.
- 7. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
- 8. Inspection and surveillance of factory production control
- 9. The approval relates to on-going production.
- 10. Approved products carry both the original manufacturer's CERTIFIRE approval label and a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Page 3 of 6 Signed E/150

fol lyg-





BLANK CONVERSION, GLAZED APERTURES and DOOR FRAMES (Falcon Panel Products Limited)

- This approval relates to the sizing and lipping and cutting of apertures, with or without glazing, in blanks supplied by Falcon Panel Products Limited and to the manufacture of door frames. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
- 2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 3. The certified blanks for which the sizing and lipping of blanks, cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

FPP Ltd Certificate Number	Timber Door Product	Sizing and lipping	Aperture Cutting	Glazing of Apertures	Manufacture of Frames
CF807	FD30 Strebord blank	•	•	✓	~
CF808	FD60 Strebord blank	~	•	~	~

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

- 4. Lippings, apertures, glazing and frames shall be in accordance with Falcon Panel Products Limited construction specifications and data sheets for the above referenced products.
- 5. Please refer to the relevant / current CERTIFIRE data sheet for suitable frame material options.
- 6. Processing is conducted in accordance with Falcon Panel Products Limited procedures.
- 7. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
- 8. Inspection and surveillance of factory production control
- 9. The approval relates to on-going production.
- Approved products carry a label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Page 4 of 6 Signed E/150

fol ligg-





BLANK CONVERSION, GLAZED APERTURES and DOOR FRAMES (Pacific Rim Wood Limited)

- This approval relates to the sizing and lipping and cutting of apertures, with or without glazing, in blanks supplied by Pacific Rim Wood Limited and to the manufacture of door frames. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
- 2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 3. The certified blanks for which the sizing and lipping of blanks, cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

PRW Ltd Certificate Number	Timber Door Product	Sizing and lipping	Aperture Cutting	Glazing of Apertures	Manufacture of Frames
CF5260	FD30 Flamebreak blank	•	•	•	•
CF5261	FD60 Flamebreak blank	~	✓	~	V

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

- 4. Lippings, apertures, glazing and frames shall be in accordance with Pacific Rim Wood Limited construction specifications and data sheets for the above referenced products.
- 5. Please refer to the relevant / current CERTIFIRE data sheet for suitable frame material options.
- 6. Processing is conducted in accordance with Pacific Rim Wood Limited procedures.
- 7. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
- 8. Inspection and surveillance of factory production control
- 9. The approval relates to on-going production.
- 10. Approved products carry a label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Page 5 of 6 Signed E/150

Pal legg-





GLAZED APERTURES and DOOR FRAMES (ZMR Limited, Trading as Millennium Door Systems)

- This approval relates to the cutting of apertures with or without glazing in doors supplied by supplied by ZMR Limited (Trading as Millennium Door Systems) and to the manufacture of door frames. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
- 2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

ZMR Ltd Certificate Number	Timber Door Product	Sizing and lipping	Aperture Cutting	Glazing of Apertures	Manufacture of Frames
CF819	FD30 Strebord 44	✓	✓	•	~
CF820	FD60 Strebord 54	✓	•	✓	✓

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

- 4. Lippings, apertures, glazing and frames shall be in accordance with ZMR Limited (Trading as Millennium Door Systems) construction specifications and data sheets for the above referenced products.
- 5. Please refer to the relevant / Current CERTIFIRE data sheet for suitable frame material options.
- 6. Processing is conducted in accordance with ZMR Limited (Trading as Millennium Door Systems) procedures.
- 7. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
- 8. Inspection and surveillance of factory production control
- 9. The approval relates to on-going production.
- 10. Approved products carry a label identified with the blank manufacturers certificate number, the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Page 6 of 6 Signed E/150

Pol ligg-