



CERTIFICATE OF APPROVAL

No CAF 187

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

**Designated CERTIFIRE Approved Door and Blank Manufacturers
as Converted by**

CONCEPT DOORS LIMITED

**Pegrams Road, Harlow, Essex, CM18 7PT
Tel: 01279 780200 Fax: 01279 429770**

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

SCOPE OF APPROVAL

Approved for processing of fire
doors manufactured by
CERTIFIRE approved companies
as specified in this certificate:
Apertures; glazing of apertures
and door frames

TECHNICAL SCHEDULE

TS10 Fire Resisting Door
Assemblies with non- Metallic
Leaves

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

**Paul Duggan
Certification Manager**



Issued: 22nd May 2007
Reissued: 12th February 2020
Valid to: 17th May 2022





CERTIFICATE No CAF 187 CONCEPT DOORS LIMITED

GLAZED APERTURES and DOOR FRAMES (Vicaima Limited)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by Vicaima Limited and to the manufacture of door frames. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

Vicaima Certificate No	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	Resizing
CF218	FD30 'SDC'	✓	✓	✓	x
CF454	FD60	✓	✓	✓	x

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

4. Apertures, glazing and frames shall be in accordance with Vicaima Limited construction specifications and data sheets for the above referenced products.
5. Please refer to the relevant / Current CERTIFIRE data sheet for suitable frame material options.
6. Processing is conducted in accordance with Vicaima Limited procedures.
7. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2015.
8. Inspection and surveillance of factory production control
9. The approval relates to on-going production.
10. Approved products carry both the original manufacturer's CERTIFIRE approval label and a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Signed
E/225

Issued: 22nd May 2007
Reissued: 12th February 2020
Valid to: 17th May 2022



CERTIFICATE No CAF 187

CONCEPT DOORS LIMITED

GLAZED APERTURES and DOOR FRAMES (Premdor Crosby Limited)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by Premdor Crosby Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

Premdor Crosby Certificate No	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	Resizing
CF195	FD30 Premdor Fireshield	✓	✓	✓	✗
CF198	FD30 Moulded Skin Chipboard Core	✓	✓	✓	✗
CF240	FD30 Premcore	✓	✓	✓	✓
CF240A	FD30 Strebord 44	✓	✓	✓	✓
CF241	FD60 Premcore	✓	✓	✓	✓
CF241A	FD60 Strebord 54	✓	✓	✓	✓
CF302	FD60 Flaxcore	✗	✗	✓	✗
CF380	FD30 Tubecore Lite	✓	✓	✓	✗
CF625	FD30 PremCORE Lite (L)	✓	✓	✓	✓

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

4. Apertures, glazing and frames shall be in accordance with Premdor Crosby Limited construction specifications and data sheets for the above referenced products.
5. Please refer to the relevant / current CERTIFIRE data sheet for suitable frame material options.
6. Processing is conducted in accordance with Premdor Crosby Limited procedures.
7. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2015.
8. Inspection and surveillance of factory production control
9. The approval relates to on-going production.
10. Approved products carry both the original manufacturer's CERTIFIRE approval label, a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, and the CERTIFIRE certificate number and a unique serial number.

Signed
E/225

Issued: 22nd May 2007
Reissued: 12th February 2020
Valid to: 17th May 2022



CERTIFICATE No CAF 187

CONCEPT DOORS LIMITED

GLAZED APERTURES and DOOR FRAMES (JELD-WEN Limited)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by JELD-WEN Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

JELD-WEN Certificate Number	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	Resizing / Relipping
CF160	FD30 Flush & Die Formed	✓	✓	✓	✗
CF192	FD30 Tubeboard	✓	✓	✓	✗
CF271	FD30 Doors	✓	✗	✓	✗
CF433	FD30 Doors	✗	✗	✓	✗
CF572	FD30 Doors	✗	✗	✓	✗
CF573	FD30 Doors	✗	✗	✓	✗
CF5143	FD30 Doors	✓	✓	✓	✓
CF5478	FD30 Flush & Die Formed	✗	✗	✓	✗
CF177	FD60 Flush	✓	✓	✓	✗
CF179	FD60 Die-formed	✗	✗	✓	✗
CF331	FD60 Doors	✓	✓	✓	✓

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

4. Apertures, glazing and frames shall be in accordance with JELD-WEN UK Limited construction specifications and data sheets for the above referenced products.
5. Please refer to the relevant / current CERTIFIRE data sheet for suitable frame material options.
6. Processing is conducted in accordance with JELD-WEN UK Limited procedures.
7. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2015.
8. Inspection and surveillance of factory production control
9. The approval relates to on-going production.
10. Approved products carry both the original manufacturer's CERTIFIRE approval label and a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Signed
E/225

Issued: 22nd May 2007
Reissued: 12th February 2020
Valid to: 17th May 2022