



---

## CERTIFICATE OF APPROVAL

### No CF 5701

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

**ASSA ABLOY Opening Solutions UK & Ireland**  
**Door Group**  
**21 Ferguson Drive, Knockmore Hill Ind Park, Lisburn, BT 28 2EX**  
**TEL:028 92 662200**

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

#### CERTIFIED PRODUCT

'Assa Abloy Glen LPS1175 SR3'  
and 'Assa Abloy Strangford  
LPS1175 SR4' Steel Doorsets.

#### TECHNICAL SCHEDULE

TS12 Hinged or Pivoted Fire  
Resisting Pedestrian Type  
Doorsets with Metallic Leaves  
and Frames

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan  
Certification Manager

Issued:  
Valid to:

20<sup>th</sup> March 2019  
19<sup>th</sup> March 2024





---

**CERTIFICATE No CF 5701**  
**ASSA ABLOY Opening Solutions**  
**UK & Ireland Door Group**

---

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the use of the above doorsets in providing a fire resistance of up to 180 minutes integrity, as defined in BS EN 1634-1: 2014 and BS 476: Part 22: 1987.
3. The doors are approved on the basis of:
  - i) Initial Type Testing.
  - ii) A design appraisal against TS12.
  - iii) Certification of quality management system.
  - iv) Inspection and surveillance of factory production control
4. The doorsets comprise door leaves with metallic leaves, for use with metallic frames.
5. This approval is applicable to complete doorsets only.
6. This approval is applicable to paper honeycomb cored, single-acting, single and double-leaf, stainless steel doorsets, at leaf dimensions up to those given in Table 1.
7. Hardware items shall be CERTIFIRE approved or otherwise as specified in the data sheet.
8. The doorsets shall be mechanically fixed to wall constructions having a fire resistance of at least the same period as the doorset.
9. This certificate does not include any approval relating to the mechanical requirements of the doorsets specified in TS 12.

Signed  
E/064

P age 2 of 3

Issued: 20<sup>th</sup> March 2019  
Valid to: 19<sup>th</sup> March 2024



---

**CERTIFICATE No CF 5701**  
**ASSA ABLOY Opening Solutions**  
**UK & Ireland Door Group**

---

**LATCHED, SINGLE-ACTING, MILD STEEL DOORSETS**

**Table 1: Maximum Permitted Door Leaf Dimensions for Single and Double-leaf Doorsets**

<b>Integrity (mins)</b>	<b>Maximum Height (mm)</b>	<b>Maximum Width (mm)</b>	<b>Maximum Area (m<sup>2</sup>)</b>
Up to 120	3423 (at 1285 wide)	1608 (at 2734 high)	4.40
Up to 180	3160 (at 1289 wide)	1484 (at 2743 high)	4.07

Signed  
E/064

Page 3 of 3

Issued: 20<sup>th</sup> March 2019  
Valid to: 19<sup>th</sup> March 2024