

Aisha Al Rumhi
AL TASNIM ENTERPRISES LLC

WIR - Requesting to inspect the testing and commissioni...
WORK INSPECTION REQUEST

15/06/2025
TASNIM-WIRQ-044311

Syed Bilal
NICHOLSON JONES PARTNERSHIP OMAN

Re: WIR - Requesting to inspect the testing and commis...
RESPONSE TO WORK INSPEC...

22/07/2025
NJP OMAN-RWIR-059227



MAIL TYPE

Response to Work Inspection Request

MAIL NUMBER

NJP Oman-RWIR-059227

REFERENCE NUMBER

Tasnim-WIRQ-044311

Re: WIR - Requesting to inspect the testing and commissioning of Diesel pump, Electric Pump & Jockey pump at fire pump room as per attached highlighted drawing.

From Mr Syed Bilal - Nicholson Jones Partnership Oman

To (9) Mrs Aisha Al Rumhi - Al Tasnim Enterprises LLC (+8 more...)

Cc (9) Mr Vipin Shankar - Al Tasnim Enterprises LLC (+8 more...)

Sent Tuesday, 22 July 2025 1:19:32 PM GST (GMT +04:00)

Status N/A

DETAILS

Contract No. C2100000180 - RAH Club-Ph1A

Discipline MP Piping.

Phase Phase 1A

WIR Status Closed

Building/Unit ID RAH RC

Inspection Type Hold Point

Milestone Ref. 3.2

Communication Status Closed

FILE ATTACHMENTS (1)

File Name
 T&C Report.pdf

ATTRIBUTES

Attribute 1	RAH RC
Attribute 2	Demolition, D&B of RAHRC (PDO Club) for RAHDP-Ph1A

MESSAGE

Work Inspection Request (WIR)				
WIR Ref. No:		ATNM-RAH-C2100000180-WIR-1967		Rev. No:01
The WIR is issued in pursuance of the Inspection and Test Plan:				
ITP Title	Inspection and Test Plan for Infrastructure(Civil & MEP) Works	ITP No:	RAH-02-106255-QA-5733-00007-0000	Rev. No.
Location description: Infra				
Villa No.:	N/A	Level	GF	
Room	Fire Pump Room	Grid	N/A	
Key reference approved drawings/ documents attached: As per attached				
Description of the works to be inspected: Requesting to inspect the testing and commissioning of Diesel pump, Electric Pump & Jockey pump at fire room as per attached highlighted drawing.				
Works have been inspected by the ATNM QCI. It is in accordance with approved submittals and in the case of submittals returned status B it incorporates all comments marked up upon that submittal.				
Date Inspection Required	15.06.2025	Time of Inspection	10:30	
For AL TASNIM				
Requested by:	Sanjay L	Date:	14.06.2025	
For ATKINS				
Supervision Consultant Inspection Status (write the code):				
A – Approved		B – Approved with comments	B	C – Reject & Resubmit

- This is partial approval, therefore, Final approval is subjected to the Fire consultant and PDO AHJ/PDO Fire Department.
- Identification according to the PDO standards shall be provided.
- System must be tested periodically to make sure the accurate performance of the system.
- Testing and commissioning report is attached for reference.
- Contractor will be responsible for the rectification or compliance of any comments may provide by the PDO Fire department.

Inspected by (name):

Syed Bilal

Date:

22-July

Note: In case of WIR is rejected with status C code the same WIR is to be resubmitted with next rev. number for re-inspection and approval. Same cycle to continue till code A or B is given post inspection.