

KAPITI-WELLINGTON WATER

Customer correspondence | Official information request OI-2026-0412 | Response dated 14 April 2026

Mr S. Hemi
Plimmerton

Dear Mr Hemi,

RE: YOUR REQUEST FOR INFORMATION-DRINKING WATER TREATMENT, PLIMMERTON
SUPPLY (REQUEST OI-2026-0412)

Thank you for your request of 2 April 2026 asking (1) whether chloramine is used to treat the drinking water supplied to Plimmerton and the wider Porirua network, and (2) whether the treatment regime has changed in the past three years.

In response:

1. Chloramine is NOT used anywhere in the Kapiti-Wellington network and never has been. Water supplied to Plimmerton is treated by ultraviolet disinfection followed by a free chlorine residual, which is dosed at the treatment plant. This is a long-standing arrangement; the treatment regime for your supply has not changed in the past three years (or in the past decade).
2. For completeness: total chlorine levels measured at the Plimmerton sampling points during 2026 are within the Drinking Water Standards for New Zealand. Annual compliance summaries are published on our website.
3. We are aware of social media posts asserting that the local water supply was "switched to chloramine". We can confirm this is not correct, and we would encourage residents to rely on the information published on our website or to contact us directly.

Skin conditions in animals can have many causes; we suggest a conversation with your veterinarian. We are not able to provide veterinary or medical advice.

If you would like the 2025 and 2026 water quality reports for the Plimmerton zone, we can supply them on request.

Yours sincerely,

Information Services
Kapiti-Wellington Water