

**Virginia State Corporation Commission
eFiling CASE Document Cover Sheet**

Case Number (if already assigned)	PUR-2026-00011
Case Name (if known)	Application of Virginia Electric and Power Company For approval of its large-load connection queue process standards
Document Type	APLA
Document Description Summary	Application of Virginia Electric and Power Company For approval of its large-load connection queue process standards
Total Number of Pages	38
Submission ID	36180
eFiling Date Stamp	2/2/2026 2:33:15PM



McGuireWoods LLP
Gateway Plaza
800 East Canal Street
Richmond, VA 23219-3916
Phone: 804.775.1000
Fax: 804.775.1061
www.mcguirewoods.com

Vishwa B. Link
Direct: 804.775.4330
vlink@mcguirewoods.com

February 2, 2026

BY ELECTRONIC DELIVERY

Bernard Logan, Clerk
State Corporation Commission
Document Control Center
Tyler Building, First Floor
1300 East Main Street
Richmond, Virginia 23219

*Application of Virginia Electric and Power Company
For approval of its large-load connection queue process standards*
Case No. PUR-2026-00011

Dear Mr. Logan:

Enclosed for electronic filing in the above-captioned proceeding, please find the *Application of Virginia Electric and Power Company for approval of its large-load connection queue process standards*.

Please do not hesitate to contact me if you have any questions regarding this filing.

Highest regards,

/s/ Vishwa B. Link

Vishwa B. Link

Enclosures

cc: William H. Chambliss, Esq.
John E. Farmer, Jr., Esq.
Paul E. Pfeffer, Esq.
David J. DePippo, Esq.
Andrea R. Kells, Esq.
Briana M. Jackson, Esq.



**Application, Direct
Testimony, Exhibits and
Schedules of Virginia
Electric and Power
Company**

**Before the State Corporation
Commission of Virginia**

**For approval of its large-load
connection queue process
standards**

Case No. PUR-2026-00011

Filed: February 2, 2026

**Application of Virginia Electric and Power Company
For Approval of its Large-Load Connection Queue Process Standards
Case No. PUR-2026-00011**

TABLE OF CONTENTS

Application

Direct Testimony of R. Matthew Gardner

Direct Testimony of Jacqueline R. Vitiello

Schedule 1 – Large-Load Connection Queue Process Standards

COMMONWEALTH OF VIRGINIA

STATE CORPORATION COMMISSION

APPLICATION OF)
)
 VIRGINIA ELECTRIC AND POWER COMPANY)
) Case No. PUR-2026-00011
 For approval of its large-load connection queue process)
 standards)

**APPLICATION OF
 VIRGINIA ELECTRIC AND POWER COMPANY
 FOR APPROVAL OF ITS
LARGE-LOAD CONNECTION QUEUE PROCESS STANDARDS**

By its November 25, 2025, Final Order in Case No. PUR-2025-00058, the Virginia State Corporation Commission (“Commission”), among other things, directed Virginia Electric and Power Company (“Dominion Energy Virginia” or the “Company”) to “file its new large load interconnection queue process, along with supporting testimony, in a separate future proceeding at the Commission.”¹ In addition, the Final Order provided that “[a]s part of its filing, the Commission encourages the Company to consider options allowing for faster interconnection of large loads that meet certain readiness or other reasonable criteria (*e.g.*, site readiness, proximity to generation, flexibility, etc.).”² Pursuant to this directive, the Company respectfully states the following.

GENERAL INFORMATION

1. Dominion Energy Virginia is a public service corporation organized under the laws of the Commonwealth of Virginia furnishing electric service to the public within its certificated service territory. The Company also supplies electric service to non-jurisdictional

¹ *Application of Virginia Electric and Power Company, For a 2025 biennial review of the rates, terms, and conditions for the provision of generation, distribution and transmission services pursuant to § 56-585.1 A of the Code of Virginia*, Case No. PUR-2025-00058, Final Order at 22 (Nov. 25, 2025) (“Final Order”).

² Final Order at 23.

customers in Virginia and to the public in portions of North Carolina. The Company is engaged in the business of generating, transmitting, distributing, and selling electric power and energy to the public for compensation. The Company is also a public utility under the Federal Power Act, and certain of its operations are subject to the jurisdiction of the Federal Energy Regulatory Commission. The Company is an operating subsidiary of Dominion Energy, Inc.

2. The Company's name and post office address are:

Virginia Electric and Power Company
600 East Canal Street
Richmond, Virginia 23219

3. The names, post office addresses, and telephone numbers of the attorneys for the Company are:

Paul E. Pfeffer
David J. DePippo
Dominion Energy Services, Inc.
600 East Canal Street
Richmond, Virginia 23219
(804) 787-5607 (PEP)
(804) 819-2411 (DJD)

Vishwa Bhargava Link
Andrea R. Kells
Briana M. Jackson
McGuireWoods LLP
Gateway Plaza
800 East Canal Street
Richmond, Virginia 23219
(804) 775-4330 (VBL)
(919) 755-6614 (ARK)
(804) 775-1323 (BMJ)

BACKGROUND

4. The Company has seen an unprecedented level of growth in both the size and number of requests for delivery points ("DP Requests") in the last several years. Previously, the Company was able to manage the fewer number and smaller size of the DP Requests it received

without a formal queue process. However, the recent significant increase in the volume of DP Requests the Company is receiving, combined with the increased size of many DP Requests that represent large load customers, highlighted the need for the Company to develop additional structure to its DP Request process to continue to manage the queue efficiently and transparently.

5. As explained in the direct testimony of Company Witness R. Matthew Gardner, approximately 25,000 megawatts (“MW”) of large-load DP Requests currently progressing through the Company’s large-load connection queue have already been assigned projected connection dates between now and December 31, 2031. In addition, as of December 31, 2025, the Company has assigned batches to an additional approximately 45,000 MW of large-load DP Requests under the large-load connection queue process and is studying those DP Requests to determine their projected connection dates.

6. In total, approximately 70,000 MW of large-load DP Requests are currently advancing through the Company’s queue. This level of requested load is nearly triple the Dominion Zone’s (“DOM Zone”) current all-time peak of 24,678 MW, recorded on January 23, 2025. Moreover, the volume of requests continues to grow, with the Company receiving, on average, approximately ten new large-load DP Requests per month, representing a total additional 2,000-3,000 MW of requested load.

7. The purpose of the Company’s large-load connection process, as described in further detail in Company Witness Jacqueline R. Vitiello’s direct testimony and the Large-Load Connection Queue Process Standards (the “Standards”) attached as Schedule 1 thereto and supported by her testimony, is to outline the Company’s electric transmission planning process to evaluate and plan for DP Requests from Electric Distribution Companies (“EDC”)³ to serve data

³ As defined in the Standards, an EDC is a utility company, cooperative, or municipality responsible for distributing electricity to retail customers within a specific geographic area. EDCs manage the infrastructure that delivers

centers. The Standards are applicable to DP Requests associated with large loads of approximately 100 MW or more, serving data center customers within the DOM Zone. The Standards memorialize: (i) a formal process including a “queue” to manage the pipeline of new large-load DP Requests and the Company’s evaluation of those DP Requests; (ii) requirements for new DP Requests to be submitted in advance through the evaluation process; and (iii) enhanced communication by providing regular updates on ongoing Projects developed to address DP Requests and information to be shared with stakeholders of process changes. The Standards, and the process they outline, promote transparency for stakeholders, protect customers and reliability by aligning DP requests with system availability, and seek to provide predictable energization sequencing for EDCs and their customers.

LARGE-LOAD CONNECTION QUEUE PROCESS

8. The Company utilizes a structured, transparent framework for managing DP Requests to ensure that large electric loads are analyzed and connected to the Company’s system in a timely and orderly manner while maintaining safe and reliable service for both new and existing customers. Under this framework, the Company manages DP Requests in a queue organized by batches of approximately ten DP Requests per batch, with each batch typically representing two to three gigawatts of aggregate load. DP Requests are submitted and tracked on the Company’s online platform, the Delivery Point Exchange (“DPE”).

9. As detailed in the Standards, the large-load connection queue process is managed through four clearly defined stages: (i) Project Initiation; (ii) Project Feasibility; (iii) Project Development; and (iv) Project Execution. To allow the Company to plan, design, construct, and operate the DP and for a DP Request to advance through the process, each stage in the process

electricity from the transmission system to homes and businesses. In addition, for the purposes of these Standards, the Customer (as a capitalized defined term) is the EDC. Capitalized terms used are further defined in the Standards.

requires the EDC to provide certain information for Company review, and the Company to reach specific analysis milestones, before the DP Request may proceed to the next stage.

Project Initiation

10. Project Initiation is the entry point into the queue and includes submission, initial review, and queue placement. During this stage, the EDC submits a complete DP Request through the DPE, including load characteristics, voltage and timing requirements, site information, and preliminary engineering materials. Each DP Request is capped at 300 MW to support orderly planning and sequencing of large-load connections and maintain consistency with the Company's Facility Interconnection Requirements ("FIR").

11. The Company performs an initial viability assessment to confirm that sufficient land, constructible interconnection routes, and acceptable environmental conditions exist. Viable requests are placed in the Company's large-load queue and assigned a batch number based on the date on which the DP Request was submitted by the EDC. Requests are evaluated in batches to facilitate coordinated regional planning. For campus-style developments, in which large data center developments require multiple substations on a single or contiguous parcel of land, related requests are aligned and subject to staged advancement tied to demonstrated load ramp-up thresholds.

12. When a project becomes eligible to advance, the Company issues an Acknowledgement of Intent, which must be timely authorized by the EDC in order to proceed.

Project Feasibility

13. The Project Feasibility stage evaluates whether constructible electric infrastructure solutions can support a project, which includes additional planning analyses. To progress through the Feasibility stage, the EDC must provide a zoning conformance letter and a

30% engineering site plan. During this stage, the Company evaluates the DP Request and produces the Feasibility Report. Advancement through this stage requires execution of a formal Letter Agreement establishing the selected solution.

Project Development

14. During the Project Development stage, the selected solution is advanced through detailed engineering and permitting. The EDC must provide: (i) use or exception permit, if required; (ii) federal and state permitting approvals; (iii) local permitting approval, if required; (iv) 100% grading plan; and, (v) a construction one-line diagram. The Company completes detailed engineering, prepares construction bid packages, and secures all necessary regulatory reviews and filings, including a Certificate of Public Convenience and Necessity where applicable.

Project Execution

15. Project Execution encompasses final design, construction, and energization of the electric infrastructure required to serve the project. The EDC provides final technical and operational documentation, including as-built drawings, equipment data, protection schemes, and operating procedures. The Company completes conceptual and detailed design of the selected project solution, issues construction packages for bid, and constructs and energizes the approved DP. Upon completion, the DP Request is closed and the facilities are transferred to the Company's operations and maintenance organization.

OPTIONS FOR ACCELERATED CONNECTION OF DP REQUESTS

16. The Company is considering potential options for further accelerating connection of large loads, including possible location specific solutions, as it recognizes the need to incorporate flexibility into the large loads connection process. In continuing to evaluate this

topic, the Company's top priorities are ensuring the reliability of the grid, followed closely with continuing to ensure affordability. In addition, as the Commission heard at its recent Data Center Load Technical Conference (Case No. PUR-2024-00144), there are a number of ongoing proceedings and actions at FERC and PJM that will directly inform the Company's analysis of potential fast-tracking options for connecting large loads. The Company is committed to developing solutions that are workable, non-discriminatory, and support the safe and reliable connection of all customers, both large and small.

17. While the Company today does not propose any specific "fast-track" rules related to its large-load connection queue, or outside of that process, the Company understands the importance of the issue and will continue working closely with stakeholders to develop potential flexibility solutions to help increase the speed to power for its large load customers. Company Witness Gardner discusses the Company's position on fast-tracking in further detail.

PROCESS EVOLUTION AND UPDATES

18. All told, the Company's large-load connection process represents a comprehensive, policy-driven framework designed to support continued load growth while protecting the reliability and affordability of service for all customers. The process enables the Company to mitigate the risk of network constraints, avoid stranded investment associated with requests that do not materialize, and ensure that system expansion proceeds in a manner consistent with prudent utility planning and the long-term interests of all customers.

19. As stated in the direct testimonies of Company Witnesses Gardner and Vitiello, the large-load connection process continues to evolve over time based on changes in customer requests and the conditions on the electrical grid. Updates to the Standards will be made as needed and incorporated into the FIR annually, as required by NERC.

CONCLUSION

WHEREFORE, Dominion Energy Virginia respectfully requests the Commission provide appropriate notice of this Application, issue a procedural order, approve the Large-Load Connection Queue Process Standards, and grant such other and further relief as it deems necessary and appropriate.

Respectfully submitted,

VIRGINIA ELECTRIC AND POWER COMPANY

By: Vishwa Bhargava Link

Paul E. Pfeffer
David J. DePippo
Dominion Energy Services, Inc.
600 East Canal Street
Richmond, Virginia 23219
(804) 787-5607 (PEP)
(804) 819-2411 (DJD)
paul.e.pfeffer@dominionenergy.com
david.j.depippo@dominionenergy.com

Vishwa Bhargava Link
Andrea R. Kells
Briana M. Jackson
McGuireWoods LLP
Gateway Plaza
800 East Canal Street
Richmond, Virginia 23219
(804) 775-4330 (VBL)
(919) 755-6614 (ARK)
(804) 775-1323 (BMJ)
vlink@mcguirewoods.com
akells@mcguirewoods.com
bmjackson@mcguirewoods.com

Counsel for Virginia Electric and Power Company

February 2, 2026