

ULTRASONIC METER
INSPECTION REPORT



Location & USM Data

USM	New USM 1	Matrix version	149	Reference	automatic
Site	翔安二期A	CPU CRC	1AB7	Time	7/30/2024 2:22:31 PM
Unit Number	832362	fiscal par. CRC	CD79	Found	Ref.
Log Start	7/30/2024 2:57:11 PM	piecewise lin. CRC	0000	Gas Velocity	4.38 m/s 4.01 m/s
Log Finish	7/30/2024 2:59:10 PM	Config. Status	Error!		

Counters

		Tot. Volume d.1	Tot. VolumeErr d.1	Tot. Volume d.2	Tot. VolumeErr d.2
Start	7/30/2024 2:57:11 PM	000002113.34 m3	000000000.75 m3	000000000.44 m3	000000000.14 m3
End	7/30/2024 2:59:10 PM	000002122.03 m3	000000000.75 m3	000000000.44 m3	000000000.14 m3
Diff.	00:02:00	8.69 m3	0.00 m3	0.00 m3	0.00 m3

Flow Profile	Velocity(m/s)			In Plane Velocity Ratios				Swirl	Profile Factor		Symmetry							
	Plane	Path		Path	Found	Ref.	Dev. (%)											
	1	1	4.126	1/2	1.0061	0.9969	0.9156	0.096	1.124		1.011							
		2	4.101															
	2	3	4.675	3/4	1.0090	1.0137	-0.4667	0.147										
	4	4.633																
	3	5	4.183	5/6	1.0085	1.0012	0.7236	0.141										
		6	4.148															
PASS	Marginal Limit			±5.0000				±10.000	1.110 ±0.200		1.000 ±0.200							
	Fail Limit			±10.0000				±15.000	±0.300		±0.300							
Performance & Speed of Sound	Performance (%)			SoS (m/s)		SoS Deviation (Pn/Avg. %)			Speed of Sound (m/s)									
	Plane	Path			Found	Ref.	Diff.	Meter	AGA10	Dev. (%)								
	1	1	100	423.719	-0.01	0.01	-0.02	423.750	423.47	0.07								
		2	100	423.779	0.01	0.02	-0.01											
	2	3	100	423.720	-0.01	-0.02	0.02	Source AGA10 SoS: calculated by RMGViewUSM										
		4	100	423.760	0.00	-0.01	0.02											
	3	5	100	423.713	-0.01	-0.01	-0.00											
		6	100	423.810	0.01	0.02	-0.00											
Average		100	423.750															
PASS	Marginal Limit			85		±2.00	±5.00	±5.00										
	Fail Limit			33		±5.00	±10.00	±10.00										
Transducers	Transducer Gain (dB)												SNR (dB)					
					1				2				1		2			
					Deviation				Deviation				Deviation Formula					
	Plane	Path	Found	Ref.	Found	Ref.	Diff.	Found	Ref.	Found	Ref.	Diff.						
	1	1	9.7	9.7	0.12	0.12	0.00	9.6	9.6	-0.19	-0.19	0.00	AGC1 - (AGC1+AGC2+AGC5+AGC6)/4				39.11	36.16
		2	9.8	9.8	0.20	0.20	0.00	9.8	9.8	0.01	0.01	0.00	AGC2 - (AGC1+AGC2+AGC5+AGC6)/4				36.15	36.16
	2	3	11.4	11.4	-0.26	-0.26	0.00	11.2	11.2	-0.51	-0.51	0.00	AGC3 - (AGC3+AGC4)/2				40.17	41.56
		4	11.9	11.9	0.26	0.26	0.00	12.2	12.2	0.51	0.51	0.00	AGC4 - (AGC3+AGC4)/2				36.33	36.81
3	5	9.3	9.3	-0.24	-0.24	0.00	9.9	9.9	0.09	0.09	0.00	AGC5 - (AGC1+AGC2+AGC5+AGC6)/4				36.20	36.02	
	6	9.5	9.5	-0.08	-0.08	0.00	9.9	9.9	0.09	0.09	0.00	AGC6 - (AGC1+AGC2+AGC5+AGC6)/4				36.46	35.57	
PASS	Marginal Limit				10.00		10.00				10.00		10.00		20.0		20.0	
	Fail Limit				20.00		20.00				20.00		20.00		15.0		15.0	
AGA10 Input	Pressure	54.4 bara			Constituent		Normalized		Constituent		Normalized		Constituent		Normalized			
	-Source	Input in RMGViewUSM					Mol %				Mol %				Mol %			
	Temperature	27.9 ° C			Methane		95.643		Hexane		0.000		Hydr. Sulphide		0.000			
	-Source	Input in RMGViewUSM			Ethane		2.979		Heptane		0.000		Helium		0.000			
					Propane		0.804		Octane		0.000		Argon		0.000			
					Iso Butane		0.167		Nonane		0.000		Oxygen		0.000			
					Normal Butane		0.212		Decane		0.000		Hydrogen (H2)		0.000			
					Iso Pentane		0.019		Carbon Dioxide		0.000		Water		0.000			
					Normal Pentane		0.005		Nitrogen		0.171		Total		100.000			
					Neo Pentane		0.000		Carbon Monoxide		0.000							
	Instrument Calibration	GC Calibration			Pressure Transmitter						Temperature Transmitter							
		Test Run	Found	Left	Test Ref.	Found	Left	Test Ref.	Found	Left	Test Ref.	Found	Left					
Ref. Gas:																		

Performed by:

Witnessed by:

Remarks:

Date:

