## DECLARATION OF PERFORMANCE NO. 25022016 VARIANT N EC



Product FLAMRO Variant N EC

1. Unique identification code of the product-type RA-15-0802

2. Intended use Pipe sealing

3. Manufacturer FLAMRO Brandschutz-Systeme GmbH

56291 Leiningen

Germany

4. Authorised representative **not relevant** 

5. System(s) of AVCP System 1

6a) Harmonised standard **not relevant** 

6b) European Assessment Document ETAG Nº 026 Part 2, August 2011

European Technical Assessment ETA-15/0802

Technical Assessment Body Österreichisches Institut für Bautechnik, OIB Wien

Notified body/ ies Materialprüfanstalt für das Bauwesen Braunschweig,

Nº 0761

## 7. Declared performances

Essential characteristics	Performance	Harmonised technical specification
Fire resistance as a pipe sealing for combustible or non-combustible non-insulated or insulated pipes in min. 94mm thick flexible walls -, rigid walls - or in min 150mm thick rigid floor constructions by means of the fire protection collar type Variant N EC with a maximum dimension of 160 mm. *)	Max. El 240 U/C or Max. El 240 U/U	ETA-15/0802
Durability and serviceability	use category type Y <sub>1</sub>	
Air permeability	NPD	
Water permeability	NPD	

## **DECLARATION OF PERFORMANCE NO. 25022016 VARIANT N EC**



Release of dangerous substances	none	
Mechanical resistance and stability	NPD	
Resistance to impact/ movement	NPD	
Adhesion	NPD	
Airborne sound insulation	NPD	
Thermal properties	NPD	
Water vapour permeability	NPD	
Components – reaction to fire: ROKU®Strip ROKU®Strip EM Metal strap Metal hook FLAMRO BSS	Class acc. to EN 13501-1 E E A1 A1 E	

8. Appropriate Technical Documentation / Specific Technical Documentation:

not relevant

Online-copy of Declaration of Performance

www.flamro.de

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Dr. Hemp, Head of R & D / Authorised officer

FLAMRO Brandschutz-Systeme GmbH

Olin r. West

<sup>\*)</sup> according to ETA-15/0802