

PROJECT 26-014 — Riverside Community Center	DOCUMENT CONTROL RFI · RFI-027 · Original Issue
ISSUE DATE / RESPONSE DUE 2026-07-25 / 2026-08-01	ISSUED BY Jordan Ramirez

RFI	
SUBJECT Coordination of lobby storefront head, structure, and concealed fire protection	
RESPONSIBLE PARTY Morgan Lee, AIA — Harbor Design Studio	REQUESTED RESPONSE DATE 2026-08-01

QUESTION	
QUESTION Architectural detail A8.31/5 locates the interior storefront head at elevation 10'-0" AFF. Structural detail S5.12/3 shows a continuous HSS member at elevation 10'-2" AFF, while the reflected ceiling plan indicates a 9'-10" ceiling with concealed sprinkler coverage. Please confirm the controlling storefront head elevation and provide the required attachment detail between the aluminum storefront framing and the structural HSS. Please also confirm whether the sprinkler branch line may pass through the resulting 2-inch zone or whether the ceiling and storefront head should be lowered together. The requested clarification is needed before storefront release so the glazing package, ceiling framing, and fire-protection layout can be coordinated without field modification.	

CONTRACTOR SUGGESTION	
CONTRACTOR SUGGESTION Maintain the structural HSS elevation shown on S5.12/3. Set the storefront head at 9'-10" AFF, align it with the finished ceiling, and use a slotted clip connection designed by the storefront delegated-design engineer. Route the sprinkler branch line above the HSS and provide flexible drops to the concealed heads.	

REFERENCES	
DRAWING REFERENCES A2.21, A8.31/5, A9.12, FP2.21, S5.12/3	SPECIFICATION REFERENCES 08 41 13 Aluminum-Framed Entrances and Storefronts; 21 13 13 Wet-Pipe Sprinkler Systems

RESPONSE	
RESPONSE —	

DISTRIBUTION AND FILE RECORD
OFFICIAL ROUTING SNAPSHOT To: Morgan Lee, AIA; Priya Shah, PE CC: Alex Thompson Delivery: Record only Included files: RFI-027-coordination-markup.pdf (6e061b517b08...); storefront-vendor-sketch-SK-12.pdf (a836bff26693...)

This RFI is a controlled project record. The official number is assigned when the RFI is issued.