

CYBERSECURITY CONTROL ASSESSMENT REPORT

MATRIX GROUP GLOBAL LLC • ENTERPRISE SECURITY & COMPLIANCE OPERATIONS

Audit Control ID	SEC-2026-802	Assessment Date	May 30, 2026
Target Organization	GreenEnergy Dynamics		
Lead Lead Assessor	Siddharth Mehta, CISSP	Assessment Scope	SCADA Perimeter Network Security Controls

OVERALL SECURITY POSTURE SCORE: 68/100 (ACTION REQUIRED)

1. KEY VULNERABILITY / COMPLIANCE FINDING

Unencrypted telemetry data streams detected passing through public internet routing nodes without active VPN isolation tunnels.

2. MANDATORY SECURITY REMEDIATION DIRECTIVES

Deploy hardware-accelerated IPSec tunnels immediately across all remote edge grid nodes and enforce TLS 1.3 protocol rules.

This document represents an internal, legally privileged security assessment. Dissemination must adhere strictly to established corporate security verification policies.