

ASSET MAINTENANCE & ENGINEERING ACTION REPORT

MATRIX GROUP GLOBAL LLC • CORPORATE FACILITIES & EQUIPMENT INFRASTRUCTURE REGISTRY

Work Order ID	MNT-2026-301	Execution Date	May 30, 2026
Target Asset Name	Primary HVAC Compressor Unit #4		
Assigned Technician	Arthur Curry, Facilities Tech	Physical Location	HQ Facility, Roof Sector B

CURRENT MAINTENANCE STATUS: COMPLETED

1. REPORTED ISSUE / DIAGNOSTIC BASELINE FAULTS

Continuous vibration alarms flagged by automated building sensors, indicating potential mechanical misalignment or bearing degradation.

2. CORRECTIVE REMEDIATION ACTIONS EXECUTED

Executed structural leveling checks, replaced worn vibration isolation dampening mounts, and re-greased the primary drive bearings.

This document serves as an authorized technical record. All post-maintenance asset metrics have been verified against corporate equipment safety rules and re-logged into the primary operational framework dashboard.

Field Technician Signature

Facilities Operations Sign-off