

ASSET MAINTENANCE & ENGINEERING ACTION REPORT

MATRIX GROUP GLOBAL LLC • CORPORATE FACILITIES & EQUIPMENT INFRASTRUCTURE REGISTRY

Work Order ID	MNT-2026-302	Execution Date	May 30, 2026
Target Asset Name	Server Rack Cooling Fan Array 2B		
Assigned Technician	Liam Brookes, IT Support	Physical Location	Datacenter Floor 3, Row E

CURRENT MAINTENANCE STATUS: COMPLETED

1. REPORTED ISSUE / DIAGNOSTIC BASELINE FAULTS

RPM outputs dropped below the mandatory operational safety threshold, triggering minor thermal alerts on neighboring cloud node switches.

2. CORRECTIVE REMEDIATION ACTIONS EXECUTED

Hot-swapped the secondary backup cooling module, cleared accumulated dust blocks from the intake vents, and validated system RPM parameters.

This document serves as an authorized technical record. All post-maintenance asset metrics have been verified against corporate equipment safety rules and re-logged into the primary operational framework dashboard.

Field Technician Signature

Facilities Operations Sign-off