

ASSET MAINTENANCE & ENGINEERING ACTION REPORT

MATRIX GROUP GLOBAL LLC • CORPORATE FACILITIES & EQUIPMENT INFRASTRUCTURE REGISTRY

Work Order ID	MNT-2026-309	Execution Date	May 30, 2026
Target Asset Name	Main Water Filtration & Loop Pump		
Assigned Technician	Arthur Curry, Facilities Tech	Physical Location	Facility Basement, Utility Hub 1

CURRENT MAINTENANCE STATUS: COMPLETED

1. REPORTED ISSUE / DIAGNOSTIC BASELINE FAULTS

The primary particulate filter reached maximum pressure drop parameters, triggering automated replacement alerts.

2. CORRECTIVE REMEDIATION ACTIONS EXECUTED

Isolated the primary fluid loop, replaced the 5-micron sediment core filter, and inspected downstream seal assemblies for leakage.

This document serves as an authorized technical record. All post-maintenance asset metrics have been verified against corporate equipment safety rules and re-logged into the primary operational framework dashboard.

Field Technician Signature

Facilities Operations Sign-off