

ASSET MAINTENANCE & ENGINEERING ACTION REPORT

MATRIX GROUP GLOBAL LLC • CORPORATE FACILITIES & EQUIPMENT INFRASTRUCTURE REGISTRY

Work Order ID	MNT-2026-310	Execution Date	May 30, 2026
Target Asset Name	Enterprise HQ Fiber Patch Panel Stack		
Assigned Technician	Ethan Hunt, Network Admin	Physical Location	Main Telecommunications Room (MDF)

CURRENT MAINTENANCE STATUS: COMPLETED

1. REPORTED ISSUE / DIAGNOSTIC BASELINE FAULTS

Slight light-attenuation spikes detected on core fiber backhaul strands linking Floor 4 downstream nodes.

2. CORRECTIVE REMEDIATION ACTIONS EXECUTED

Inspected optical ports via digital scoping, cleaned fiber tips with specialized lint-free cleaning tools, and re-seated transit patch cables.

This document serves as an authorized technical record. All post-maintenance asset metrics have been verified against corporate equipment safety rules and re-logged into the primary operational framework dashboard.

Field Technician Signature

Facilities Operations Sign-off