

ASSET MAINTENANCE & ENGINEERING ACTION REPORT

MATRIX GROUP GLOBAL LLC • CORPORATE FACILITIES & EQUIPMENT INFRASTRUCTURE REGISTRY

Work Order ID	MNT-2026-313	Execution Date	May 30, 2026
Target Asset Name	Kitchen Walk-In Blast Freezer #1		
Assigned Technician	Mateo Silva, Executive Chef	Physical Location	Culinary Prep Center, Back of House

CURRENT MAINTENANCE STATUS: COMPLETED

1. REPORTED ISSUE / DIAGNOSTIC BASELINE FAULTS

Defrost heating element cycle failed to engage, leading to ice buildup on evaporator coil surfaces and higher ambient temperatures.

2. CORRECTIVE REMEDIATION ACTIONS EXECUTED

Cleared physical ice blockages manually, replaced the faulty electronic defrost timer relay module, and verified temperature drops.

This document serves as an authorized technical record. All post-maintenance asset metrics have been verified against corporate equipment safety rules and re-logged into the primary operational framework dashboard.

Field Technician Signature

Facilities Operations Sign-off