



CHECKLIST PM

LIQUID PUMP

Booster Compression Plant (BCP) Seng



Location : BCP Seng
Tag No. : P-703
Type : DIAPHRAGM
Capacity : 125 Psi (8.6 Bar)
Unit Name : K.O Drum Pump
Manufacture : VERSAMATIC/ SN:2590467

Date : 16 July 2026
Flow Meter : -
Down time : - Minutes
Running Hour : -
Next PM (RH) : 16 Aug 2026

Please ensure every item below has been ticked at the end of every service:

	YES	NO					
1	✓		Inspect check ball valve Suction and Discharge	Repair		Replace	
2	✓		Inspect Hausing pump	Check	✓	Change	
3	✓		Check line leaking	Check	✓	Change	
4	✓		Inspect Diaphragm pump	Check	✓	Change	
5		✓	Inspect and check Shaft pump	Check		Tighten	
6		✓	Inspect coupling flange Pipe Suction & Discharge	Check		Tighten	
7	✓		Check of Pressure Gauge	Clean	✓	Adjust	
8		✓	Check terminal connection block	Clean		Replace	
9		✓	Check electrical connection	Check		Tighten	
10		✓	Check cover body of motor from corrosion	Clean		Paint	
11		✓	Check automatic running of motor (Auto/MAN)	Check		Re-wiring	
12	✓		Greasing Equipment				

Running after service

13	✓		Check of push button controller	✓	Function	✓	Repair
14	✓		Check of voltage and ampere	✓	VAC	✓	A
15	✓		Check Discharge Pressure	✓	PSI		
16	✓	A	Check rotary of motor	✓	CW	✓	CCW

No	Part/material Use	Description	Quantity	Remarks

Serviced by :

Perform By

Checked By

Acknowledge By

1. *to tangsi*
2. *kar farm*
3.
4.

[Signature]
MTC Tech

[Signature]
MTC Spv.

[Signature]
Prod.Spv