



Deficiency Report

Property Information

Test Site with Missing Locations

456 Override Street

Vancouver

Inspection Date:

December 15, 2024

Earth Wind Fire Services Inc.

Fire Protection Services

604-299-1030 | info@myfirepro.ca



Test Site with Missing Locations

456 Override Street
Vancouver, BC

Job #: TEST-OVERRIDE-001

12/15/2024

INSPECTION SUMMARY

Service Date: December 15, 2024 | Job #: TEST-OVERRIDE-001 | Technician: Test Technician

3 DEFICIENCIES IDENTIFIED

2 Critical • 1 Major

Please review the enclosed deficiency report for full details and corrective action recommendations.



Test Site with Missing Locations

456 Override Street
Vancouver, BC

Job #: TEST-OVERRIDE-001
12/15/2024

Executive Summary

Deficiency Summary by Severity

Severity	Count	Status
Critical	2	2 Issues
Major	1	1 Issue
Minor	0	None
Total	3	3 Issues

Deficiency Summary by System

- Other/Uncategorized: 3 deficiencies

Overall Status:

Critical deficiencies require immediate attention and corrective action.



December 15, 2024

TEST SITE WITH MISSING LOCATIONS

TEST CUSTOMER

ATTENTION: JANE ADMIN

EMAIL: admin@test.com

RE: Fire Protection Inspection — Deficiencies Identified

Test Site with Missing Locations — 456 Override Street

Job #TEST-OVERRIDE-001 | Service Date: December 15, 2024

Dear Jane Admin,

On December 15, 2024, our certified technician, Test Technician, conducted the annual fire protection inspection at Test Site with Missing Locations, located at 456 Override Street, in accordance with CAN/ULC S536:2019 and applicable BC Fire Code requirements.

During our inspection, 3 deficiencies were identified that require corrective action. The full details, corrective action recommendations, and associated costs are outlined in the enclosed Deficiency Report.

2 Critical

1 Major

To authorize the corrective work, please sign and return the enclosed authorization form. This quotation is valid for 30 days from the date of this letter. Verbal authorization is not accepted — a signed copy must be returned before work will be scheduled.

If you have any questions or require additional information, please do not hesitate to contact our office.

Sincerely,

Earth Wind Fire Services Inc.

Test Technician

Fire Safety Inspector

604-299-1030

tech@test.com

This letter is intended solely for the use of the addressee. Earth Wind & Fire Protection Services accepts no liability for any loss or damage arising from reliance on this document by any other party. All prices are in Canadian dollars and subject to applicable taxes.



Test Site with Missing Locations

456 Override Street
Vancouver, BC

Job #: TEST-OVERRIDE-001

12/15/2024

& TEST MODE — Missing location data. See appendix.

Smoke Alarm Deficiencies

#	Location & Description	System / Device	Cost
10	Location: TBD. Test deficiency 1 with missing location	Smoke Alarm	\$100.00
11	Location: TBD. Test deficiency 2 with missing location	Smoke Alarm	\$100.00
12	Location: TBD. Test deficiency 3 with missing location	Smoke Alarm	\$100.00

Subtotal: \$300.00

GST + PST (12%): \$36.00

Total: \$336.00

Terms & Conditions

- The proposed quotation is valid for 30 days from the date of receipt of this report. Cancellation after approval of materials will incur a 25% restocking fee.
- Scope of work is based on information in this report. Additional costs for permits, engineering, drawings, aerial lift, sub-trades, rentals, accommodations, and subcontractors will be charged separately. Drywall, fire-stopping, painting, and pipe insulation are excluded.
- GST and PST apply to materials only; GST applies to labour. Taxes are not included in quoted prices.
- All prices are based on regular business hours (8:00 AM – 4:30 PM). An environmental disposal fee of \$7.00/battery applies to all batteries removed. Travel time is included if the majority of repairs are approved simultaneously.
- Prices are based on a single mobilization. Additional trips due to access issues may be charged extra. No travel surcharge for return trips caused by stocking issues.
- A vehicle service charge of \$88.00 will be applied.



Test Site with Missing Locations
456 Override Street
Vancouver, BC

Job #: TEST-OVERRIDE-001
12/15/2024

AUTHORIZATION TO PROCEED — CORRECTIVE WORK

APPENDIX: Missing Location Information

By signing below, you authorize Earth Wind Fire Services Inc. to proceed with the corrective work detailed in this report at the quoted prices. This quotation is valid until January 14, 2025. Verbal authorization is not accepted. A signed copy must be returned before work will be scheduled.

ID	Description	Severity
10	Test deficiency 1 with missing location	CRITICAL
11	Test deficiency 2 with missing location	MAJOR
12	Test deficiency 3 with missing location	CRITICAL
Printed Name and Title		Purchase Order / Reference #



Test Site with Missing Locations

456 Override Street
Vancouver, BC

Job #: TEST-OVERRIDE-001

12/15/2024

INSPECTION, TESTING, AND MAINTENANCE OF FIRE ALARM SYSTEMS

CAN/ULC-S536:2019 — Inspection and Testing of Fire Alarm Systems

Inspection Item	Yes	No
The entire fire alarm system has been inspected and tested in accordance with CAN/ULC-S536:2019, Inspection and Testing of Fire Alarm Systems.	☐	☐
The fire alarm system is fully functional.	☐	☐
During the inspection and test, were any Deficiencies Identified? (See attached deficiency report, if applicable.)	☐	☐
During the inspection and test, were any Recommendations Identified?	☐	☐

The information in this report, which comprises 10 pages, affirms that the equipment listed here-in was tested and inspected in conformance with ULC 536:2019 (2024); Standard for Inspection and Testing of Fire Alarm Systems, applicable codes, bylaws, Standards, and the manufacturer's requirements by a qualified technician. The equipment was left in an operational condition except as noted above.

Supervising / Primary Technician Name	Certification Number / Seal	Date	Signature
Test Technician	FIRE PROTECTION ASTTBC TEST TECHNICIAN	2024-12-15	Earth Wind Fire Services Inc.

Company Conducting Test: Earth Wind Fire Services Inc.	Phone: 604-299-1030
---	----------------------------

