



Deficiency Report

Property Information

Test Building

123 Main Street
Vancouver

Inspection Date:
December 1, 2024

Inspectra Fire Protection

Fire Protection Services

604-299-1030 | info@myfirepro.ca



Test Building

123 Main Street
Vancouver, BC

Job #: TEST-001
12/1/2024

INSPECTION SUMMARY

Service Date: December 1, 2024 | Job #: TEST-001 | Technician: Jane Smith

Device / System Type	Total	Pass	Fail	N/A
Smoke Detector	10	9	1	0
Fire Extinguisher	5	5	0	0

1 DEFICIENCY IDENTIFIED

1 Major

Please review the enclosed deficiency report for full details and corrective action recommendations.

**Test Building**

123 Main Street
Vancouver, BC

Job #: TEST-001

12/1/2024

Executive Summary

Deficiency Summary by Severity

Severity	Count	Status
Critical	0	None
Major	1	1 Issue
Minor	0	None
Total	1	1 Issue

Deficiency Summary by System

- Other/Uncategorized: 1 deficiency

Overall Status:

Major deficiencies should be addressed promptly to maintain compliance.



December 1, 2024

TEST BUILDING
TEST CUSTOMER CORP
456 Customer Ave
Burnaby, BC, V5G 5J6

ATTENTION: JOHN DOE

EMAIL: john@testcustomer.com

RE: Fire Protection Inspection — Deficiencies Identified

Test Building — 123 Main Street

Job #TEST-001 | Service Date: December 1, 2024

Dear John Doe,

On December 1, 2024, our certified technician, Jane Smith, conducted the annual fire protection inspection at Test Building, located at 123 Main Street, in accordance with CAN/ULC S536:2019 and applicable BC Fire Code requirements.

During our inspection, 1 deficiency was identified that require corrective action. The full details, corrective action recommendations, and associated costs are outlined in the enclosed Deficiency Report.

1 Major

Systems and devices included in this inspection:

- Smoke Detector: 9/10 pass, 1 fail
- Fire Extinguisher: 5/5 pass

To authorize the corrective work, please sign and return the enclosed authorization form. This quotation is valid for 30 days from the date of this letter. Verbal authorization is not accepted — a signed copy must be returned before work will be scheduled.

If you have any questions or require additional information, please do not hesitate to contact our office.

Sincerely,

Inspectra Fire Protection

Jane Smith

Fire Alarm Technician

604-299-1030

jane@firepro.ca

This letter is intended solely for the use of the addressee. Earth Wind & Fire Protection Services accepts no liability for any loss or damage arising from reliance on this document by any other party. All prices are in Canadian dollars and subject to applicable taxes.

**Test Building**

123 Main Street
Vancouver, BC

Job #: TEST-001

12/1/2024

Fire Alarm Deficiencies

#	Location & Description	System / Device	Cost
1	Unit 1005. Unit 1005 smoke detector did not respond to test.	Smoke Detector	\$107.50

Subtotal: \$107.50

GST + PST (12%): \$12.90

Total: \$120.40

Terms & Conditions

- The proposed quotation is valid for 30 days from the date of receipt of this report. Cancellation after approval of materials will incur a 25% restocking fee.
- Scope of work is based on information in this report. Additional costs for permits, engineering, drawings, aerial lift, sub-trades, rentals, accommodations, and subcontractors will be charged separately. Drywall, fire-stopping, painting, and pipe insulation are excluded.
- GST and PST apply to materials only; GST applies to labour. Taxes are not included in quoted prices.
- All prices are based on regular business hours (8:00 AM – 4:30 PM). An environmental disposal fee of \$7.00/battery applies to all batteries removed. Travel time is included if the majority of repairs are approved simultaneously.
- Prices are based on a single mobilization. Additional trips due to access issues may be charged extra. No travel surcharge for return trips caused by stocking issues.
- A vehicle service charge of \$88.00 will be applied.

AUTHORIZATION TO PROCEED — CORRECTIVE WORK

By signing below, you authorize Inspectra Fire Protection to proceed with the corrective work detailed in this report at the quoted prices. This quotation is valid until December 31, 2024. Verbal authorization is not accepted. A signed copy must be returned before work will be scheduled.

Authorized Signature

Date

Printed Name and Title

Purchase Order / Reference #



Test Building

123 Main Street
Vancouver, BC

Job #: TEST-001
12/1/2024

The information in this report, which comprises 11 pages, affirms that the equipment listed here-in was tested and inspected in conformance with ULC 536:2019 (2024); Standard for Inspection and Testing of Fire Alarm Systems, applicable codes, bylaws, Standards, and the manufacturer's requirements by a qualified technician. The equipment was left in an operational condition except as noted above.

Supervising / Primary Technician Name	Certification Number / Seal	Date	Signature
Jane Smith	FIRE PROTECTION ASTTBC JANE SMITH	2024-12-01	Inspectra Fire Protection

